

MEMD Calibration Lighting Hours of Use Study

Research Plan

November 19, 2013



Energy Market Innovations



Agenda

Introduction
Sampling
Data Collection
Analysis
Schedule

Objective

Calibrate the MEMD assumptions for lighting hours-of-use (HOU) and peak coincidence factors (CF) for C&I lighting.

Why?

- It's important. Currently, lighting accounts for about 75% of expected electric energy savings
- It's an unknown. Current estimates are based on secondary data from outside of Michigan.

Definitions

Hours-of-use (HOU):

The estimated number of hours a fixture is on through-out the year

Coincidence factor

(CF): The percentage of time a fixture is on during the peak period

Current MEMD values for most non-high bay lighting:

- HOU: 3,680 hours/year
- CF: 0.90

MEMD Use

How the HOU and CF values are used

$$\text{Demand Reduction (kW savings)} = \frac{\text{Existing Watts} - \text{Replacement Watts}}{1,000}$$

$$\text{Peak Demand Reduction} = \text{Demand Reduction} \times \text{CF}$$

$$\text{Energy Savings} \left(\frac{\text{kWh}}{\text{yr}} \right) = \text{Demand Reduction} \times \text{HOU}$$

Study Design

Collect real-world data on C&I lighting from a sample of representative facilities in Michigan



Analyze and extrapolate these data to the population




Report findings to support MEMD refinement

Sampling


- Sample design balances accuracy and cost
- Scientifically designed to be representative of all C&I customers
- Pulled from actual customer records from DTE Energy and Consumers Energy
- 1800 metered fixtures (10 per 180 sites)

Facility Type	On-sites	Estimated Relative Precision at 90% CI
Industrial	35	14.9%
All Other	145	11.0%
Total	180	10.0%


Data Collection



Data Collection



Data Collection




Data Collection Schedule

- Phase I – Winter/Spring 2014
 - Recruit facilities
 - Install meters
 - Collect data for June report on HOU & CF
 - Leave meters installed
- Phase II – Summer 2014
 - Recruit new facilities as needed
 - Collect data during peak period for report update on CF

Task	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	Jun-14	Jul-14	Aug-14	Sep-14	Oct-14	
Planning																
Data Collection					Phase I						Phase II					
Data Analysis																
Reporting																
Project Management																

Metering

Hobo UX-90-002



Hobo U12-012



Analysis

Annual HOU

- Average metered HOU extrapolated to the year based on reported operating characteristics
- Facility operating hours reported alongside HOU estimates

Peak CF

- Average percentage of the peak period each metered light is on
- 3PM to 6PM on non-holiday weekdays during the three consecutive hottest days in July
- Based on modeled **and** metered data

Analysis

Results reported overall and by the following facility types:

- Assembly (churches, etc.)
- Hospital
- Industry
- Lodging
- Office
- Restaurant
- Retail
- School (K-12)
- School (College/University)
- Warehouse

Reporting Schedule

- Phase I report – June 1, 2014
 - Metered HOU
 - Modeled CF
- Phase II update – October 30, 2014
 - Update with Metered CF

Task	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	Jun-14	Jul-14	Aug-14	Sep-14	Oct-14
Planning															
Data Collection					Phase I					Phase II					
Data Analysis															
Reporting															
Project Management															

Questions

Jeremy Kraft

jkraft@emiconsulting.com

(608) 298-7190

Jess Chandler

jchandler@emiconsulting.com

(757) 224-6639