

Michigan Statewide Commercial and Industrial Lighting Hours-of- Use Study

Research Results 2014



PRESENTATION

June 17, 2014

AGENDA

- Purpose
- Key Findings
- Overview of Study
- Sample
- Methods
- Findings
- Characteristics Data

PURPOSE

Collect reliable data on C&I lighting hours-of-use (HOU) and coincidence factors (CFs) for the State of Michigan to validate and calibrate the MEMD to accurately reflect local operating conditions.

KEY FINDINGS

Hours of Use and Coincidence Factor Values

Variable	Current MEMD Value (a)	Calibrated Value (b)	Ratio (b)/(a)
Hours of Use	3,680	2,744	0.755
Coincidence Factor	0.90	0.505	0.561

^a. Current MEMD Value is based on the non-high bay estimates.

In general, what did we do?

OVERVIEW

OVERVIEW OF STUDY

- Two waves of metering
 - Wave 1 complete & included in this analysis
 - Wave 2 to be reported in Fall 2014
- Facility type incidence study
- Combined metering data from:
 - Wave 1 from this study (179 sites)
 - Lighting Controls study (377 sites)
- Aggregated logger-level data

DATA COLLECTED

Data Type	Data Collection Method ^a
Lighting Hours-of-Use	Metering
Peak Coincidence Factors	Metering
Facility Operating Hours	Field Technician Report
Inventory of Space Types	Field Technician Report
Type, Number, and Nominal Wattage of Lighting Equipment	Field Technician Report
Heating and Cooling Equipment Specifications and Usage	Field Technician Report
Facility Distribution	Incidence Study

On what is our analysis based?

SAMPLE

WAVE 1 RECRUITING

- Sample from Population of C&I customers provided by DTE and CE
- Metering contractor called to recruit participants
- \$100 incentive (split between visits)
- During recruiting call, team collected data for incidence study

WAVE 1 INCIDENCE STUDY

Facility Types as Reported by All Facilities through Incidence Study

Facility Type	Count	Percent
Apartments	53	6%
Assembly (Churches, etc.)	61	7%
Industry	65	7%
Lodging	9	1%
Medical	47	5%
Office	211	24%
Other/None of the above	59	7%
Restaurant	47	5%
Retail	288	33%
School (College/University)	1	<1%
School (K-12)	20	2%
Warehouse	25	3%
Total	886	100%
Refused to Provide	115	--

WAVE 1 RECRUITED FACILITIES


Participating Facilities by Facility Type and Utility

Facility Type	CE		DTE		Total	
	Count	%	Count	%	Count	%
Apartments	8	8%	1	1%	9	5%
Assembly	7	7%	3	4%	10	6%
Industry	10	9%	2	3%	12	7%
Lodging	1	1%	0	0%	1	1%
Medical	5	5%	4	5%	9	5%
Office	19	18%	12	16%	31	17%
Other	10	9%	7	9%	17	9%
Restaurant	6	6%	3	4%	9	5%
Retail	29	27%	39	53%	68	38%
School (K-12)	5	5%	1	1%	6	3%
Warehouse	6	6%	2	3%	8	4%
Total	106	100%	74	100%	180	100%

WAVE 1 RECRUITED FACILITIES

Locations of Facilities in the Metering Study

- Apartments
- Assembly (Churches, etc.)
- Industry
- Lodging
- Medical
- Office
- Other
- Restaurant
- Retail
- School (K-12)
- Warehouse



How did we come to our results?

METHODS

METHODS – ON-SITE

- Walkthrough of facility
- Interview with on-site representative
- Facility lighting inventory
- Logger installation


METHODS - ANALYSIS

- Cleaned logger data
- Developed daily load profiles for each site
- Converted daily load profiles to annual hours and estimated CF
- Aggregated logger data to spaces and facilities

METHODS - AGGREGATION

1. Aggregate to metered value by Space Type by metered space lighting load
2. Aggregate values for metered Space Types to Facility by Space lighting load
3. Aggregate values for Facilities to Facility Type by Facility Lighting Load
4. Aggregate values to C&I overall by incidence study

Facility 1a



Facility 1b



What did we find out?

FINDINGS

LIGHTING HOU

Hours-of-Use by Facility Type

Facility Type	HOU	Std. Dev.	Loggers (n)	Relative Precision
Apartments	5,184	2325	55	10%
Assembly (Churches, etc.)	1,686	1171	99	12%
Industry	2,575	1205	86	8%
Lodging	1,515	NA	6	NA
Medical	3,222	2276	87	13%
Office	1,974	1113	1123	3%
Other	1,414	690	124	7%
Restaurant	4,046	1444	65	7%
Retail	2,830	1383	461	4%
School (K-12)	2,239	779	1276	2%
Warehouse	3,587	1980	1198	3%
Weighted Total	2,744	991.00	4,580	1%

SPACE HOU BY TYPE

Hours-of-Use by Space Type by Facility Type

Space Type	Facility Type										
	Apartments	Assembly	Industry	Lodging	Medical	Office	Other	Restaurant	Retail	School (K-12)	Warehouse
Assembly	4,890	1,064	NA	NA	NA	NA	899	NA	NA	NA	NA
Break Room	NA	884	1,257	NA	1,200	1,829	1,682	NA	1,802	1,303	2,918
Cafeteria	NA	375	NA	NA	NA	NA	NA	NA	NA	2,356	1,775
Classroom	NA	596	NA	NA	NA	NA	172	NA	4,842	1,429	NA
Conference	4,035	488	1,671	NA	675	971	261	NA	1,018	1,221	1,277
Dining	1,448	NA	NA	NA	NA	NA	1,758	4,452	NA	NA	NA
Equipment	NA	707	780	NA	975	2,064	1,610	1,324	2,034	NA	NA
Gym	563	101	NA	NA	NA	NA	1,406	NA	6,566	2,545	NA
Hallway	8,528	1,424	2,995	NA	3,778	1,914	2,098	4,896	2,262	3,598	2,483
Kitchen	2,329	1,308	1,936	NA	3,818	2,037	308	5,081	1,737	1,626	1,925
Library/CPU	NA	1,782	NA	NA	NA	NA	NA	NA	NA	1,767	NA
Office (Closed)	1,929	678	1,620	NA	1,291	1,671	1,575	4,683	2,449	1,444	1,994
Office (Open)	3,020	2,734	2,334	8,760	2,455	2,378	2,223	NA	3,417	2,338	2,758
Other	4,366	2,213	1,215	NA	2,523	2,550	1,853	NA	3,263	2,111	2,202
Production	NA	NA	2,959	NA	NA	1,972	NA	NA	2,897	NA	3,351
Restroom	38	873	431	267	685	1,212	1,679	3,212	587	1,515	1,140
Retail	NA	3,184	2,632	NA	2,716	3,558	NA	NA	2,825	NA	NA
Storage	1,904	401	927	17	984	992	1,325	3,077	1,801	1,420	1,516
Warehouse	NA	NA	2,195	NA	NA	1,661	1,945	NA	2,550	NA	2,295

PRELIMINARY CF

Preliminary Coincidence Factors by Facility Type

Facility Type	CF	Std. Dev.	Loggers (n)	Relative Precision
Apartments	0.71	0.27	55	8%
Assembly (Churches, etc.)	0.28	0.22	99	13%
Industry	0.45	0.29	86	11%
Lodging	0.17	NA	6	NA
Medical	0.59	0.26	87	8%
Office	0.35	0.20	1123	3%
Other	0.27	0.18	124	10%
Restaurant	0.78	0.25	65	6%
Retail	0.61	0.29	461	4%
School (K-12)	0.19	0.17	1276	4%
Warehouse	0.52	0.30	1198	3%
Weighted Total	0.51	0.18	4,580	1%

SPACE CF BY TYPE

Preliminary Coincidence Factors, by Space Type

Space Type	Facility Type										
	Apartments	Assembly	Industry	Lodging	Medical	Office	Other	Restaurant	Retail	School (K-12)	Warehouse
Assembly	0.62	0.14	NA	NA	NA	NA	0.18	NA	NA	NA	NA
Break Room	NA	0.21	0.20	NA	0.24	0.38	0.25	NA	0.39	0.06	0.49
Cafeteria	NA	0.07	NA	NA	NA	NA	NA	NA	NA	0.22	0.21
Classroom	NA	0.05	NA	NA	NA	NA	0.12	NA	0.81	0.12	NA
Conference	0.66	0.06	0.32	NA	0.06	0.19	0.04	NA	0.25	0.12	0.25
Dining	0.17	NA	NA	NA	NA	NA	0.33	0.88	NA	NA	NA
Equipment	NA	0.06	0.09	NA	0.26	0.36	0.33	0.09	0.37	NA	NA
Gym	0.18	0.00	NA	NA	NA	NA	0.88	NA	0.89	0.21	NA
Hallway	0.98	0.27	0.58	NA	0.75	0.33	0.44	0.93	0.51	0.35	0.41
Kitchen	0.37	0.21	0.44	NA	0.86	0.32	0.03	0.99	0.42	0.12	0.35
Library/CPU	NA	0.20	NA	NA	NA	NA	NA	NA	NA	0.12	NA
Office (Closed)	0.48	0.11	0.25	NA	0.31	0.29	0.27	0.92	0.51	0.13	0.35
Office (Open)	0.68	0.54	0.37	1.00	0.54	0.44	0.45	NA	0.60	0.20	0.46
Other	0.56	0.44	0.31	NA	0.48	0.44	0.16	NA	0.67	0.28	0.41
Production	NA	NA	0.42	NA	NA	0.42	NA	NA	0.70	NA	0.48
Restroom	0.01	0.16	0.06	0.03	0.15	0.21	0.29	0.60	0.11	0.12	0.21
Retail	NA	0.35	0.36	NA	0.42	0.70	NA	NA	0.66	NA	NA
Storage	0.49	0.06	0.10	0.00	0.15	0.13	0.26	0.51	0.40	0.12	0.24
Warehouse	NA	NA	0.27	NA	NA	0.30	0.23	NA	0.52	NA	0.38

What type of buildings did we meter?

CHARACTERISTICS


WAVE 1 FACILITY SIZE

Square Footage by Facility Type in Wave 1

Facility Type	Count	Mean	S.D.
Apartments	9	3,644	3,880
Assembly (e.g., churches)	7	36,000	67,863
Industry	9	14,759	18,528
Medical	7	3,986	3,040
Office	24	4,337	5,700
Other	11	8,059	12,816
Restaurant	6	3,029	943
Retail	52	5,857	8,088
School (K-12)	1	38,000	NA
Warehouse	8	29,288	63,371
Total	134	14,696	23,845


OFFICE FACILITY SIZE TO HOU

Office Facility Lighting HOU by Facility Size, Wave 1 and LCS



OFFICE FACILITY SIZE TO HOU CONTINUED

Office Facility Lighting HOU by Facility Size, Wave 1 and LCS
Facilities Less than 100,000 Square Feet



HEATING EQUIPMENT

Heating Type Inventory by Space in Wave 1

Heating Type	Number of Spaces	Percent
Boiler (Hot Water)	631	19.4%
Boiler (Steam)	170	5.2%
Electric Resistance	24	0.7%
Gas Furnace	1,584	48.8%
Gas Furnace (Condensing)	171	5.3%
Heat Pump (Air)	3	0.1%
Heat Pump (Geothermal)	174	5.4%
None	70	2.2%
Other	112	3.4%
Radiant	11	0.3%
Unknown	299	9.2%
Total	3,249	100.0%

COOLING EQUIPMENT

Cooling Type Inventory by Space

Cooling Type	Number of Spaces	Percent
Chiller Air Cooled	47	1.4%
Chiller Centrifugal	123	3.8%
Chiller Scroll	38	1.2%
Direct Expansion	1,710	52.6%
Heat Pump Air	3	0.1%
Heat Pump Geo	175	5.4%
None	771	23.7%
Other	71	2.2%
Unknown	311	9.6%
Total	3,249	100.0%

QUESTIONS?

Jeremy Kraft

jkraft@emiconsulting.com

206-621-1160

Jess Chandler

jchandler@emiconsulting.com

757-224-6639

John Flotterud

jdf@michaelsenergy.com

608-799-4452

APPENDIX SLIDES

EXAMPLE LOAD PROFILE

