



Water Quality Monitoring
3rd Quarter 2015

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS				
Distribution System Location #	Sample Point Name & Address	Sample Date	Time	Temperature (C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)
#1	Arby's 3742 Davison Rd.	9/2/2015	10:25	22.3	0.392	7.53	38	40.1
#2	BP Gas Station 822 S.Dort Hwy	9/2/2015	10:39	22.4	0.399	7.48	38	41.7
#3	Liquor Palace 3302 S. Dort Hwy	9/2/2015	10:55	23.8	0.380	7.49	46	40.1
#4	Taco Bell 3606 Corunna Rd.	9/2/2015	11:34	21.9	0.397	7.51	42	40.1
#5	University Market 2501 Flushing Rd.	9/2/2015	11:48	23.6	0.396	7.47	40	45.7
#6	Salem Housing 3216 MLK Blvd.	9/2/2015	12:16	23.8	0.404	7.76	42	40.9
#7	Rite-Aid 5018 Clio Rd.	9/2/2015	12:32	20.9	0.394	7.45	44	40.9
#8	N. Flint Automotive 6204 N. Saginaw St.	9/2/2015	12:50	22.6	0.403	7.48	46	42.5
CS	Cedar Street Reservoir & Pump Station	9/2/2015	11:16	21.9	0.398	7.41	42	40.9
WS	West Side Reservoir & Pump Station	9/2/2015	12:00	22.2	0.408	7.38	40	43.3
N/A	Russell Collection Agency 3285 Van Slyke Rd	9/30/2015	15:34	19.8	0.479	7.30	38	41.7
N/A	Southwestern Academy High School 1420 W.12th St.	9/30/2015	15:21	22.4	0.478	7.40	40	38.5
N/A	St. Pius Church 3139 Hogarth Ave.	9/30/2015	16:06	22.7	0.478	7.46	40	41.7
N/A	Rite-Aid 3521 Corunna Rd.	9/17/2015	12:00	21.6	0.420	7.48	40	46.5
N/A	Clio Rd. Pharmacy 4902 Clio Rd.	9/17/2015	12:27	23.0	0.418	7.44	40	47.3
N/A	Tim Hortons 1274 Ballanger Hwy.	9/17/2015	12:15	22.5	0.421	7.46	40	43.3
N/A	Arby's 3559 S. Dort Hwy.	9/30/2015	12:58	20.5	0.482	7.40	42	39.3
N/A	Ya Ya's 519 S. Dort Hwy	9/30/2015	13:54	23.3	0.472	7.36	40	39.3
N/A	Taco Bell 1740 S. Dort Hwy	9/30/2015	13:09	22.1	0.479	7.42	40	41.7
N/A	Grandma's Recipe 3538 Richfield Rd.	9/30/2015	12:30	21.9	0.477	7.45	40	41.7
N/A	Flint City Hall 1101 S. Saginaw St.	9/30/2015	17:31	20.7	0.467	7.43	38	42.5
N/A	Quizzno's 3818 E. Court St.	9/30/2015	12:43	22.0	0.475	7.46	42	41.7
N/A	Whitehorse Tavern 621 W. Court St.	9/17/2015	11:48	21.8	0.424	7.44	44	47.3
N/A	Flint Public Library 1026 E. Kearsley Rd.	9/17/2015	12:48	22.9	0.425	7.69	44	40.9
N/A	Rite-Aid 3717 Fenton Rd.	9/17/2015	11:38	20.2	0.419	7.43	42	50.1



Water Quality Monitoring
2nd Quarter 2015

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS				
Distribution System Location #	Sample Point Name & Address	Sample Date	Time	Temperature (C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)
#1	Arby's 3742 Davison Rd.	5/14/2015	10:17	15.1	0.475	7.53	62	62.5
#2	BP Gas Station 822 S.Dort Hwy	5/14/2015	13:32	14.7	0.471	7.51	56	60.9
#3	Liquor Palace 3302 S. Dort Hwy	5/14/2015	10:51	16.2	0.470	7.49	60	63.3
#4	Taco Bell 3606 Corunna Rd.	5/14/2015	11:25	15.2	0.471	7.52	58	61.7
#5	University Market 2501 Flushing Rd.	5/14/2015	11:42	16.5	0.480	7.48	61	64.1
#6	Salem Housing 3216 MLK Blvd.	5/14/2015	12:04	13.9	0.490	7.58	68	64.9
#7	Rite-Aid 5018 Clio Rd.	5/14/2015	12:25	11.9	0.485	7.52	64	65.7
#8	N. Flint Automotive 6204 N. Saginaw St.	5/14/2015	12:44	17.6	0.460	7.52	47	61.7
CS	Cedar Street Reservoir & Pump Station	5/12/2015	9:28	14.1	0.470	7.80	76	56.1
WS	West Side Reservoir & Pump Station	5/13/2015	10:22	17.1	0.497	7.59	70	67.3
N/A	Russell Collection Agency 3285 Van Slyke Rd	6/22/2015	12:06	19.1	0.512	7.61	77	69.7
N/A	Southwestern Academy High School 1420 W.12th St.	6/17/2015	11:14	22.3	0.523	7.66	84	70.5
N/A	Cummings Elementary School G-2200 Walton St.	6/17/2015	11:28	18.8	0.508	7.66	80	68.1
N/A	Rite-Aid 3521 Corunna Rd.	6/17/2015	11:35	19.3	0.536	7.79	92	74.5
N/A	Clio Rd. Pharmacy 4902 Clio Rd.	6/22/2015	12:30	21.4	0.498	7.69	84	66.5
N/A	Tim Hortons 1274 Ballanger Hwy.	6/17/2015	11:54	18.9	0.540	7.68	90	72.9
N/A	Arby's 3559 S. Dort Hwy.	6/15/2015	13:07	22.4	0.504	7.73	82	65.7
N/A	Ya Ya's 519 S. Dort Hwy	6/15/2015	13:17	20.4	0.506	7.70	82	68.9
N/A	Taco Bell 1740 S. Dort Hwy	6/15/2015	12:57	20.2	0.485	7.62	74	60.9
N/A	Grandma's Recipe 3538 Richfield Rd.	6/15/2015	10:27	19.3	0.496	7.61	76	64.1
N/A	Flint City Hall 1101 S. Saginaw St.	5/13/2015	10:00	18.5	0.484	7.69	68	64.9
N/A	Quizzno's 3818 E. Court St.	6/15/2015	12:45	23.6	0.495	7.73	76	64.9
N/A	Whitehorse Tavern 621 W. Court St.	6/17/2015	10:49	21.2	0.526	7.67	84	72.1
N/A	Flint Public Library 1026 E. Kearsley Rd.	6/23/2015	13:21	18.6	0.494	7.73	81	65.7
N/A	Rite-Aid 3717 Fenton Rd.	5/12/2015	9:10	17.6	0.506	7.67	80	68.9



Water Quality Monitoring
1st Quarter 2014

DEQ
RESOURCE MANAGEMENT DIVISION

MAR 30 2015

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS				
Distribution System Location #	Sample Point Name & Address	Sample Date	Time	Temperature (C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)
#1	Arby's 3742 Davison Rd.	3/4/2015	10:11	6.5	0.594	7.65	119	70.5
#2	BP Gas Station 822 S.Dort Hwy	3/4/2015	10:34	3.6	0.594	7.77	128	71.3
#3	Liquor Palace 3302 S. Dort Hwy	3/4/2015	10:51	8.7	0.604	7.83	130	70.5
#4	Taco Bell 3606 Corunna Rd.	3/4/2015	11:13	4.8	0.607	7.87	128	72.1
#5	University Market 2501 Flushing Rd.	3/4/2015	11:28	3.5	0.618	7.85	124	75.4
#6	Salem Housing 3216 MLK Blvd.	3/4/2015	12:31	10.3	0.573	7.95	116	65.7
#7	Rite-Aid 5018 Clio Rd.	3/4/2015	12:46	8.1	0.602	7.93	128	77.0
#8	N. Flint Automotive 6204 N. Saginaw St.	3/4/2015	13:05	12.8	0.584	7.84	132	73.7
CS	Cedar Street Reservoir & Pump Station	3/17/2015	10:45	7.8	0.570	7.86	114	73.7
WS	West Side Reservoir & Pump Station	3/4/2015	11:49	1.9	0.609	7.86	120	77.8
N/A	Russell Collection Agency 3285 Van Slyke Rd	3/6/2015	9:49	6.4	0.540	7.69	110	81.0
N/A	Southwestern Academy High School 1420 W. 12th St.	3/11/2015	11:08	19.7	0.630	7.99	128	80.2
N/A	Cummings Elementary School G-2200 Walton St.	3/11/2015	11:23	7.1	0.569	7.81	128	83.4
N/A	Rite-Aid 3521 Corunna Rd.	3/10/2015	11:10	8.4	0.596	7.88	130	78.6
N/A	Clio Rd. Pharmacy 4902 Clio Rd.	3/5/2015	11:55	7.7	0.611	7.80	128	85.6
N/A	Tim Hortons 1274 Ballanger Hwy.	3/5/2015	11:06	5.3	0.620	7.76	124	82.6
N/A	Arby's 3559 S. Dort Hwy.	3/5/2015	10:36	11.0	0.629	7.80	130	83.4
N/A	Ya Ya's 519 S. Dort Hwy	3/13/2015	10:31	14.8	0.603	7.77	134	84.2
N/A	Taco Bell 1740 S. Dort Hwy	3/13/2015	10:41	4.7	0.586	7.77	134	84.2
N/A	Grandma's Recipe 3538 Richfield Rd.	3/5/2015	9:45	6.5	0.580	7.73	130	84.2
N/A	Flint City Hall 1101 S. Saginaw St.	3/6/2015	10:33	14.1	0.630	7.71	136	83.4
N/A	Quizzno's 3818 E. Court St.	3/12/2015	11:03	7.9	0.572	7.93	122	87.4
N/A	Whitehorse Tavern 621 W. Court St.	3/6/2015	10:12	9.1	0.634	7.60	134	84.2
N/A	Flint Public Library 1026 E. Kearsley Rd.	3/6/2015	10:56	20.7	0.606	7.85	126	81.8
N/A	Rite-Aid 3717 Fenton Rd.	3/10/2015	10:53	9.6	0.623	7.84	126	75.4

(7.81 Avg)



Water Quality Monitoring
4th Quarter 2014

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS				
Distribution System Location #	Sample Point Name & Address	Sample Date	Time	Temperature (C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)
#1	Arby's 3742 Davison Rd.	11/25/2014	10:40	16.8	0.465	7.96	114	58.5
#2	BP Gas Station 822 S.Dort Hwy	11/25/2014	10:53	14.9	0.421	7.99	114	60.9
#3	Liquor Palace 3302 S. Dort Hwy	11/25/2014	11:08	11.6	0.461	7.98	118	59.3
#4	Taco Bell 3606 Corunna Rd.	11/25/2014	11:49	17.4	0.479	7.99	118	60.1
#5	University Market 2501 Flushing Rd.	11/25/2014	12:08	15.6	0.442	7.90	116	63.3
#6	Salem Housing 3216 MLK Blvd.	11/25/2014	12:34	15.0	0.437	7.85	104	58.5
#7	Rite-Aid 5018 Clio Rd.	11/25/2014	13:00	16.1	0.448	7.99	118	62.5
#8	N. Flint Automotive 6204 N. Saginaw St.	11/25/2014	13:14	16.1	0.488	8.00	114	59.3
CS	Cedar Street Reservoir & Pump Station	11/25/2014	11:25	11.1	0.442	7.99	108	60.9
WS	West Side Reservoir & Pump Station	11/25/2014	12:18	9.1	0.449	7.96	114	59.3
N/A	Russell Collection Agency 3285 Van Slyke Rd	12/2/2014	11:35	12.2	0.372	7.67	100	64.1
N/A	Southwestern Academy High School 1420 W.12th St.	12/2/2014	11:23	12.7	0.352	7.71	100	65.7
N/A	Cummings Elementary School G-2200 Walton St.	12/2/2014	11:51	11.2	0.382	7.65	108	64.1
N/A	Rite-Aid 3521 Corunna Rd.	11/28/2014	12:37	13.2	0.405	8.03	106	55.3
N/A	Clio Rd. Pharmacy 4902 Clio Rd.	12/2/2014	13:00	13.4	0.356	7.62	100	65.7
N/A	Tim Hortons 1274 Ballanger Hwy.	11/28/2014	12:58	11.7	0.404	7.95	106	50.5
N/A	Arby's 3559 S. Dort Hwy.	11/26/2014	11:07	15.5	0.443	7.87	108	68.1
N/A	Ya Ya's 519 S. Dort Hwy	11/26/2014	10:33	12.2	0.424	7.95	106	66.5
N/A	Taco Bell 1740 S. Dort Hwy	11/26/2014	10:50	9.5	0.414	7.86	108	64.1
N/A	Grandma's Recipe 3538 Richfield Rd.	11/26/2014	9:55	15.3	0.426	7.68	114	65.7
N/A	Flint City Hall 1101 S. Saginaw St.	12/3/2014	10:00	15.7	0.404	7.84	98	61.7
N/A	Quizzno's 3818 E. Court St.	11/26/2014	10:19	11.5	0.421	7.88	122	68.1
N/A	Whitehorse Tavern 621 W. Court St.	11/28/2014	12:00	12.0	0.405	8.10	104	56.9
N/A	Flint Public Library 1026 E. Kearsley Rd.	12/3/2014	11:00	18.4	0.449	7.76	100	59.3
N/A	Rite-Aid 3717 Fenton Rd.	11/28/2014	11:48	10.5	0.407	7.88	102	56.1

7:55 AM



Water Quality Monitoring

3rd Quarter 2014

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS				
Distribution System Location #	Sample Point Name & Address	Sample Date	Time	Temperature (C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)
#1	Arby's 3742 Davison Rd.	8/6/2014	10:36	23.0	0.388	7.74	60	49.7
#2	BP Gas Station 822 S.Dort Hwy	8/6/2014	10:49	23.9	0.372	7.76	70	52.1
#3	Liquor Palace 3302 S. Dort Hwy	8/6/2014	11:00	23.8	0.369	7.65	72	51.3
#4	Taco Bell 3606 Corunna Rd.	8/6/2014	11:34	26.8	0.359	7.69	74	53.7
#5	University Market 2501 Flushing Rd.	8/6/2014	11:47	26.5	0.383	7.56	80	56.9
#6	Salem Housing 3216 MLK Blvd.	8/6/2014	12:09	27.3	0.350	7.73	70	49.7
#7	Rite-Aid 5018 Clio Rd.	8/8/2014	10:22	20.9	0.387	7.74	78	50.5
#8	N. Flint Automotive 6204 N. Saginaw St.	8/6/2014	12:38	25.5	0.363	7.83	72	52.9
CS	Cedar Street Reservoir & Pump Station	8/6/2014	11:16	25.5	0.395	7.69	78	54.5
WS	West Side Reservoir & Pump Station	8/6/2014	11:57	26.5	0.406	7.56	82	52.1
N/A	Russell Collection Agency 3285 Van Slyke Rd	8/8/2014	11:12	25.6	0.370	7.78	74	55.3
N/A	Southwestern Academy High School 1420 W.12th St.	8/8/2014	11:42	26.7	0.403	7.82	86	59.3
N/A	Cummings Elementary School G-2200 Walton St.	8/8/2014	11:00	25.8	0.359	7.62	76	53.7
N/A	Rite-Aid 3521 Corunna Rd.	8/8/2014	10:47	23.0	0.390	7.86	86	56.1
N/A	Kroger 2629 W. Pierson Rd.	8/6/2014	12:24	27.3	0.370	7.76	88	58.5
N/A	Tim Hortons 1274 Ballanger Hwy.	8/8/2014	10:35	21.9	0.411	7.73	86	56.1
N/A	Arby's 3559 S. Dort Hwy.	8/5/2014	11:19	23.1	0.401	7.63	88	61.7
N/A	Ya Ya's 519 S. Dort Hwy	8/5/2014	10:57	23.7	0.392	7.60	90	60.1
N/A	Taco Bell 1740 S. Dort Hwy	8/5/2014	11:09	23.2	0.412	7.60	90	60.9
N/A	Grandma's Recipe 3538 Richfield Rd.	8/5/2014	10:28	23.1	0.406	7.69	88	61.7
N/A	Flint City Hall 1101 S. Saginaw St.	8/5/2014	11:35	23.0	0.396	7.75	88	56.9
N/A	Quizzno's 3818 E. Court St.	8/5/2014	10:48	23.3	0.415	7.67	86	60.1
N/A	Whitehorse Tavern 621 W. Court St.	8/8/2014	11:53	26.1	0.390	7.81	78	57.7
N/A	Flint Public Library 1026 E. Kearsley Rd.	8/8/2014	11:45	22.2	0.446	7.82	82	64.1
N/A	Rite-Aid 3717 Fenton Rd.	8/8/2014	11:30	22.0	0.394	7.78	88	58.5

(7.71 Avg)



2014 2nd Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	4/9/2014	8.9	7.59	76	1.03
#2	BP Gas Station 822 S.Dort Hwy	4/9/2014	7.5	7.57	77	1.12
#3	Liquor Palace 3302 S. Dort Hwy	4/9/2014	13.9	7.44	76	1.13
#4	Taco Bell 3606 Corunna Rd.	4/9/2014	8.3	7.44	76	1.09
#5	University Market 2501 Flushing Rd.	4/9/2014	8.7	7.42	76	1.07
#6	Salem Housing 3216 MLK Blvd.	4/9/2014	15.7	7.48	77	1.06
#7	Rite-Aid 5018 Clio Rd.	4/9/2014	8.8	7.50	77	1.07
#8	N. Flint Automotive 6204 N. Saginaw St.	4/9/2014	15.6	7.46	76	1.09
CS	Cedar Street Reservoir & Pump Station	4/9/2014	5.9	7.50	76	1.08
WS	West Side Reservoir & Pump Station	4/9/2014	6.7	7.47	76	1.10



2014 1st Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	1/29/2014	8.4	7.48	72	1.12
#2	BP Gas Station 822 S.Dort Hwy	1/29/2014	7.4	7.46	71	1.17
#3	Liquor Palace 3302 S. Dort Hwy	1/29/2014	10.0	7.40	73	1.04
#4	Taco Bell 3606 Corunna Rd.	1/29/2014	7.9	7.44	72	1.17
#5	University Market 2501 Flushing Rd.	1/29/2014	6.4	7.47	74	1.16
#6	Salem Housing 3216 MLK Blvd.	1/29/2014	9.2	7.44	72	1.12
#7	Rite-Aid 5018 Clio Rd.	1/29/2014	7.9	7.54	73	1.05
#8	N. Flint Automotive 6204 N. Saginaw St.	1/29/2014	10.7	7.44	73	1.10
CS	Cedar Street Reservoir & Pump Station	1/29/2014	8.3	7.53	73	1.09
WS	West Side Reservoir & Pump Station	1/29/2014	7.1	7.48	72	1.12

DEQ
RESOURCE MANAGEMENT DIVISION

FEB 25 2014

LANSING DISTRICT



2013 4th Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	11/13/2013	17.3	7.49	76	1.00
#2	BP Gas Station 822 S.Dort Hwy	11/13/2013	15.0	7.52	74	1.15
#3	7-11 3302 S. Dort Hwy	11/13/2013	14.9	7.45	74	1.02
#4	Taco Bell 3606 Corunna Rd.	11/13/2013	14.6	7.47	73	1.06
#5	7-11 2501 Flushing Rd.	11/13/2013	15.3	7.48	74	1.03
#6	Salem Housing 3216 MLK Blvd.	11/13/2013	16.9	7.45	74	1.02
#7	Rite-Aid 5018 Clio Rd.	11/13/2013	16.6	7.53	77	1.10
#8	N. Flint Automotive 6204 N. Saginaw St.	11/13/2013	18.8	7.49	75	1.04
CS	Cedar Street Reservoir & Pump Station	11/13/2013	17.8	7.53	76	1.10
WS	West Side Reservoir & Pump Station	11/13/2013	16.1	7.50	75	1.21

DEQ
RESOURCE MANAGEMENT DIVISION

NOV 25 2013

LANSING DISTRICT



2013 3rd Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	9/4/2013	22.6	7.76	74	1.15
#2	BP Gas Station 822 S.Dort Hwy	9/4/2013	23.6	7.58	75	1.16
#3	7-11 3302 S. Dort Hwy	9/4/2013	21.3	7.58	74	1.18
#4	Taco Bell 3606 Corunna Rd.	9/4/2013	21.8	7.52	75	1.23
#5	7-11 2501 Flushing Rd.	9/4/2013	24.4	7.53	75	1.08
#6	Salem Housing 3216 MLK Blvd.	9/4/2013	22.7	7.57	75	1.06
#7	Rite-Aid 5018 Clio Rd.	9/4/2013	22.2	7.75	76	1.10
#8	N. Flint Automotive 6204 N. Saginaw St.	9/4/2013	23.1	7.54	76	1.14
CS	Cedar Street Reservoir & Pump Station	9/4/2013	20.9	7.57	74	1.12
WS	West Side Reservoir & Pump Station	9/4/2013	21.4	7.52	75	1.15



2013 2nd Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	5/1/2013	16.7	7.62	73	0.87
#2	BP Gas Station 822 S.Dort Hwy	5/1/2013	14.6	7.45	74	1.01
#3	7-11 3302 S. Dort Hwy	5/1/2013	14.1	7.38	74	1.02
#4	Taco Bell 3606 Corunna Rd.	5/1/2013	10.8	7.38	73	0.90
#5	7-11 2501 Flushing Rd.	5/1/2013	12.1	7.40	74	0.93
#6	Salem Housing 3216 MLK Blvd.	5/1/2013	12.7	7.40	73	0.85
#7	Rite-Aid 5018 Clio Rd.	5/1/2013	12.5	7.50	74	0.94
#8	N. Flint Automotive 6204 N. Saginaw St.	5/1/2013	16.3	7.41	73	0.81
CS	Cedar Street Reservoir & Pump Station	5/1/2013	10.5	7.47	75	0.86
WS	West Side Reservoir & Pump Station	5/1/2013	10.4	7.36	74	0.85

DEQ
RESOURCE MANAGEMENT DIVISION

JUN 07 2013

LANSING DISTRICT



DEQ
RESOURCE MANAGEMENT DIVISION

MAR 11 2013

LANSING DISTRICT

2013 1st Quarter Water Quality Monitoring Results						
SAMPLE POINT IDENTIFICATION			PARAMETERS AND RESULTS			
Distribution System Location #	Sample Point Name & Address	Sample Date	Temperature (C)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Total Phosphorous (mg/L)
#1	Arby's 3742 Davison Rd.	2/27/2013	11.1	7.43	76	1.05
#2	BP Gas Station 822 S.Dort Hwy	2/27/2013	8.1	7.35	75	1.15
#3	7-11 3302 S. Dort Hwy	2/27/2013	11.1	7.31	73	1.21
#4	Taco Bell 3606 Corunna Rd.	2/27/2013	7.0	7.33	74	1.28
#5	7-11 2501 Flushing Rd.	2/27/2013	6.4	7.33	73	1.09
#6	Salem Housing 3216 MLK Blvd.	2/27/2013	10.3	7.38	74	0.96
#7	Rite-Aid 5018 Clio Rd.	2/27/2013	10.1	7.45	74	1.05
#8	N. Flint Automotive 6204 N. Saginaw St.	2/27/2013	14.3	7.33	75	1.10
CS	Cedar Street Reservoir & Pump Station	2/27/2013	8.4	7.42	73	1.03
WS	West Side Reservoir & Pump Station	2/27/2013	8.1	7.35	72	1.19