Attachment 2

CHECKLISTS FOR COMPLIANCE WITH CONTINUOUS EMISSION MONITORS (CEMS) AND CONTINUOUS OPACITY MONITORS (COMS)

This checklist is provided as a courtesy for businesses by the Michigan Department of Environmental Quality (MDEQ), Air Quality Division, and is not required to be returned or submitted to the MDEQ.

MINIMUM MONITORING PLAN REQUIREMENTS		Included ?		Need to Gather More Information ?	
	Yes	No	Yes	No	
General description of the process(es) and pollution control equipment					
• Explain and show that the location of the monitor(s) will be representative of emissions and also be accessible. Provide a diagram showing the sample acquisition point(s) or path(s) in relation to:					
 Flow disturbances (fans, elbows, inlets, outlets, etc.) 					
Pollution control equipment					
 Emission point of monitored gases to the atmosphere 					
 Flue walls at the sample acquisition location 					
If necessary, include any test data and explanations as to the basis for the choice of the location. Explain any deviation from location criteria in Performance Specification 1, Section 4 and/or Performance Specification 2, Section 3 of Appendix B in 40 CFR Part 60.					
The following system information must be included:					
 Types of pollutant(s) and or parameter(s) to be monitored 					
 Operating principles of the analyzers 					
 Number of analyzers, including the number of sample acquisition point(s) or path(s) per analyzer and locations monitored by each 					
Equipment manufacturer and model number(s)					
Type of probe (i.e., Will the system be able to accept an external audit?)					
 Equipment specifications of monitors which will be verified by the applicable Performance Specification of Appendix B in 40 CFR 60 					
 Formulas, including any factors used to calculate emissions in the units of the applicable standard 					
 Span values of all pollutant monitors 					
Instrument ranges of all pollutant monitors					
 Proposed daily calibration gas, calibration error, linearity, and/or cylinder gas audit values 					
Data acquisition system/data recorder resolution					
Expected date of monitor installation and performance specification testing		_			

	NIMUM PERFORMANCE SPECIFICATION TESTING REPORT QUIREMENTS	Included ?		Need to Gather More Information	
141	QUILLIII.	Yes	No	Yes	No
•	CEMS description which should include the following:				
	Manufacturer, model and serial number of each monitor				
	 Sample acquisition system (i.e., extractive, point in-situ, etc.) and analytical principle 				
	Span values and instrument ranges of each monitor				
	If monitors are shared, indicate time strategies				
•	Reference Method (RM) testing description must include:				
	 Dimensioned sketch showing location of sampling points in relation to breeching and upstream and downstream disturbances or obstructions of gas flow 				
	 Sketch of cross-sectional view indicating traverse point locations and exact stack or duct dimensions 				
	 Sampling and analysis procedures 				
•	Seven Day Calibration Drift (CD) Test				
	 All CEMS responses from the source's CEMS Data Acquisition System (DA) are to be submitted. Delineate all final responses. 				
	 Seven Day CD Test data is to be summarized for all measured pollutants usin Figure 2-1 of the Performance Specification 2, Appendix B, 40 CFR 60. Spa values are to be specified. 				
	 All cylinder concentration certifications are to be submitted. 				
•	Relative Accuracy Test Audit (RATA)				
	 Submit all CEMS responses from the source's CEMS DAS documenting the nine 21-minute runs (delineate runs from start to end). 				
	 Submit all supporting reference method (RM) data. Include all data logger printouts and/or chart recording with each of the nine 21-minute runs clearly delineated from start to end. Include all bias, zero calibration drift (CD), and interference data for the velocity profile measurements and moisture determinations. 				
	 Submit all cylinder gas concentration certifications used for the calibrations of the RM testing. 				
	 RA data is to be summarized for all measured pollutants using Figure 2-2 of Performance Specification 2, Appendix B, 40 CFR 60 imits consistent with the applicable standard. 				
•	Calculations				
	 Submit example calculations of CEMS and RM test results in the units of the applicable standard. Include F-factor if applicable. 				
•	Source Operation Data				
	 Submit process data verifying the source was operating greater than 50% of normal load or as specified in an applicable subpart. 				

MINIMUM EXCESS EMISSION(S) REPORTING REQUIREMENTS *	Included ?		Need to G luded? More Inform	
	Yes	No	Yes	No
Total operating time of each source during the reporting period				
• Documentation of excess emission(s)				
 Date of each excess emission of the applicable standard 				
 Start and end time of each excess emission of the applicable standard 				
 Magnitude of each excess emission above the applicable limit [Excess opacity emission(s) (COMS) are reported in 6-minute block averages. For continuous emission monitors (CEMS), other than opacity, monitored excess emission(s) are reported in the units of the standard.] 				
 Nature or cause of each excess emission of the applicable standard 				
 Corrective action or preventive measures of each excess emission above the applicable standard. 				
• Any mathematical factors used to convert emission(s) to units of the applicable standard				
Document monitoring system performance:				
 List date when monitoring system was inoperative (daily zero and span check are exempt) 				
Start and end time when the monitoring system was inoperative				
 Nature of system repairs or adjustments 				
Document any time the monitor exceeded the instrument range. Include date, time, duration, nature or cause, and corrective action.				
Document any time the monitor exceeded the instrument range. Include date, time, duration, nature or cause, and corrective action.				
Report when no excess emission(s) or monitor system outage occurred.				
Summarize excess emission(s)				

^{*} Note: Owner/Operators must maintain a log of all measurements, including all CEMS downtimes, repairs, adjustments, maintenance, calibrations, audits, and testing in a permanent form suitable for inspection.