



**EGLE Part 213 DAILY REPORT – October 12, 2021\***

**Incident Name: Flat Rock ER 08-31-2021**

**Ford Flat Rock Assembly Facility**

**Gasoline Release**

**1 International Drive, Flat Rock, Michigan**

To: Paul Owens (EGLE)

REF. No.: REL-0186-21

CC: Ford Motor Company (Ford)

DATE: October 12, 2021

**ACTIVITIES AT THE FORD FLAT ROCK ASSEMBLY PROPERTY**

**October 12, 2021**

- Ford contractors continued to maintain culvert plug in the 10” sanitary line
  - Ford contractors continued to remove sanitary water from the plugged sanitary line and stage the liquid in on-site temporary frac tank storage
- Ford continued backfilling the excavation and installing a vapor ventilation system in the excavation
- Ford contractors conducted unmanned aircraft photography of excavation area and dock area

**Tactics October 12, 2021 (19:00) to October 13, 2021 (19:00)**

- Ford contractors will continue to maintain the culvert plug in the 10” sanitary line on Ford property
  - Ford contractors will continue to remove sanitary water from the plugged sanitary line and stage the liquid in on-site temporary frac tank storage
  - Ford contractors will collect one sample of liquid from the 10” sanitary line for laboratory analysis
- Ford contractors will continue to monitor containment boom within stormwater pond as a proactive measure
- Ford contractors will collect a water sample(s) from stormwater pond

**\* The Unified Command is no longer requiring daily reports**