

RECEIVED

MAR 12 2015

DEQ • RD
JACKSON DISTRICT OFFICE

EXTRACTION DATA

- TABLE #1 - UNIT "D2" UPGRADIENT EXTRACTION DATA
- TABLE #2 - UNIT "D2" DOWNGRADIENT EXTRACTION DATA
- TABLE #3 - CORE AREA EXTRACTION DATA
- TABLE #4 - MARSHY AREA EXTRACTION DATA
- TABLE #5 - SOUTHWEST AREA EXTRACTION DATA
- TABLE #6 - UNIT "E" EXTRACTION DATA
- TABLE #7 - LITTLE LAKE AREA SYSTEM DATA
- TABLE #8 - INDIVIDUAL PURGE WELL CONCENTRATIONS
- TABLE #9 - RED POND DATA
- TABLE #10 - RED POND CONCENTRATIONS

OZONE OPERATION DATA

- TABLE #11 - OZONE OPERATION REPORT

DISCHARGE DATA

- TABLE #12 - GREEN POND / DISCHARGE DATA
- TABLE #13 - DAILY DISCHARGE MONITORING REPORT

UNIT D2 UPGRADIENT EXTRACTION DATA

Month of: Feb-15

Date	TW-21			Daily Flow	Daily Total
	Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-2/1/15	94,942	66	24.00	66	94,942
Mon-2/2/15	94,846	66	24.00	66	94,846
Tue-2/3/15	94,862	66	24.00	66	94,862
Wed-2/4/15	94,944	66	24.00	66	94,944
Thu-2/5/15	94,896	66	24.00	66	94,896
Fri-2/6/15	94,941	66	24.00	66	94,941
Sat-2/7/15	94,979	66	24.00	66	94,979
Sun-2/8/15	94,997	66	24.00	66	94,997
Mon-2/9/15	94,921	66	24.00	66	94,921
Tue-2/10/15	94,875	66	24.00	66	94,875
Wed-2/11/15	94,921	66	24.00	66	94,921
Thu-2/12/15	94,862	66	24.00	66	94,862
Fri-2/13/15	94,861	66	24.00	66	94,861
Sat-2/14/15	94,866	66	24.00	66	94,866
Sun-2/15/15	94,844	66	24.00	66	94,844
Mon-2/16/15	94,861	66	24.00	66	94,861
Tue-2/17/15	99,856	69	24.00	69	99,856
Wed-2/18/15	102,097	71	24.00	71	102,097
Thu-2/19/15	102,037	71	24.00	71	102,037
Fri-2/20/15	93,138	65	24.00	65	93,138
Sat-2/21/15	87,674	61	24.00	61	87,674
Sun-2/22/15	92,473	64	24.00	64	92,473
Mon-2/23/15	94,844	66	24.00	66	94,844
Tue-2/24/15	97,434	68	24.00	68	97,434
Wed-2/25/15	102,126	71	24.00	71	102,126
Thu-2/26/15	96,836	67	24.00	67	96,836
Fri-2/27/15	94,878	66	24.00	66	94,878
Sat-2/28/15	94,906	66	24.00	66	94,906
TOTALS	2,676,717	66	672.00	66	2,676,717

TOTAL VOLUME EXTRACTED :	2,676,717 GALLONS
DAYS IN MONTH :	28 DAYS
MONTHLY AVERAGE FLOW RATE :	66.39 GPM

UNIT D2 DOWNGRAIDENT EXTRACTION DATA

Month of: **Feb-15**

Date	LB-4			Daily	Daily
	Gallons	GPM	Run Hrs.	Flow GPM	Total Gallons
Sun-2/1/15	144,094	100	24.00	100	144,094
Mon-2/2/15	144,107	100	24.00	100	144,107
Tue-2/3/15	144,086	100	23.98	100	144,086
Wed-2/4/15	144,082	100	24.00	100	144,082
Thu-2/5/15	144,062	100	24.00	100	144,062
Fri-2/6/15	144,047	100	24.00	100	144,047
Sat-2/7/15	144,077	100	24.00	100	144,077
Sun-2/8/15	144,011	100	24.00	100	144,011
Mon-2/9/15	144,084	100	24.00	100	144,084
Tue-2/10/15	144,070	100	23.98	100	144,070
Wed-2/11/15	144,128	100	24.00	100	144,128
Thu-2/12/15	143,266	99	24.00	99	143,266
Fri-2/13/15	144,133	100	24.00	100	144,133
Sat-2/14/15	144,067	100	24.00	100	144,067
Sun-2/15/15	144,212	100	24.00	100	144,212
Mon-2/16/15	144,429	100	24.00	100	144,429
Tue-2/17/15	144,293	100	23.98	100	144,293
Wed-2/18/15	144,152	100	24.00	100	144,152
Thu-2/19/15	144,002	100	24.00	100	144,002
Fri-2/20/15	144,164	100	24.00	100	144,164
Sat-2/21/15	144,363	100	24.00	100	144,363
Sun-2/22/15	144,161	100	24.00	100	144,161
Mon-2/23/15	144,131	100	23.98	100	144,131
Tue-2/24/15	144,358	100	24.00	100	144,358
Wed-2/25/15	144,267	100	24.00	100	144,267
Thu-2/26/15	144,083	100	24.00	100	144,083
Fri-2/27/15	143,961	100	24.00	100	143,961
Sat-2/28/15	144,207	100	24.00	100	144,207
TOTALS	4,035,097	100	671.92	100	4,035,097

TOTAL VOLUME EXTRACTED :	4,035,097 GALLONS
DAYS IN MONTH :	28 DAYS
MONTHLY AVERAGE FLOW RATE :	100.08 GPM

CORE AREA EXTRACTION DATA

Month of: **Feb-15**

Core Area Well Extraction							Daily	Daily
Date	TW-2 (Dolph)			TW-20			Flow	Total
	Gallons	GPM	Run Hrs.	Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-2/1/15	16,190	11	24.00	39,579	27	24.00	39	55,769
Mon-2/2/15	16,168	11	24.00	39,543	27	24.00	39	55,711
Tue-2/3/15	16,214	11	24.00	39,674	28	24.00	39	55,888
Wed-2/4/15	16,306	11	24.00	40,340	28	24.00	39	56,646
Thu-2/5/15	16,313	11	24.00	40,128	28	24.00	39	56,441
Fri-2/6/15	16,350	11	24.00	40,072	28	24.00	39	56,422
Sat-2/7/15	16,372	11	24.00	39,972	28	24.00	39	56,344
Sun-2/8/15	16,377	11	24.00	40,115	28	24.00	39	56,492
Mon-2/9/15	16,259	11	24.00	40,085	28	24.00	39	56,344
Tue-2/10/15	16,320	11	24.00	39,994	28	24.00	39	56,314
Wed-2/11/15	16,352	11	24.00	40,024	28	24.00	39	56,376
Thu-2/12/15	16,357	11	24.00	39,825	28	24.00	39	56,182
Fri-2/13/15	16,406	11	24.00	39,777	28	24.00	39	56,183
Sat-2/14/15	16,470	11	24.00	39,745	28	24.00	39	56,215
Sun-2/15/15	16,388	11	24.00	39,321	27	24.00	39	55,709
Mon-2/16/15	16,467	11	24.00	39,494	27	24.00	39	55,961
Tue-2/17/15	16,520	11	24.00	39,547	27	24.00	39	56,067
Wed-2/18/15	16,561	12	24.00	39,497	27	24.00	39	56,058
Thu-2/19/15	16,528	11	24.00	39,249	27	24.00	39	55,777
Fri-2/20/15	16,543	11	24.00	39,147	27	24.00	39	55,690
Sat-2/21/15	16,631	12	24.00	39,155	27	24.00	39	55,786
Sun-2/22/15	16,617	12	24.00	38,955	27	24.00	39	55,572
Mon-2/23/15	16,631	12	24.00	38,697	27	24.00	38	55,328
Tue-2/24/15	16,683	12	24.00	38,844	27	24.00	39	55,527
Wed-2/25/15	16,689	12	24.00	38,814	27	24.00	39	55,503
Thu-2/26/15	16,707	12	24.00	38,634	27	24.00	38	55,341
Fri-2/27/15	16,733	12	24.00	38,229	27	24.00	38	54,962
Sat-2/28/15	16,751	12	24.00	38,111	26	24.00	38	54,862
TOTALS	460,903	11	672.00	1,104,567	27	672.00	39	1,565,470

TOTAL VOLUME EXTRACTED :	1,565,470 GALLONS
DAYS IN MONTH :	28 DAYS
MONTHLY AVERAGE FLOW RATE :	38.83 GPM

MARSHY AREA EXTRACTION DATA

Month of: Feb-15

Marshy Well Extraction				Daily Flow	Daily Total
Date	PW-1 Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-2/1/15	2,362	2	24.00	2	2,362
Mon-2/2/15	2,358	2	24.00	2	2,358
Tue-2/3/15	2,356	2	24.00	2	2,356
Wed-2/4/15	2,353	2	24.00	2	2,353
Thu-2/5/15	2,339	2	24.00	2	2,339
Fri-2/6/15	2,338	2	24.00	2	2,338
Sat-2/7/15	2,264	2	23.68	2	2,264
Sun-2/8/15	2,377	2	24.00	2	2,377
Mon-2/9/15	2,371	2	24.00	2	2,371
Tue-2/10/15	2,372	2	24.00	2	2,372
Wed-2/11/15	2,364	2	24.00	2	2,364
Thu-2/12/15	2,382	2	24.00	2	2,382
Fri-2/13/15	2,357	2	24.00	2	2,357
Sat-2/14/15	2,375	2	24.00	2	2,375
Sun-2/15/15	2,378	2	24.00	2	2,378
Mon-2/16/15	2,359	2	24.00	2	2,359
Tue-2/17/15	2,351	2	24.00	2	2,351
Wed-2/18/15	2,366	2	24.00	2	2,366
Thu-2/19/15	2,355	2	24.00	2	2,355
Fri-2/20/15	2,359	2	24.00	2	2,359
Sat-2/21/15	2,355	2	24.00	2	2,355
Sun-2/22/15	2,358	2	24.00	2	2,358
Mon-2/23/15	2,352	2	24.00	2	2,352
Tue-2/24/15	2,345	2	24.00	2	2,345
Wed-2/25/15	2,354	2	24.00	2	2,354
Thu-2/26/15	2,354	2	24.00	2	2,354
Fri-2/27/15	2,350	2	24.00	2	2,350
Sat-2/28/15	2,345	2	24.00	2	2,345
TOTALS	65,949	2	671.68	2	65,949

TOTAL VOLUME EXTRACTED :	65,949 GALLONS
DAYS IN MONTH :	28 DAYS
MONTHLY AVERAGE FLOW RATE :	1.64 GPM

SOUTHWEST AREA EXTRACTION DATA

Month of: Feb-15

South West Well Extraction				Daily	Daily
Date	ACTIVE WELLS			Flow	Total
	Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-2/1/15	12,845	9	24.00	9	12,845
Mon-2/2/15	12,773	9	24.00	9	12,773
Tue-2/3/15	12,701	9	24.00	9	12,701
Wed-2/4/15	12,682	9	24.00	9	12,682
Thu-2/5/15	12,545	9	24.00	9	12,545
Fri-2/6/15	12,528	9	24.00	9	12,528
Sat-2/7/15	12,516	9	24.00	9	12,516
Sun-2/8/15	12,497	9	24.00	9	12,497
Mon-2/9/15	12,534	9	24.00	9	12,534
Tue-2/10/15	12,546	9	24.00	9	12,546
Wed-2/11/15	12,555	9	24.00	9	12,555
Thu-2/12/15	12,472	9	24.00	9	12,472
Fri-2/13/15	12,421	9	24.00	9	12,421
Sat-2/14/15	12,405	9	24.00	9	12,405
Sun-2/15/15	12,242	9	24.00	9	12,242
Mon-2/16/15	12,246	9	24.00	9	12,246
Tue-2/17/15	12,254	9	24.00	9	12,254
Wed-2/18/15	12,231	8	24.00	8	12,231
Thu-2/19/15	12,138	8	24.00	8	12,138
Fri-2/20/15	12,005	8	24.00	8	12,005
Sat-2/21/15	11,943	8	24.00	8	11,943
Sun-2/22/15	11,863	8	24.00	8	11,863
Mon-2/23/15	11,747	8	24.00	8	11,747
Tue-2/24/15	11,748	8	24.00	8	11,748
Wed-2/25/15	11,721	8	24.00	8	11,721
Thu-2/26/15	11,678	8	24.00	8	11,678
Fri-2/27/15	11,566	8	24.00	8	11,566
Sat-2/28/15	11,519	8	24.00	8	11,519
TOTALS	342,921	9	672.00	9	342,921

TOTAL VOLUME EXTRACTED :	342,921 GALLONS
DAYS IN MONTH :	28 DAYS
MONTHLY AVERAGE FLOW RATE :	8.50 GPM

Note: ACTIVE WELLS = TW-8, TW-22

TABLE #6

UNIT "E" EXTRACTION DATA

Month of: Feb-15

Date	TW-16			TW-18			TW-19			Daily Flow GPM	Daily Total Gallons
	Gallons	GPM	Run Hrs.	Gallons	GPM	Run Hrs.	Gallons	GPM	Run Hrs.		
Sun-2/1/15	46,869	33	24.00	242,919	169	24.00	100,141	70	24.00	271	389,929
Mon-2/2/15	46,755	32	24.00	242,925	169	24.00	100,251	70	24.00	271	389,931
Tue-2/3/15	46,761	32	24.00	242,909	169	24.00	100,247	70	24.00	271	389,917
Wed-2/4/15	46,744	32	24.00	242,883	169	24.00	100,262	70	24.00	271	389,889
Thu-2/5/15	46,773	32	24.00	242,944	169	24.00	100,232	70	24.00	271	389,949
Fri-2/6/15	46,781	32	24.00	242,913	169	24.00	100,225	70	24.00	271	389,919
Sat-2/7/15	46,752	32	24.00	242,888	169	24.00	100,252	70	24.00	271	389,892
Sun-2/8/15	46,703	32	24.00	242,884	169	24.00	100,295	70	24.00	271	389,882
Mon-2/9/15	46,739	32	24.00	242,929	169	24.00	100,265	70	24.00	271	389,933
Tue-2/10/15	15,610	32	8.10	242,921	169	24.00	131,391	91	24.00	271	389,922
Wed-2/11/15	-	-	-	242,919	169	24.00	146,998	102	24.00	271	389,917
Thu-2/12/15	-	-	-	242,953	169	24.00	147,002	102	24.00	271	389,955
Fri-2/13/15	-	-	-	242,970	169	24.00	147,006	102	24.00	271	389,976
Sat-2/14/15	-	-	-	242,937	169	24.00	147,007	102	24.00	271	389,944
Sun-2/15/15	-	-	-	243,036	169	24.00	147,007	102	24.00	271	390,043
Mon-2/16/15	-	-	-	243,021	169	24.00	147,008	102	24.00	271	390,029
Tue-2/17/15	20,679	33	10.52	247,702	172	24.00	126,324	88	24.00	274	394,705
Wed-2/18/15	46,913	33	24.00	250,260	174	24.00	100,092	70	24.00	276	397,265
Thu-2/19/15	46,933	33	24.00	250,329	174	24.00	100,083	70	24.00	276	397,345
Fri-2/20/15	46,963	33	24.00	241,873	168	24.00	100,051	69	24.00	270	388,887
Sat-2/21/15	46,900	33	24.00	235,565	164	24.00	100,110	70	24.00	266	382,575
Sun-2/22/15	46,904	33	24.00	240,156	167	24.00	100,106	70	24.00	269	387,166
Mon-2/23/15	46,978	33	24.00	242,996	169	24.00	100,039	69	24.00	271	390,013
Tue-2/24/15	46,919	33	24.00	245,328	170	24.00	100,095	70	24.00	272	392,342
Wed-2/25/15	46,826	33	24.00	250,208	174	24.00	100,183	70	24.00	276	397,217
Thu-2/26/15	46,878	33	24.00	250,254	174	24.00	100,135	70	24.00	276	397,267
Fri-2/27/15	46,924	33	24.00	250,290	174	24.00	100,083	70	24.00	276	397,297
Sat-2/28/15	46,979	33	24.00	250,250	174	24.00	100,031	69	24.00	276	397,260
TOTALS	973,283	33	498.62	6,842,162	170	672.00	3,142,921	78	672.00	272	10,958,366

TOTAL VOLUME EXTRACTED :	10,958,366 GALLONS
DAYS IN MONTH :	28 DAYS
MONTHLY AVERAGE FLOW RATE :	271.78 GPM

02/10-15 - 02/17/15 - TW-16 was shut down for maintenance.

TABLE #7

Little Lake Area System

MW-53i	
Date	1,4-Dioxane ug/L
11/04/14	90
12/02/14	140
01/12/15	120
02/06/15	52

A2 Cleaning Supply Well	
Date	1,4-Dioxane ug/L
09/02/14	56
12/15/14	53
01/15/15	47
02/04/15	70

TABLE #8

INDIVIDUAL PURGE WELL CONCENTRATIONS

SAMPLE ID	Date Sampled	1,4-DIOXANE (ppb)
DOLPH-02-04-15-08:20-1	02/04/15	84
TW-20-02-04-15-10:26-1	02/04/15	990
LB-4-02-04-15-10:09-1	02/04/15	490
TW-21-02-04-15-10:18-1	02/04/15	120
TW-16-02-04-15-09:20-1	02/04/15	930
TW-18-02-04-15-08:17-1	02/04/15	280
TW-19-02-04-15-09:21-1	02/04/15	680
PW-1-02-04-15-08:15-1	02/04/15	630
TW-22-02-04-15-10:52-1	02/04/15	540
TW-8-02-04-15-10:57-1	02/04/15	670

RED POND DATA

Month of: Feb-15

Date	Time	Notes	Red Pond				
			Pond	Level	Aeration	Influent	Influent
			Visual Chk	Feet	Hours	Hours	GPM
Sun-2/1/15	3:05	(1)		4.9	-	24.00	486
Mon-2/2/15	3:00		Y	5.0	-	24.00	486
Tue-2/3/15	3:00		Y	4.9	-	24.00	486
Wed-2/4/15	3:00		Y	4.9	-	24.00	487
Thu-2/5/15	3:00		Y	4.9	-	24.00	486
Fri-2/6/15	3:00		Y	4.8	-	24.00	486
Sat-2/7/15	3:00	(1)		4.8	-	24.00	486
Sun-2/8/15	3:00	(1)		4.7	-	24.00	486
Mon-2/9/15	3:00		Y	4.7	-	24.00	486
Tue-2/10/15	3:00		Y	4.6	-	24.00	486
Wed-2/11/15	3:00		Y	4.6	-	24.00	486
Thu-2/12/15	3:00		Y	4.5	-	24.00	485
Fri-2/13/15	3:00		Y	4.5	-	24.00	486
Sat-2/14/15	3:00	(1)		4.4	-	24.00	486
Sun-2/15/15	3:00	(1)		4.3	-	24.00	486
Mon-2/16/15	3:00		Y	4.3	-	24.00	486
Tue-2/17/15	3:00		Y	4.2	-	24.00	493
Wed-2/18/15	3:00		Y	4.4	-	24.00	496
Thu-2/19/15	3:00		Y	4.5	-	24.00	496
Fri-2/20/15	3:00		Y	4.6	-	24.00	484
Sat-2/21/15	3:00	(1)		5.1	-	24.00	475
Sun-2/22/15	3:00	(1)		4.9	-	24.00	482
Mon-2/23/15	3:00		Y	4.8	-	24.00	485
Tue-2/24/15	3:00		Y	4.8	-	24.00	489
Wed-2/25/15	3:00		Y	4.8	-	24.00	495
Thu-2/26/15	3:00		Y	4.9	-	24.00	491
Fri-2/27/15	3:00		Y	4.9	-	24.00	490
Sat-2/28/15	3:00	(1)		4.9	-	24.00	490
TOTALS			-	-	-	672	

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

TABLE #10

RED POND CONCENTRATIONS

Concentrations of 1,4-Dioxane found in the Red Pond

SAMPLE ID	Date Sampled	1,4-DIOXANE (ppb)
Red Pond-02-02-15-09:25-1	2/2/2015	410
Red Pond-02-09-15-07:50-1	2/9/2015	420
Red Pond-02-17-15-08:25-1	2/17/2015	410
Red Pond-02-23-15-08:09-1	2/23/2015	440

Analyte value quantified from a dilution, reporting limit is raised to 10 ppb to reflect dilution

OZONE OPERATION REPORT

Month of: Feb-15

Date	Time	Notes	SYSTEM-1A		SYSTEM-1B		SYSTEM-2A		SYSTEM-2B	
			Flow GPM	Run Hours	Flow GPM	Run Hours	Flow GPM	Run Hours	Flow GPM	Run Hours
Sun-2/1/15	3:07 AM	(1)	240	24.00	0	0.00	239	24.00	0	0.00
Mon-2/2/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Tue-2/3/15	3:00 AM		240	23.88	0	0.00	240	23.90	0	0.00
Wed-2/4/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Thu-2/5/15	3:00 AM		239	24.00	0	0.00	241	24.00	0	0.00
Fri-2/6/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Sat-2/7/15	3:00 AM	(1)	240	24.00	0	0.00	240	24.00	0	0.00
Sun-2/8/15	3:00 AM	(1)	240	24.00	0	0.00	241	24.00	0	0.00
Mon-2/9/15	3:00 AM		239	24.00	0	0.00	241	24.00	0	0.00
Tue-2/10/15	3:00 AM		239	24.00	0	0.00	242	24.00	0	0.00
Wed-2/11/15	3:00 AM		239	24.00	0	0.00	241	24.00	0	0.00
Thu-2/12/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Fri-2/13/15	3:00 AM		240	24.00	0	0.00	238	24.00	0	0.00
Sat-2/14/15	3:00 AM	(1)	241	24.00	0	0.00	240	24.00	0	0.00
Sun-2/15/15	3:00 AM	(1)	240	24.00	0	0.00	241	24.00	0	0.00
Mon-2/16/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Tue-2/17/15	3:00 AM		240	23.83	0	0.00	237	23.82	0	0.00
Wed-2/18/15	3:00 AM		240	24.00	0	0.00	237	24.00	0	0.00
Thu-2/19/15	3:00 AM		240	24.00	0	0.00	244	24.00	0	0.00
Fri-2/20/15	3:00 AM		240	21.53	0	0.00	240	21.58	0	0.00
Sat-2/21/15	3:00 AM	(1)	240	24.00	0	0.00	241	24.00	0	0.00
Sun-2/22/15	3:00 AM	(1)	240	24.00	0	0.00	241	24.00	0	0.00
Mon-2/23/15	3:00 AM		240	24.00	0	0.00	239	24.00	0	0.00
Tue-2/24/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Wed-2/25/15	3:00 AM		239	24.00	0	0.00	241	24.00	0	0.00
Thu-2/26/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Fri-2/27/15	3:00 AM		239	24.00	0	0.00	239	24.00	0	0.00
Sat-2/28/15	3:00 AM	(1)	240	24.00	0	0.00	240	24.00	0	0.00

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

02/20/15 - Systems 1A and 2A were shut down briefly for maintenance.

TABLE #12

GREEN POND / DISCHARGE DATA

Month of: Feb-15

			Green Pond																	
Date	Time	Notes	Pond			Influent			Pond Discharge			Bypass Discharge			Recirc Thru UV to Pond			Recirc Thru UV to Disch		
			Visual Chk	Level Feet	Aeration Hours	Influent Hours	Influent GPM	Pond Discharge GPM	Pond Discharge Gallons	Pond Discharge Hours	Bypass Discharge GPM	Bypass Discharge Gallons	Bypass Discharge Hours	Recirc Thru UV to Pond GPM	Recirc Thru UV to Pond Gallons	Recirc Thru UV to Pond Hours	Recirc Thru UV to Disch GPM	Recirc Thru UV to Disch Gallons	Recirc Thru UV to Disch Hours	
Sun-2/1/15	3:05 AM	(1)		-	-							502	723,505	24.00	-	-	-	-	-	-
Mon-2/2/15	3:00 AM		Y	-	-							502	723,315	24.00	-	-	-	-	-	-
Tue-2/3/15	3:00 AM		Y	-	-							500	719,433	24.00	-	-	-	-	-	-
Wed-2/4/15	3:00 AM		Y	-	-							502	723,286	24.00	-	-	-	-	-	-
Thu-2/5/15	3:00 AM		Y	-	-							502	723,236	24.00	-	-	-	-	-	-
Fri-2/6/15	3:00 AM		Y	-	-							502	723,529	24.00	-	-	-	-	-	-
Sat-2/7/15	3:00 AM	(1)		-	-							503	724,025	24.00	-	-	-	-	-	-
Sun-2/8/15	3:00 AM	(1)		-	-							503	724,245	24.00	-	-	-	-	-	-
Mon-2/9/15	3:00 AM		Y	-	-							503	723,768	24.00	-	-	-	-	-	-
Tue-2/10/15	3:00 AM		Y	-	-							503	724,052	24.00	-	-	-	-	-	-
Wed-2/11/15	3:00 AM		Y	-	-							503	723,788	24.00	-	-	-	-	-	-
Thu-2/12/15	3:00 AM		Y	-	-							503	723,806	24.00	-	-	-	-	-	-
Fri-2/13/15	3:00 AM		Y	-	-							503	723,964	24.00	-	-	-	-	-	-
Sat-2/14/15	3:00 AM	(1)		-	-							503	724,095	24.00	-	-	-	-	-	-
Sun-2/15/15	3:00 AM	(1)		-	-							503	723,693	24.00	-	-	-	-	-	-
Mon-2/16/15	3:00 AM		Y	-	-							503	724,312	24.00	-	-	-	-	-	-
Tue-2/17/15	3:00 AM		Y	-	-							499	718,770	24.00	-	-	-	-	-	-
Wed-2/18/15	3:00 AM		Y	-	-							503	723,958	24.00	-	-	-	-	-	-
Thu-2/19/15	3:00 AM		Y	-	-							503	724,103	24.00	-	-	-	-	-	-
Fri-2/20/15	3:00 AM		Y	-	-							501	647,967	21.57	-	-	-	-	-	-
Sat-2/21/15	3:00 AM	(1)		-	-							501	721,327	24.00	-	-	-	-	-	-
Sun-2/22/15	3:00 AM	(1)		-	-							501	721,883	24.00	-	-	-	-	-	-
Mon-2/23/15	3:00 AM		Y	-	-							502	722,170	24.00	-	-	-	-	-	-
Tue-2/24/15	3:00 AM		Y	-	-							502	722,621	24.00	-	-	-	-	-	-
Wed-2/25/15	3:00 AM		Y	-	-							502	722,710	24.00	-	-	-	-	-	-
Thu-2/26/15	3:00 AM		Y	-	-							502	722,834	24.00	-	-	-	-	-	-
Fri-2/27/15	3:00 AM		Y	-	-							502	722,707	24.00	-	-	-	-	-	-
Sat-2/28/15	3:00 AM	(1)		-	-							502	723,012	24.00	-	-	-	-	-	-
TOTALS													20,170,114	670						

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

TABLE #13
Daily Discharge Monitoring Report

	(Daily)	(Influent - Red Pond)	(Effluent - Outfall)	(Effluent - Outfall)	(Weekly)	(2 x Week)	(4 x Week)	(5 X Week)	(2 X Week)
PARAMETER NAME	Flow	1,4-Dioxane	1,4-Dioxane	Hydrogen Peroxide (measured as TRO)	Outfall Observation	Equipment Inspection	pH	Bromate	Sodium Bisulfite Dose Rate
PARAMETER CODE	50050	82388	82388	00139	84130	46478	00400	99814	99798
MONITORING PT.	001A	001A	001A	001A	001A	001A	001A	001A	001A
STAGE CODE	1	G	1	1	1	1	1	1	1
UNIT	MGD	mg/l	ug/l	ug/l	yes/no	yes/no	S.U.	ug/l	mg/l
2/1/2015	0.724		4					6	
2/2/2015	0.723	0.410	3	100	yes	yes	6.6	6	10
2/3/2015	0.719		3	50	no	no	6.7	6	
2/4/2015	0.723		4	50	no	no	6.7	6	
2/5/2015	0.723		4	50	no	yes	6.7	6	16
2/6/2015	0.724			0	no	no	6.7		
2/7/2015	0.724								
2/8/2015	0.724		4					0	
2/9/2015	0.724	0.420	4	50	yes	yes	6.7	0	20
2/10/2015	0.724		4	50	no	no	6.6	5	
2/11/2015	0.724		4	50	no	no	6.7	6	
2/12/2015	0.724		4	0	no	yes	6.7	6	12
2/13/2015	0.724			50	no	no	6.7		
2/14/2015	0.724								
2/15/2015	0.724		4					6	
2/16/2015	0.724		3					7	
2/17/2015	0.719	0.410	4	50	yes	yes	6.8	5	10
2/18/2015	0.724		4	50	no	no	6.7	6	
2/19/2015	0.724		4	50	no	no	6.7	5	8
2/20/2015	0.648			50	no	yes	6.7		
2/21/2015	0.721								
2/22/2015	0.722		4					5	
2/23/2015	0.722	0.440	4	50	yes	yes	6.7	6	8
2/24/2015	0.723		4	100	no	no	6.7	6	
2/25/2015	0.723		4	100	no	no	6.8	6	
2/26/2015	0.723		4	100	no	yes	6.8	5	10
2/27/2015	0.723			50	no	no	6.7		
2/28/2015	0.723								
Discharged (mg)	20.170								
Monthly Avg			4					5	

Bromate: A zero value equals ND (less than 5 ppb)
Hydrogen Peroxide - A zero value equals ND (less than 100 ppb)

**02/16/15 - Presidents' Day