



EXTRACTION DATA

- TABLE #1 - UNIT "D2" UPGRADIENT EXTRACTION DATA**
- TABLE #2 - UNIT "D2" DOWNGRADIENT EXTRACTION DATA**
- TABLE #3 - CORE AREA EXTRACTION DATA**
- TABLE #4 - MARSHY AREA EXTRACTION DATA**
- TABLE #5 - SOUTHWEST AREA EXTRACTION DATA**
- TABLE #6 - UNIT "E" EXTRACTION DATA**
- TABLE #7 - LITTLE LAKE AREA SYSTEM DATA**
- TABLE #8 - INDIVIDUAL PURGE WELL CONCENTRATIONS**
- TABLE #9 - RED POND DATA**
- TABLE #10 - RED POND CONCENTRATIONS**

OZONE OPERATION DATA

- TABLE #11 - OZONE OPERATION REPORT**

DISCHARGE DATA

- TABLE #12 - GREEN POND / DISCHARGE DATA**
- TABLE #13 - DAILY DISCHARGE MONITORING REPORT**

UNIT D2 UPGRADIENT EXTRACTION DATA

Month of: **Mar-15**

Date	TW-21			Daily Flow	Daily Total
	TW-21 Gallons	GPM	Run Hrs.	GPM	Gallons
	Sun-3/1/15	94,866	66	24.00	66
Mon-3/2/15	94,956	66	24.00	66	94,956
Tue-3/3/15	94,931	66	24.00	66	94,931
Wed-3/4/15	95,019	66	24.00	66	95,019
Thu-3/5/15	93,527	65	24.00	65	93,527
Fri-3/6/15	87,659	61	24.00	61	87,659
Sat-3/7/15	87,736	61	24.00	61	87,736
Sun-3/8/15	87,776	61	24.00	61	87,776
Mon-3/9/15	91,723	64	24.00	64	91,723
Tue-3/10/15	98,925	69	24.00	69	98,925
Wed-3/11/15	100,783	70	24.00	70	100,783
Thu-3/12/15	100,765	70	24.00	70	100,765
Fri-3/13/15	100,735	70	24.00	70	100,735
Sat-3/14/15	100,760	70	24.00	70	100,760
Sun-3/15/15	100,803	70	24.00	70	100,803
Mon-3/16/15	100,802	70	24.00	70	100,802
Tue-3/17/15	100,759	70	24.00	70	100,759
Wed-3/18/15	96,483	67	24.00	67	96,483
Thu-3/19/15	93,549	65	24.00	65	93,549
Fri-3/20/15	93,494	65	24.00	65	93,494
Sat-3/21/15	93,563	65	24.00	65	93,563
Sun-3/22/15	93,528	65	24.00	65	93,528
Mon-3/23/15	93,481	65	24.00	65	93,481
Tue-3/24/15	93,176	65	23.90	65	93,176
Wed-3/25/15	101,332	70	24.00	70	101,332
Thu-3/26/15	103,665	72	24.00	72	103,665
Fri-3/27/15	103,578	72	24.00	72	103,578
Sat-3/28/15	103,545	72	24.00	72	103,545
Sun-3/29/15	103,619	72	24.00	72	103,619
Mon-3/30/15	96,309	70	22.78	67	96,309
Tue-3/31/15	100,755	70	24.00	70	100,755
TOTALS	3,002,602	67	742.68	67	3,002,602

TOTAL VOLUME EXTRACTED :	3,002,602 GALLONS
DAYS IN MONTH :	31 DAYS
MONTHLY AVERAGE FLOW RATE :	67.26 GPM

3/30/15 - TW-21 was shut down briefly to upgrade pipeline to Pond.

UNIT D2 DOWNGRADIENT EXTRACTION DATA

Month of: Mar-15

Date	LB-4			Daily	Daily
	Gallons	GPM	Run Hrs.	Flow GPM	Total Gallons
Sun-3/1/15	144,400	100	24.00	100	144,400
Mon-3/2/15	144,029	100	23.98	100	144,029
Tue-3/3/15	144,041	100	24.00	100	144,041
Wed-3/4/15	144,072	100	24.00	100	144,072
Thu-3/5/15	144,056	100	24.00	100	144,056
Fri-3/6/15	144,071	100	24.00	100	144,071
Sat-3/7/15	144,046	100	24.00	100	144,046
Sun-3/8/15	144,126	100	24.00	100	144,126
Mon-3/9/15	144,106	100	23.98	100	144,106
Tue-3/10/15	144,116	100	24.00	100	144,116
Wed-3/11/15	144,059	100	24.00	100	144,059
Thu-3/12/15	144,160	100	24.00	100	144,160
Fri-3/13/15	144,080	100	24.00	100	144,080
Sat-3/14/15	144,092	100	24.00	100	144,092
Sun-3/15/15	144,135	100	24.00	100	144,135
Mon-3/16/15	144,077	100	23.98	100	144,077
Tue-3/17/15	144,070	100	24.00	100	144,070
Wed-3/18/15	144,073	100	24.00	100	144,073
Thu-3/19/15	144,092	100	24.00	100	144,092
Fri-3/20/15	144,102	100	24.00	100	144,102
Sat-3/21/15	144,077	100	24.00	100	144,077
Sun-3/22/15	144,076	100	23.98	100	144,076
Mon-3/23/15	144,055	100	24.00	100	144,055
Tue-3/24/15	143,336	100	24.00	100	143,336
Wed-3/25/15	144,134	100	24.00	100	144,134
Thu-3/26/15	144,370	100	24.00	100	144,370
Fri-3/27/15	144,272	100	24.00	100	144,272
Sat-3/28/15	144,197	100	24.00	100	144,197
Sun-3/29/15	144,284	100	23.98	100	144,284
Mon-3/30/15	137,580	100	22.90	96	137,580
Tue-3/31/15	144,226	100	24.00	100	144,226
TOTALS	4,460,610	100	742.80	100	4,460,610

TOTAL VOLUME EXTRACTED :	4,460,610 GALLONS
DAYS IN MONTH :	31 DAYS
MONTHLY AVERAGE FLOW RATE :	99.92 GPM

3/30/15 - LB-4 was shut down briefly to upgrade pipeline to Pond.

CORE AREA EXTRACTION DATA

Month of: Mar-15

Core Area Well Extraction							Daily	Daily
Date	TW-2 (Dolph)			TW-20			Flow	Total
	Gallons	GPM	Run Hrs.	Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-3/1/15	16,816	12	24.00	38,334	27	24.00	38	55,150
Mon-3/2/15	16,798	12	24.00	38,205	27	24.00	38	55,003
Tue-3/3/15	16,827	12	24.00	38,247	27	24.00	38	55,074
Wed-3/4/15	16,848	12	24.00	38,255	27	24.00	38	55,103
Thu-3/5/15	16,832	12	24.00	37,686	26	24.00	38	54,518
Fri-3/6/15	16,826	12	24.00	37,710	26	24.00	38	54,536
Sat-3/7/15	16,894	12	24.00	37,982	26	24.00	38	54,876
Sun-3/8/15	16,895	12	24.00	37,764	26	24.00	38	54,659
Mon-3/9/15	16,869	12	24.00	37,613	26	24.00	38	54,482
Tue-3/10/15	16,910	12	24.00	37,683	26	24.00	38	54,593
Wed-3/11/15	16,905	12	24.00	37,328	26	24.00	38	54,233
Thu-3/12/15	16,905	12	24.00	36,971	26	24.00	37	53,876
Fri-3/13/15	16,931	12	24.00	37,478	26	24.00	38	54,409
Sat-3/14/15	16,948	12	24.00	37,610	26	24.00	38	54,558
Sun-3/15/15	16,921	12	24.00	37,213	26	24.00	38	54,134
Mon-3/16/15	16,923	12	24.00	37,457	26	24.00	38	54,380
Tue-3/17/15	16,869	12	24.00	37,026	26	24.00	37	53,895
Wed-3/18/15	16,849	12	24.00	36,888	26	24.00	37	53,737
Thu-3/19/15	16,867	12	24.00	36,837	26	24.00	37	53,704
Fri-3/20/15	16,860	12	24.00	36,995	26	24.00	37	53,855
Sat-3/21/15	16,850	12	24.00	36,880	26	24.00	37	53,730
Sun-3/22/15	16,805	12	24.00	36,531	25	24.00	37	53,336
Mon-3/23/15	16,802	12	24.00	36,422	25	24.00	37	53,224
Tue-3/24/15	16,816	12	24.00	36,390	25	24.00	37	53,206
Wed-3/25/15	16,897	12	24.00	36,677	25	24.00	37	53,574
Thu-3/26/15	16,894	12	24.00	36,543	25	24.00	37	53,437
Fri-3/27/15	16,808	12	24.00	36,259	25	24.00	37	53,067
Sat-3/28/15	16,814	12	24.00	35,643	25	24.00	36	52,457
Sun-3/29/15	16,861	12	24.00	35,755	25	24.00	37	52,616
Mon-3/30/15	16,937	12	24.00	35,038	24	24.00	36	51,975
Tue-3/31/15	16,936	12	24.00	34,150	24	24.00	35	51,086
TOTALS	522,913	12	744.00	1,147,570	26	744.00	37	1,670,483

TOTAL VOLUME EXTRACTED :	1,670,483 GALLONS
DAYS IN MONTH :	31 DAYS
MONTHLY AVERAGE FLOW RATE :	37.42 GPM

MARSHY AREA EXTRACTION DATA

Month of: Mar-15

Marshy Well Extraction				Daily Flow	Daily Total
Date	PW-1 Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-3/1/15	2,344	2	24.00	2	2,344
Mon-3/2/15	2,270	2	24.00	2	2,270
Tue-3/3/15	2,221	2	24.00	2	2,221
Wed-3/4/15	2,233	2	24.00	2	2,233
Thu-3/5/15	2,233	2	24.00	2	2,233
Fri-3/6/15	2,225	2	24.00	2	2,225
Sat-3/7/15	2,230	2	24.00	2	2,230
Sun-3/8/15	2,250	2	24.00	2	2,250
Mon-3/9/15	2,253	2	24.00	2	2,253
Tue-3/10/15	2,258	2	24.00	2	2,258
Wed-3/11/15	2,265	2	24.00	2	2,265
Thu-3/12/15	2,265	2	24.00	2	2,265
Fri-3/13/15	2,264	2	24.00	2	2,264
Sat-3/14/15	2,264	2	24.00	2	2,264
Sun-3/15/15	2,268	2	24.00	2	2,268
Mon-3/16/15	2,271	2	24.00	2	2,271
Tue-3/17/15	2,267	2	24.00	2	2,267
Wed-3/18/15	2,267	2	24.00	2	2,267
Thu-3/19/15	2,263	2	24.00	2	2,263
Fri-3/20/15	2,263	2	24.00	2	2,263
Sat-3/21/15	2,260	2	24.00	2	2,260
Sun-3/22/15	2,258	2	24.00	2	2,258
Mon-3/23/15	2,250	2	24.00	2	2,250
Tue-3/24/15	2,244	2	24.00	2	2,244
Wed-3/25/15	2,243	2	24.00	2	2,243
Thu-3/26/15	2,245	2	24.00	2	2,245
Fri-3/27/15	2,243	2	24.00	2	2,243
Sat-3/28/15	2,251	2	24.00	2	2,251
Sun-3/29/15	2,239	2	24.00	2	2,239
Mon-3/30/15	2,194	2	23.47	2	2,194
Tue-3/31/15	2,086	2	22.57	1	2,086
TOTALS	69,687	2	742.03	2	69,687

TOTAL VOLUME EXTRACTED :	69,687 GALLONS
DAYS IN MONTH :	31 DAYS
MONTHLY AVERAGE FLOW RATE :	1.56 GPM

3/31/15 - PW-1 was shut down for maintenance.

SOUTHWEST AREA EXTRACTION DATA

Month of: **Mar-15**

SouthWest Well Extraction				Daily	Daily
Date	ACTIVE WELLS			Flow	Total
	Gallons	GPM	Run Hrs.	GPM	Gallons
Sun-3/1/15	11,516	8	24.00	8	11,516
Mon-3/2/15	11,500	8	24.00	8	11,500
Tue-3/3/15	11,509	8	24.00	8	11,509
Wed-3/4/15	11,465	8	24.00	8	11,465
Thu-3/5/15	11,335	8	24.00	8	11,335
Fri-3/6/15	11,435	8	24.00	8	11,435
Sat-3/7/15	11,408	8	24.00	8	11,408
Sun-3/8/15	11,329	8	24.00	8	11,329
Mon-3/9/15	11,284	8	24.00	8	11,284
Tue-3/10/15	11,264	8	24.00	8	11,264
Wed-3/11/15	11,173	8	24.00	8	11,173
Thu-3/12/15	11,064	8	24.00	8	11,064
Fri-3/13/15	11,068	8	24.00	8	11,068
Sat-3/14/15	11,067	8	24.00	8	11,067
Sun-3/15/15	11,025	8	24.00	8	11,025
Mon-3/16/15	11,009	8	24.00	8	11,009
Tue-3/17/15	10,934	8	24.00	8	10,934
Wed-3/18/15	10,899	8	24.00	8	10,899
Thu-3/19/15	10,866	8	24.00	8	10,866
Fri-3/20/15	10,889	8	24.00	8	10,889
Sat-3/21/15	10,858	8	24.00	8	10,858
Sun-3/22/15	10,782	7	24.00	7	10,782
Mon-3/23/15	10,758	7	24.00	7	10,758
Tue-3/24/15	10,731	7	24.00	7	10,731
Wed-3/25/15	10,729	7	24.00	7	10,729
Thu-3/26/15	10,703	7	24.00	7	10,703
Fri-3/27/15	10,664	7	24.00	7	10,664
Sat-3/28/15	10,579	7	24.00	7	10,579
Sun-3/29/15	10,576	7	24.00	7	10,576
Mon-3/30/15	10,561	7	24.00	7	10,561
Tue-3/31/15	10,533	7	24.00	7	10,533
TOTALS	341,513	8	744.00	8	341,513

TOTAL VOLUME EXTRACTED :	341,513 GALLONS
DAYS IN MONTH :	31 DAYS
MONTHLY AVERAGE FLOW RATE :	7.65 GPM

Note: ACTIVE WELLS = TW-8, TW-22

UNIT "E" EXTRACTION DATA

Month of: **Mar-15**

Date	TW-16			TW-18			TW-19			Daily	Daily
	Gallons	GPM	Run Hrs.	Gallons	GPM	Run Hrs.	Gallons	GPM	Run Hrs.	Flow GPM	Total Gallons
Sun-3/1/15	46,933	33	24.00	250,216	174	24.00	100,080	70	24.00	276	397,229
Mon-3/2/15	46,869	33	24.00	250,194	174	24.00	100,137	70	24.00	276	397,200
Tue-3/3/15	46,903	33	24.00	250,179	174	24.00	100,101	70	24.00	276	397,183
Wed-3/4/15	47,124	33	24.00	250,200	174	24.00	99,873	69	24.00	276	397,197
Thu-3/5/15	47,181	33	24.00	247,905	172	24.00	99,822	69	24.00	274	394,908
Fri-3/6/15	47,231	33	24.00	235,695	164	24.00	99,773	69	24.00	266	382,699
Sat-3/7/15	47,180	33	24.00	235,564	164	24.00	99,822	69	24.00	266	382,566
Sun-3/8/15	47,149	33	24.00	240,428	167	24.00	99,853	69	24.00	269	387,430
Mon-3/9/15	47,156	33	24.00	243,850	169	24.00	99,841	69	24.00	271	390,847
Tue-3/10/15	47,192	33	24.00	247,444	172	24.00	99,802	69	24.00	274	394,438
Wed-3/11/15	47,177	33	24.00	248,741	173	24.00	99,817	69	24.00	275	395,735
Thu-3/12/15	47,251	33	24.00	248,745	173	24.00	99,744	69	24.00	275	395,740
Fri-3/13/15	47,269	33	24.00	248,751	173	24.00	99,733	69	24.00	275	395,753
Sat-3/14/15	47,207	33	24.00	248,742	173	24.00	99,786	69	24.00	275	395,735
Sun-3/15/15	46,859	33	24.00	248,741	173	24.00	100,132	70	24.00	275	395,732
Mon-3/16/15	46,874	33	24.00	248,774	173	24.00	100,121	70	24.00	275	395,769
Tue-3/17/15	46,829	33	24.00	248,757	173	24.00	100,159	70	24.00	275	395,745
Wed-3/18/15	46,886	33	24.00	244,729	170	24.00	100,108	70	24.00	272	391,723
Thu-3/19/15	46,901	33	24.00	241,473	168	24.00	100,094	70	24.00	270	388,468
Fri-3/20/15	46,902	33	24.00	241,487	168	24.00	100,096	70	24.00	270	388,485
Sat-3/21/15	46,894	33	24.00	241,456	168	24.00	100,098	70	24.00	270	388,448
Sun-3/22/15	46,930	33	24.00	241,467	168	24.00	100,064	69	24.00	270	388,461
Mon-3/23/15	46,941	33	24.00	241,481	168	24.00	100,052	69	24.00	270	388,474
Tue-3/24/15	46,740	33	23.90	240,537	168	23.92	99,636	69	23.90	269	386,913
Wed-3/25/15	46,694	32	24.00	248,903	173	24.00	100,291	70	24.00	275	395,888
Thu-3/26/15	46,668	32	24.00	251,661	175	24.00	100,322	70	24.00	277	398,651
Fri-3/27/15	46,691	32	24.00	251,706	175	24.00	100,299	70	24.00	277	398,696
Sat-3/28/15	46,718	32	24.00	251,661	175	24.00	100,274	70	24.00	277	398,653
Sun-3/29/15	46,749	32	24.00	251,682	175	24.00	100,241	70	24.00	277	398,672
Mon-3/30/15	44,524	32	22.90	249,515	173	24.00	95,895	70	22.90	271	389,934
Tue-3/31/15	46,553	32	24.00	248,764	173	24.00	100,438	70	24.00	275	395,755
TOTALS	1,453,175	33	742.80	7,639,448	171	743.92	3,096,504	69	742.80	273	12,189,127

TOTAL VOLUME EXTRACTED :	12,189,127 GALLONS
DAYS IN MONTH :	31 DAYS
MONTHLY AVERAGE FLOW RATE :	273.05 GPM

3/30/15 - TW-16 and TW-19 were shut down briefly to upgrade pipeline to Pond.

TABLE #7

Little Lake Area System

MW-53i	
Date	1,4-Dioxane ug/L
12/02/14	140
01/12/15	120
02/06/15	52
03/02/15	64

A2 Cleaning Supply Well	
Date	1,4-Dioxane ug/L
12/15/14	53
01/15/15	47
02/04/15	70
03/02/15	65

Date	Gallons Purged
3/5/2015	50,100

TABLE #8

INDIVIDUAL PURGE WELL CONCENTRATIONS

SAMPLE ID	Date Sampled	1,4-DIOXANE (ppb)
DOLPH-03-02-15-08:10-1	03/02/15	86
TW-20-03-02-15-08:27-1	03/02/15	850
LB-4-03-02-15-08:15-1	03/02/15	470
TW-21-03-02-15-08:36-1	03/02/15	110
TW-16-03-02-15-09:25-1	03/02/15	910
TW-18-03-02-15-08:06-1	03/02/15	280
TW-19-03-02-15-09:23-1	03/02/15	650
PW-1-03-02-15-08:08-1	03/02/15	830
TW-22-03-02-15-09:48-1	03/02/15	490
TW-8-03-02-15-09:49-1	03/02/15	620

RED POND DATA

Month of: Mar-15

Date	Time	Notes	Red Pond				
			Pond	Level	Aeration	Influent	Influent
			Visual Chk	Feet	Hours	Hours	GPM
Sun-3/1/15	3:05	(1)		4.9	-	24.00	490
Mon-3/2/15	3:00		Y	4.9	-	24.00	490
Tue-3/3/15	3:00		Y	4.9	-	24.00	490
Wed-3/4/15	3:00		Y	5.0	-	24.00	490
Thu-3/5/15	3:00		Y	5.0	-	24.00	487
Fri-3/6/15	3:00		Y	5.4	-	24.00	474
Sat-3/7/15	3:00	(1)		5.2	-	24.00	474
Sun-3/8/15	3:00	(1)		5.0	-	24.00	477
Mon-3/9/15	3:00		Y	4.8	-	24.00	482
Tue-3/10/15	3:00		Y	4.8	-	24.00	490
Wed-3/11/15	3:00		Y	4.8	-	24.00	492
Thu-3/12/15	3:00		Y	4.8	-	24.00	492
Fri-3/13/15	3:00		Y	4.8	-	24.00	492
Sat-3/14/15	3:00	(1)		4.9	-	24.00	492
Sun-3/15/15	3:00	(1)		4.9	-	24.00	492
Mon-3/16/15	3:00		Y	5.0	-	24.00	492
Tue-3/17/15	3:00		Y	5.0	-	24.00	491
Wed-3/18/15	3:00		Y	5.0	-	24.00	486
Thu-3/19/15	3:00		Y	5.1	-	24.00	481
Fri-3/20/15	3:00		Y	5.0	-	24.00	481
Sat-3/21/15	3:00	(1)		4.9	-	24.00	481
Sun-3/22/15	3:00	(1)		4.8	-	24.00	481
Mon-3/23/15	3:00		Y	4.6	-	24.00	481
Tue-3/24/15	3:00		Y	4.5	-	24.00	479
Wed-3/25/15	3:00		Y	4.4	-	24.00	492
Thu-3/26/15	3:00		Y	4.5	-	24.00	495
Fri-3/27/15	3:00		Y	4.5	-	24.00	495
Sat-3/28/15	3:00	(1)		4.8	-	24.00	494
Sun-3/29/15	3:00	(1)		4.8	-	24.00	494
Mon-3/30/15	3:00		Y	4.9	-	24.00	478
Tue-3/31/15	3:00		Y	5.0	-	24.00	489
TOTALS			-	-	-	744	

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

TABLE #10

RED POND CONCENTRATIONS

Concentrations of 1,4-Dioxane found in the Red Pond

SAMPLE ID	Date Sampled	1,4-DIOXANE (ppb)
Red Pond-03-02-15-08:05-1	3/2/2015	440
Red Pond-03-09-15-07:55-1	3/9/2015	480
Red Pond-03-16-15-08:25-1	3/16/2015	530
Red Pond-03-23-15-07:45-1	3/23/2015	430
Red Pond-03-30-15-07:20-1	3/30/2015	440

Analyte value quantified from a dilution, reporting limit is raised to 10 ppb to reflect dilution

OZONE OPERATION REPORT

Month of: Mar-15

Date	Time	Notes	SYSTEM-1A		SYSTEM-1B		SYSTEM-2A		SYSTEM-2B	
			Flow GPM	Run Hours	Flow GPM	Run Hours	Flow GPM	Run Hours	Flow GPM	Run Hours
Sun-3/1/15	3:07 AM	(1)	240	24.00	0	0.00	240	24.00	0	0.00
Mon-3/2/15	3:00 AM		239	24.00	0	0.00	241	24.00	0	0.00
Tue-3/3/15	3:00 AM		240	23.90	0	0.00	240	23.92	0	0.00
Wed-3/4/15	3:00 AM		240	24.00	0	0.00	239	24.00	0	0.00
Thu-3/5/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Fri-3/6/15	3:00 AM		239	24.00	0	0.00	241	24.00	0	0.00
Sat-3/7/15	3:00 AM	(1)	240	24.00	0	0.00	241	24.00	0	0.00
Sun-3/8/15	3:00 AM	(1)	240	24.00	0	0.00	240	24.00	0	0.00
Mon-3/9/15	3:00 AM		240	24.00	0	0.00	239	24.00	0	0.00
Tue-3/10/15	3:00 AM		239	24.00	0	0.00	240	24.00	0	0.00
Wed-3/11/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Thu-3/12/15	3:00 AM		239	24.00	0	0.00	239	24.00	0	0.00
Fri-3/13/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Sat-3/14/15	3:00 AM	(1)	240	23.83	0	0.00	241	23.83	0	0.00
Sun-3/15/15	3:00 AM	(1)	240	24.00	0	0.00	241	24.00	0	0.00
Mon-3/16/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00
Tue-3/17/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Wed-3/18/15	3:00 AM		240	24.00	0	0.00	239	23.05	0	0.00
Thu-3/19/15	3:00 AM		240	24.00	0	0.00	239	24.00	0	0.00
Fri-3/20/15	3:00 AM		239	24.00	0	0.00	240	24.00	0	0.00
Sat-3/21/15	3:00 AM	(1)	240	24.00	0	0.00	240	24.00	0	0.00
Sun-3/22/15	3:00 AM	(1)	240	24.00	0	0.00	240	24.00	0	0.00
Mon-3/23/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Tue-3/24/15	3:00 AM		239	24.00	0	0.00	240	24.00	0	0.00
Wed-3/25/15	3:00 AM		240	24.00	0	0.00	241	24.00	0	0.00
Thu-3/26/15	3:00 AM		240	24.00	0	0.00	243	24.00	0	0.00
Fri-3/27/15	3:00 AM		239	24.00	0	0.00	240	24.00	0	0.00
Sat-3/28/15	3:00 AM	(1)	239	23.55	0	0.00	241	23.57	0	0.00
Sun-3/29/15	3:00 AM	(1)	239	24.00	0	0.00	240	24.00	0	0.00
Mon-3/30/15	3:00 AM		240	22.83	0	0.00	241	23.78	0	0.00
Tue-3/31/15	3:00 AM		240	24.00	0	0.00	240	24.00	0	0.00

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

3/30/15 - Treatment was shut down briefly to upgrade pipeline to Pond.

TABLE #12

GREEN POND / DISCHARGE DATA

Month of: Mar-15

			Green Pond																	
Date	Time	Notes	Pond			Influent			Pond Discharge			Bypass Discharge			Recirc Thru UV to Pond			Recirc Thru UV to Disch		
			Visual Chk	Level Feet	Aeration Hours	Influent Hours	Influent GPM	Pond Discharge GPM	Pond Discharge Gallons	Pond Discharge Hours	Bypass Discharge GPM	Bypass Discharge Gallons	Bypass Discharge Hours	Recirc Thru UV to Pond GPM	Recirc Thru UV to Pond Gallons	Recirc Thru UV to Pond Hours	Recirc Thru UV to Disch GPM	Recirc Thru UV to Disch Gallons	Recirc Thru UV to Disch Hours	
Sun-3/1/15	3:05 AM	(1)		-	-							502	723,123	24.00	-	-	-	-	-	-
Mon-3/2/15	3:00 AM		Y	-	-							502	723,031	24.00	-	-	-	-	-	-
Tue-3/3/15	3:00 AM		Y	-	-							499	718,423	24.00	-	-	-	-	-	-
Wed-3/4/15	3:00 AM		Y	-	-							502	722,746	24.00	-	-	-	-	-	-
Thu-3/5/15	3:00 AM		Y	-	-							502	722,796	24.00	-	-	-	-	-	-
Fri-3/6/15	3:00 AM		Y	-	-							502	723,069	24.00	-	-	-	-	-	-
Sat-3/7/15	3:00 AM	(1)		-	-							503	723,678	24.00	-	-	-	-	-	-
Sun-3/8/15	3:00 AM	(1)		-	-							503	723,747	24.00	-	-	-	-	-	-
Mon-3/9/15	3:00 AM		Y	-	-							503	723,721	24.00	-	-	-	-	-	-
Tue-3/10/15	3:00 AM		Y	-	-							502	723,568	24.00	-	-	-	-	-	-
Wed-3/11/15	3:00 AM		Y	-	-							502	723,483	24.00	-	-	-	-	-	-
Thu-3/12/15	3:00 AM		Y	-	-							503	723,727	24.00	-	-	-	-	-	-
Fri-3/13/15	3:00 AM		Y	-	-							503	723,874	24.00	-	-	-	-	-	-
Sat-3/14/15	3:00 AM	(1)		-	-							498	717,413	24.00	-	-	-	-	-	-
Sun-3/15/15	3:00 AM	(1)		-	-							503	723,690	24.00	-	-	-	-	-	-
Mon-3/16/15	3:00 AM		Y	-	-							503	723,659	24.00	-	-	-	-	-	-
Tue-3/17/15	3:00 AM		Y	-	-							503	723,612	24.00	-	-	-	-	-	-
Wed-3/18/15	3:00 AM		Y	-	-							492	708,436	24.00	-	-	-	-	-	-
Thu-3/19/15	3:00 AM		Y	-	-							502	722,903	24.00	-	-	-	-	-	-
Fri-3/20/15	3:00 AM		Y	-	-							502	723,111	24.00	-	-	-	-	-	-
Sat-3/21/15	3:00 AM	(1)		-	-							502	723,342	24.00	-	-	-	-	-	-
Sun-3/22/15	3:00 AM	(1)		-	-							502	723,361	24.00	-	-	-	-	-	-
Mon-3/23/15	3:00 AM		Y	-	-							502	723,357	24.00	-	-	-	-	-	-
Tue-3/24/15	3:00 AM		Y	-	-							503	723,849	24.00	-	-	-	-	-	-
Wed-3/25/15	3:00 AM		Y	-	-							503	723,966	24.00	-	-	-	-	-	-
Thu-3/26/15	3:00 AM		Y	-	-							503	724,119	24.00	-	-	-	-	-	-
Fri-3/27/15	3:00 AM		Y	-	-							503	723,684	24.00	-	-	-	-	-	-
Sat-3/28/15	3:00 AM	(1)		-	-							501	708,391	23.55	-	-	-	-	-	-
Sun-3/29/15	3:00 AM	(1)		-	-							502	722,710	24.00	-	-	-	-	-	-
Mon-3/30/15	3:00 AM		Y	-	-							491	700,833	23.77	-	-	-	-	-	-
Tue-3/31/15	3:00 AM		Y	-	-							502	722,370	24.00	-	-	-	-	-	-
TOTALS													22,361,792	743						

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

TABLE #13
Daily Discharge Monitoring Report

	(Daily)	(Influent - Red Pond)	(Effluent - Outfall)	(Effluent - Outfall)	(Weekly)	(2 x Week)	(4 x Week)	(5 X Week)	(2 X Week)
PARAMETER NAME	Flow	1,4-Dioxane	1,4-Dioxane	Hydrogen Peroxide (measured as TRO)	Outfall Observation	Equipment Inspection	pH	Bromate	Sodium Bisulfite Dose Rate
PARAMETER CODE	50050	82388	82388	00139	84130	46478	00400	99814	99798
MONITORING PT.	001A	001A	001A	001A	001A	001A	001A	001A	001A
STAGE CODE	1	G	1	1	1	1	1	1	1
UNIT	MGD	mg/l	ug/l	ug/l	yes/no	yes/no	S.U.	ug/l	mg/l
3/1/2015	0.723		4					6	
3/2/2015	0.723	0.44	4	50	yes	yes	6.6	5	8
3/3/2015	0.718		4	50	no	no	6.6	5	
3/4/2015	0.723		4	0	no	no	6.7	5	
3/5/2015	0.723		5	0	no	yes	6.6	0	20
3/6/2015	0.723			0	no	no	6.6		
3/7/2015	0.724								
3/8/2015	0.724		5					6	
3/9/2015	0.724	0.48	5	0	yes	yes	6.6	5	20
3/10/2015	0.724		5	50	no	no	6.7	5	
3/11/2015	0.723		5	50	no	no	6.6	5	
3/12/2015	0.724		5	50	no	yes	6.7	6	22
3/13/2015	0.724			50	no	no	6.7		
3/14/2015	0.717								
3/15/2015	0.724		4					0	
3/16/2015	0.724	0.53	4	100	yes	yes	6.7	0	8
3/17/2015	0.724		4	50	no	no	6.7	6	
3/18/2015	0.708		5	50	no	no	6.8	5	
3/19/2015	0.723		4	50	no	yes	6.8	5	10
3/20/2015	0.723			50	no	no	6.7		
3/21/2015	0.723								
3/22/2015	0.723		4					5	
3/23/2015	0.723	0.43	4	50	yes	yes	6.7	5	28
3/24/2015	0.724		4	0	no	no	6.7	5	
3/25/2015	0.724		5	0	no	no	6.7	6	
3/26/2015	0.724		4	50	no	yes	6.6	5	20
3/27/2015	0.724			50	no	no	6.7		
3/28/2015	0.708								
3/29/2015	0.723		4					5	
3/30/2015	0.701	0.44	4	50	yes	yes	6.7	5	22
3/31/2015	0.722		4	50	no	no	6.7	0	
Discharged (mg)	22.362								
Monthly Avg			4					4	

Bromate: A zero value equals ND (less than 5 ppb)
Hydrogen Peroxide - A zero value equals ND (less than 100 ppb)