



April 20, 2022

Bridgett Carver
Surface Water Quality Division
Michigan Department of EGLE
301 East Louis Glick Highway
Jackson, Michigan 49201

**Re: Monitoring Report #299
March 1 – March 31, 2022**

Dear Ms. Carver:

Pursuant to the National Pollutant Discharge Elimination System (NPDES) Permit No. MI0048453, please find the enclosed Monitoring Report for the period of March 1 through March 31, 2022.

Should you have any questions or concerns regarding this report, please contact me at 269-993-7585.

Sincerely,

FLEIS & VANDENBRINK

A handwritten signature in blue ink, appearing to read "Jim Brode", is positioned above the printed name and title.

Jim Brode, CPG
Senior Project Manager

cc: Dan Hamel, EGLE
Supervisor, Scio Twp.
City of Ann Arbor

EXTRACTION DATA

- TABLE #1 - UNIT "D2" UPGRADIENT EXTRACTION DATA**
- TABLE #2 - UNIT "D2" DOWNGRADIENT EXTRACTION DATA**
- TABLE #3 - CORE AREA EXTRACTION DATA**
- TABLE #4 - MARSHY AREA EXTRACTION DATA**
- TABLE #5 - SOUTHWEST AREA EXTRACTION DATA**
- TABLE #6 - UNIT "E" EXTRACTION DATA**
- TABLE #7 - LITTLE LAKE AREA SYSTEM DATA**
- TABLE #8 - INDIVIDUAL PURGE WELL CONCENTRATIONS**
- TABLE #9 - RED POND DATA**
- TABLE #10 - RED POND CONCENTRATIONS**

OZONE OPERATION DATA

- TABLE #11 - OZONE OPERATION REPORT**

DISCHARGE DATA

- TABLE #12 - GREEN POND / DISCHARGE DATA**
- TABLE #13 - DAILY DISCHARGE MONITORING REPORT**

TABLE #1

UNIT D2 UPGRADIENT EXTRACTION DATA

Month of: Mar-22

| Date | Horizontal Well Extraction | | | TW-9 | | | TW-5 | | | TW-21 | | | Daily Flow | Daily Total |
|---------------|----------------------------|-----|----------|---------------|-----------|-------------|----------------|-----------|--------------|------------------|------------|---------------|------------|------------------|
| | HW-S | GPM | Run Hrs. | TW-9 | GPM | Run Hrs. | TW-5 | GPM | Run Hrs. | TW-21 | GPM | Run Hrs. | GPM | Gallons |
| | Gallons | | | Gallons | | | Gallons | | | Gallons | | | | |
| Tue-3/1/22 | - | - | - | - | - | - | - | - | - | 144,089 | 100 | 24.00 | 100 | 144,089 |
| Wed-3/2/22 | - | - | - | - | - | - | - | - | - | 144,064 | 100 | 24.00 | 100 | 144,064 |
| Thu-3/3/22 | - | - | - | - | - | - | - | - | - | 144,012 | 100 | 24.00 | 100 | 144,012 |
| Fri-3/4/22 | - | - | - | - | - | - | - | - | - | 144,043 | 100 | 24.00 | 100 | 144,043 |
| Sat-3/5/22 | - | - | - | - | - | - | - | - | - | 144,136 | 100 | 24.00 | 100 | 144,136 |
| Sun-3/6/22 | - | - | - | - | - | - | - | - | - | 142,768 | 100 | 23.75 | 99 | 142,768 |
| Mon-3/7/22 | - | - | - | - | - | - | - | - | - | 144,045 | 100 | 24.00 | 100 | 144,045 |
| Tue-3/8/22 | - | - | - | - | - | - | - | - | - | 144,069 | 100 | 24.00 | 100 | 144,069 |
| Wed-3/9/22 | - | - | - | - | - | - | - | - | - | 144,077 | 100 | 24.00 | 100 | 144,077 |
| Thu-3/10/22 | - | - | - | - | - | - | - | - | - | 143,889 | 100 | 24.00 | 100 | 143,889 |
| Fri-3/11/22 | - | - | - | - | - | - | - | - | - | 144,015 | 100 | 24.00 | 100 | 144,015 |
| Sat-3/12/22 | - | - | - | - | - | - | - | - | - | 143,944 | 100 | 24.00 | 100 | 143,944 |
| Sun-3/13/22 | - | - | - | - | - | - | - | - | - | 137,975 | 100 | 22.98 | 96 | 137,975 |
| Mon-3/14/22 | - | - | - | - | - | - | - | - | - | 144,116 | 100 | 24.00 | 100 | 144,116 |
| Tue-3/15/22 | - | - | - | - | - | - | - | - | - | 144,094 | 100 | 24.00 | 100 | 144,094 |
| Wed-3/16/22 | - | - | - | - | - | - | - | - | - | 144,140 | 100 | 24.00 | 100 | 144,140 |
| Thu-3/17/22 | - | - | - | 24,533 | 74 | 5.53 | - | - | - | 144,186 | 100 | 24.00 | 117 | 168,719 |
| Fri-3/18/22 | - | - | - | - | - | - | - | - | - | 144,168 | 100 | 24.00 | 100 | 144,168 |
| Sat-3/19/22 | - | - | - | - | - | - | - | - | - | 144,140 | 100 | 24.00 | 100 | 144,140 |
| Sun-3/20/22 | - | - | - | - | - | - | - | - | - | 144,146 | 100 | 24.00 | 100 | 144,146 |
| Mon-3/21/22 | - | - | - | - | - | - | - | - | - | 144,168 | 100 | 24.00 | 100 | 144,168 |
| Tue-3/22/22 | - | - | - | - | - | - | - | - | - | 144,105 | 100 | 24.00 | 100 | 144,105 |
| Wed-3/23/22 | - | - | - | - | - | - | - | - | - | 144,126 | 100 | 24.00 | 100 | 144,126 |
| Thu-3/24/22 | - | - | - | - | - | - | - | - | - | 144,135 | 100 | 24.00 | 100 | 144,135 |
| Fri-3/25/22 | - | - | - | - | - | - | - | - | - | 144,106 | 100 | 24.00 | 100 | 144,106 |
| Sat-3/26/22 | - | - | - | - | - | - | - | - | - | 144,065 | 100 | 24.00 | 100 | 144,065 |
| Sun-3/27/22 | - | - | - | - | - | - | - | - | - | 144,005 | 100 | 24.00 | 100 | 144,005 |
| Mon-3/28/22 | - | - | - | - | - | - | 35,666 | 59 | 10.03 | 144,011 | 100 | 24.00 | 125 | 179,677 |
| Tue-3/29/22 | - | - | - | - | - | - | 86,770 | 60 | 24.00 | 144,043 | 100 | 24.00 | 160 | 230,813 |
| Wed-3/30/22 | - | - | - | - | - | - | 23,985 | 59 | 6.75 | 46,135 | 100 | 7.70 | 49 | 70,120 |
| Thu-3/31/22 | - | - | - | - | - | - | 38,119 | 59 | 10.70 | 57,112 | 100 | 9.52 | 66 | 95,231 |
| TOTALS | - | - | - | 24,533 | 74 | 5.53 | 184,540 | 60 | 51.48 | 4,274,127 | 100 | 711.95 | 100 | 4,483,200 |

| | |
|-----------------------------|-------------------|
| TOTAL VOLUME EXTRACTED : | 4,483,200 GALLONS |
| DAYS IN MONTH : | 31 DAYS |
| MONTHLY AVERAGE FLOW RATE : | 100.43 GPM |

3/1/22-3/28/22 - TW-5 was shut down.
 3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.
 3/30/22-3/31/22 - TW-5 and TW-21 were shut down for system maintenance.

UNIT D2 DOWNGRADIENT EXTRACTION DATA

Month of: Mar-22

| Date | LB-1 | | | LB-4 | | | Daily | Daily |
|---------------|---------|-----|----------|------------------|------------|---------------|-----------|------------------|
| | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Flow GPM | Total Gallons |
| Tue-3/1/22 | - | - | - | 144,211 | 100 | 24.00 | 100 | 144,211 |
| Wed-3/2/22 | - | - | - | 144,202 | 100 | 24.00 | 100 | 144,202 |
| Thu-3/3/22 | - | - | - | 144,235 | 100 | 24.00 | 100 | 144,235 |
| Fri-3/4/22 | - | - | - | 144,240 | 100 | 24.00 | 100 | 144,240 |
| Sat-3/5/22 | - | - | - | 144,204 | 100 | 24.00 | 100 | 144,204 |
| Sun-3/6/22 | - | - | - | 144,206 | 100 | 24.00 | 100 | 144,206 |
| Mon-3/7/22 | - | - | - | 144,219 | 100 | 24.00 | 100 | 144,219 |
| Tue-3/8/22 | - | - | - | 144,232 | 100 | 24.00 | 100 | 144,232 |
| Wed-3/9/22 | - | - | - | 144,228 | 100 | 24.00 | 100 | 144,228 |
| Thu-3/10/22 | - | - | - | 144,231 | 100 | 24.00 | 100 | 144,231 |
| Fri-3/11/22 | - | - | - | 144,202 | 100 | 24.00 | 100 | 144,202 |
| Sat-3/12/22 | - | - | - | 144,254 | 100 | 24.00 | 100 | 144,254 |
| Sun-3/13/22 | - | - | - | 138,222 | 100 | 22.98 | 96 | 138,222 |
| Mon-3/14/22 | - | - | - | 144,209 | 100 | 24.00 | 100 | 144,209 |
| Tue-3/15/22 | - | - | - | 144,197 | 100 | 24.00 | 100 | 144,197 |
| Wed-3/16/22 | - | - | - | 144,170 | 100 | 24.00 | 100 | 144,170 |
| Thu-3/17/22 | - | - | - | 144,229 | 100 | 24.00 | 100 | 144,229 |
| Fri-3/18/22 | - | - | - | 144,183 | 100 | 24.00 | 100 | 144,183 |
| Sat-3/19/22 | - | - | - | 144,190 | 100 | 24.00 | 100 | 144,190 |
| Sun-3/20/22 | - | - | - | 144,192 | 100 | 24.00 | 100 | 144,192 |
| Mon-3/21/22 | - | - | - | 144,157 | 100 | 24.00 | 100 | 144,157 |
| Tue-3/22/22 | - | - | - | 144,202 | 100 | 24.00 | 100 | 144,202 |
| Wed-3/23/22 | - | - | - | 144,221 | 100 | 24.00 | 100 | 144,221 |
| Thu-3/24/22 | - | - | - | 144,203 | 100 | 24.00 | 100 | 144,203 |
| Fri-3/25/22 | - | - | - | 144,235 | 100 | 24.00 | 100 | 144,235 |
| Sat-3/26/22 | - | - | - | 144,229 | 100 | 24.00 | 100 | 144,229 |
| Sun-3/27/22 | - | - | - | 144,253 | 100 | 24.00 | 100 | 144,253 |
| Mon-3/28/22 | - | - | - | 144,198 | 100 | 24.00 | 100 | 144,198 |
| Tue-3/29/22 | - | - | - | 144,228 | 100 | 24.00 | 100 | 144,228 |
| Wed-3/30/22 | - | - | - | 46,239 | 100 | 7.70 | 32 | 46,239 |
| Thu-3/31/22 | - | - | - | 56,083 | 100 | 9.33 | 39 | 56,083 |
| TOTALS | - | - | - | 4,278,504 | 100 | 712.01 | 96 | 4,278,504 |

| | |
|-----------------------------|-------------------|
| TOTAL VOLUME EXTRACTED : | 4,278,504 GALLONS |
| DAYS IN MONTH : | 31 DAYS |
| MONTHLY AVERAGE FLOW RATE : | 95.84 GPM |

3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.
 3/30/22-3/31/22 - LB-4 was shut down for system maintenance.

TABLE #3

CORE AREA EXTRACTION DATA

Month of: Mar-22

| Date | TW-1 | | | TW-2 (Dolph) | | | TW-3 | | | TW-10 | | | TW-14 | | | TW-20 | | | TW-24 | | | Daily Flow GPM | Daily Total Gallons |
|---------------|---------|-----|----------|------------------|-----------|---------------|---------|-----|----------|----------------|-----------|---------------|------------------|-----------|---------------|------------------|-----------|---------------|----------------|-----------|---------------|----------------|---------------------|
| | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | | |
| Tue-3/1/22 | - | - | - | 38,221 | 27 | 24.00 | - | - | - | 40,068 | 28 | 24.00 | 42,621 | 30 | 24.00 | 47,962 | 33 | 24.00 | 26,344 | 18 | 24.00 | 136 | 195,216 |
| Wed-3/2/22 | - | - | - | 38,174 | 27 | 24.00 | - | - | - | 42,796 | 30 | 24.00 | 42,487 | 30 | 24.00 | 50,340 | 35 | 24.00 | 21,377 | 15 | 24.00 | 136 | 195,174 |
| Thu-3/3/22 | - | - | - | 38,138 | 26 | 24.00 | - | - | - | 38,157 | 26 | 24.00 | 34,223 | 24 | 24.00 | 41,097 | 29 | 24.00 | 30,763 | 21 | 24.00 | 127 | 182,378 |
| Fri-3/4/22 | - | - | - | 38,157 | 26 | 24.00 | - | - | - | 35,525 | 25 | 24.00 | 32,810 | 23 | 24.00 | 36,266 | 25 | 24.00 | 36,059 | 25 | 24.00 | 124 | 178,817 |
| Sat-3/5/22 | - | - | - | 38,114 | 26 | 24.00 | - | - | - | 35,358 | 25 | 24.00 | 42,891 | 30 | 24.00 | 36,866 | 26 | 24.00 | 36,238 | 25 | 24.00 | 132 | 189,467 |
| Sun-3/6/22 | - | - | - | 38,057 | 26 | 24.00 | - | - | - | 35,294 | 25 | 24.00 | 42,926 | 30 | 24.00 | 43,722 | 30 | 24.00 | 36,209 | 25 | 24.00 | 136 | 196,208 |
| Mon-3/7/22 | - | - | - | 38,069 | 26 | 24.00 | - | - | - | 35,372 | 25 | 24.00 | - | 0 | 0.02 | 40,290 | 28 | 24.00 | 36,146 | 25 | 24.00 | 104 | 149,877 |
| Tue-3/8/22 | - | - | - | 38,081 | 26 | 24.00 | - | - | - | 35,782 | 25 | 24.00 | 34,826 | 24 | 24.00 | 36,059 | 25 | 24.00 | 35,417 | 25 | 24.00 | 125 | 180,165 |
| Wed-3/9/22 | - | - | - | 38,049 | 26 | 24.00 | - | - | - | 35,813 | 25 | 24.00 | 34,080 | 24 | 24.00 | 40,586 | 28 | 24.00 | 31,715 | 22 | 24.00 | 125 | 180,243 |
| Thu-3/10/22 | - | - | - | 37,998 | 26 | 24.00 | - | - | - | 35,791 | 25 | 24.00 | 36,695 | 25 | 24.00 | 43,496 | 30 | 24.00 | 28,934 | 20 | 24.00 | 127 | 182,914 |
| Fri-3/11/22 | - | - | - | 37,954 | 26 | 24.00 | - | - | - | 35,718 | 25 | 24.00 | 36,665 | 25 | 24.00 | 43,402 | 30 | 24.00 | 29,033 | 20 | 24.00 | 127 | 182,772 |
| Sat-3/12/22 | - | - | - | 38,037 | 26 | 24.00 | - | - | - | 35,675 | 25 | 24.00 | 36,252 | 25 | 24.00 | 43,426 | 30 | 24.00 | 28,952 | 20 | 24.00 | 127 | 182,342 |
| Sun-3/13/22 | - | - | - | 36,415 | 26 | 22.98 | - | - | - | 34,210 | 25 | 22.98 | 34,219 | 25 | 23.00 | 41,601 | 30 | 22.98 | 27,737 | 20 | 22.98 | 121 | 174,182 |
| Mon-3/14/22 | - | - | - | 37,995 | 26 | 24.00 | - | - | - | 35,731 | 25 | 24.00 | 35,869 | 25 | 24.00 | 43,434 | 30 | 24.00 | 28,866 | 20 | 24.00 | 126 | 181,895 |
| Tue-3/15/22 | - | - | - | 37,979 | 26 | 24.00 | - | - | - | 35,757 | 25 | 24.00 | 35,847 | 25 | 24.00 | 43,433 | 30 | 24.00 | 28,895 | 20 | 24.00 | 126 | 181,911 |
| Wed-3/16/22 | - | - | - | 37,925 | 26 | 24.00 | - | - | - | 35,680 | 25 | 24.00 | 35,810 | 25 | 24.00 | 43,421 | 30 | 24.00 | 28,965 | 20 | 24.00 | 126 | 181,801 |
| Thu-3/17/22 | - | - | - | 37,841 | 26 | 24.00 | - | - | - | 40,815 | 28 | 24.00 | 35,881 | 25 | 24.00 | 43,507 | 30 | 24.00 | 29,010 | 20 | 24.00 | 130 | 187,054 |
| Fri-3/18/22 | - | - | - | 37,806 | 26 | 24.00 | - | - | - | 43,638 | 30 | 24.00 | 35,942 | 25 | 24.00 | 43,515 | 30 | 24.00 | 28,978 | 20 | 24.00 | 132 | 189,879 |
| Sat-3/19/22 | - | - | - | 37,819 | 26 | 24.00 | - | - | - | 43,450 | 30 | 24.00 | 36,019 | 25 | 24.00 | 43,489 | 30 | 24.00 | 29,019 | 20 | 24.00 | 132 | 189,796 |
| Sun-3/20/22 | - | - | - | 37,806 | 26 | 24.00 | - | - | - | 43,403 | 30 | 24.00 | 36,064 | 25 | 24.00 | 43,489 | 30 | 24.00 | 28,778 | 20 | 24.00 | 132 | 189,510 |
| Mon-3/21/22 | - | - | - | 37,719 | 26 | 24.00 | - | - | - | 43,469 | 30 | 24.00 | 36,132 | 25 | 24.00 | 43,421 | 30 | 24.00 | 28,806 | 20 | 24.00 | 132 | 189,547 |
| Tue-3/22/22 | - | - | - | 37,721 | 26 | 24.00 | - | - | - | 43,478 | 30 | 24.00 | 36,072 | 25 | 24.00 | 43,402 | 30 | 24.00 | 28,862 | 20 | 24.00 | 132 | 189,535 |
| Wed-3/23/22 | - | - | - | 37,741 | 26 | 24.00 | - | - | - | 43,508 | 30 | 24.00 | 36,063 | 25 | 24.00 | 43,377 | 30 | 24.00 | 29,104 | 20 | 24.00 | 132 | 189,793 |
| Thu-3/24/22 | - | - | - | 37,726 | 26 | 24.00 | - | - | - | 43,545 | 30 | 24.00 | 36,080 | 25 | 24.00 | 43,348 | 30 | 24.00 | 29,035 | 20 | 24.00 | 132 | 189,734 |
| Fri-3/25/22 | - | - | - | 34,945 | 25 | 23.75 | - | - | - | 12,766 | 35 | 6.08 | 36,139 | 25 | 24.00 | 15,176 | 42 | 6.08 | 29,097 | 20 | 24.00 | 89 | 128,123 |
| Sat-3/26/22 | - | - | - | 33,555 | 23 | 24.00 | - | - | - | - | - | 36,165 | 25 | 24.00 | - | - | - | 28,791 | 20 | 24.00 | 68 | 98,511 | |
| Sun-3/27/22 | - | - | - | 33,517 | 23 | 24.00 | - | - | - | - | - | 36,201 | 25 | 24.00 | - | - | - | 28,669 | 20 | 24.00 | 68 | 98,387 | |
| Mon-3/28/22 | - | - | - | 33,444 | 23 | 24.00 | - | - | - | - | - | 33,976 | 25 | 24.00 | - | - | - | 28,679 | 20 | 24.00 | 68 | 98,099 | |
| Tue-3/29/22 | - | - | - | 33,445 | 23 | 24.00 | - | - | - | - | - | 35,469 | 25 | 24.00 | - | - | - | 28,759 | 20 | 24.00 | 68 | 97,673 | |
| Wed-3/30/22 | - | - | - | 10,763 | 23 | 7.72 | - | - | - | - | - | 11,307 | 25 | 7.68 | - | - | - | 28,935 | 20 | 24.00 | 35 | 51,005 | |
| Thu-3/31/22 | - | - | - | 12,407 | 22 | 9.50 | - | - | - | - | - | 14,302 | 25 | 9.50 | - | - | - | 18,842 | 20 | 15.62 | 32 | 45,551 | |
| TOTALS | - | - | - | 1,101,618 | 26 | 711.95 | - | - | - | 940,799 | 27 | 581.07 | 1,052,033 | 25 | 688.20 | 1,038,095 | 30 | 581.07 | 915,014 | 21 | 734.60 | 113 | 5,047,559 |

| | |
|-----------------------------|-------------------|
| TOTAL VOLUME EXTRACTED : | 5,047,559 GALLONS |
| DAYS IN MONTH : | 31 DAYS |
| MONTHLY AVERAGE FLOW RATE : | 113.07 GPM |

3/7/22 - TW-14 was shut down during work at TW-25.
 3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.
 3/25/22-3/31/22 - TW-10 and TW-20 were shut down due to power failure and associated repairs.
 3/30/22-3/31/22 - TW-2 (Dolph) and TW-14 were shut down for system maintenance.
 3/31/22 - TW-24 was shut down to control Red Pond concentrations.

MARSHY AREA EXTRACTION DATA

Month of: Mar-22

| Marshy Well Extraction | | | | Daily | Daily |
|------------------------|---------------|----------|---------------|----------|---------------|
| Date | PW-1 | | | Flow | Total |
| | Gallons | GPM | Run Hrs. | GPM | Gallons |
| Tue-3/1/22 | 3,364 | 2 | 24.00 | 2 | 3,364 |
| Wed-3/2/22 | 3,377 | 2 | 24.00 | 2 | 3,377 |
| Thu-3/3/22 | 3,404 | 2 | 24.00 | 2 | 3,404 |
| Fri-3/4/22 | 3,387 | 2 | 24.00 | 2 | 3,387 |
| Sat-3/5/22 | 3,365 | 2 | 24.00 | 2 | 3,365 |
| Sun-3/6/22 | 3,354 | 2 | 24.00 | 2 | 3,354 |
| Mon-3/7/22 | 3,389 | 2 | 24.00 | 2 | 3,389 |
| Tue-3/8/22 | 3,383 | 2 | 24.00 | 2 | 3,383 |
| Wed-3/9/22 | 3,344 | 2 | 24.00 | 2 | 3,344 |
| Thu-3/10/22 | 3,299 | 2 | 24.00 | 2 | 3,299 |
| Fri-3/11/22 | 3,265 | 2 | 24.00 | 2 | 3,265 |
| Sat-3/12/22 | 3,202 | 2 | 24.00 | 2 | 3,202 |
| Sun-3/13/22 | 3,009 | 2 | 22.98 | 2 | 3,009 |
| Mon-3/14/22 | 3,094 | 2 | 24.00 | 2 | 3,094 |
| Tue-3/15/22 | 3,034 | 2 | 24.00 | 2 | 3,034 |
| Wed-3/16/22 | 2,803 | 2 | 24.00 | 2 | 2,803 |
| Thu-3/17/22 | 2,767 | 2 | 24.00 | 2 | 2,767 |
| Fri-3/18/22 | 2,762 | 2 | 24.00 | 2 | 2,762 |
| Sat-3/19/22 | 2,771 | 2 | 24.00 | 2 | 2,771 |
| Sun-3/20/22 | 2,796 | 2 | 24.00 | 2 | 2,796 |
| Mon-3/21/22 | 2,787 | 2 | 24.00 | 2 | 2,787 |
| Tue-3/22/22 | 2,819 | 2 | 24.00 | 2 | 2,819 |
| Wed-3/23/22 | 2,830 | 2 | 24.00 | 2 | 2,830 |
| Thu-3/24/22 | 2,827 | 2 | 24.00 | 2 | 2,827 |
| Fri-3/25/22 | 2,721 | 2 | 24.00 | 2 | 2,721 |
| Sat-3/26/22 | 2,513 | 2 | 24.00 | 2 | 2,513 |
| Sun-3/27/22 | 2,461 | 2 | 24.00 | 2 | 2,461 |
| Mon-3/28/22 | 2,468 | 2 | 24.00 | 2 | 2,468 |
| Tue-3/29/22 | 1,107 | 2 | 10.22 | 1 | 1,107 |
| Wed-3/30/22 | - | - | - | - | - |
| Thu-3/31/22 | 123 | 8 | 0.27 | 0 | 123 |
| TOTALS | 85,825 | 2 | 681.47 | 2 | 85,825 |

| | |
|-----------------------------|----------------|
| TOTAL VOLUME EXTRACTED : | 85,825 GALLONS |
| DAYS IN MONTH : | 31 DAYS |
| MONTHLY AVERAGE FLOW RATE : | 1.92 GPM |

3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.
 3/29/22-3/31/22 - PW-1 was shut down for maintenance.

SOUTHWEST AREA EXTRACTION DATA

Month of: Mar-22

| SouthWest Well Extraction | | | | | | | | Daily | Daily |
|---------------------------|---------------|----------|---------------|------------------|-----------|---------------|-------------|------------------|-------|
| Date | TW22 | | | TW28 | | | Flow GPM | Total Gallons | |
| | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | | | |
| Tue-3/1/22 | 3,416 | 2 | 24.00 | 35,861 | 25 | 24.00 | 27 | 39,277 | |
| Wed-3/2/22 | 3,396 | 2 | 24.00 | 35,836 | 25 | 24.00 | 27 | 39,232 | |
| Thu-3/3/22 | 3,388 | 2 | 24.00 | 35,781 | 25 | 24.00 | 27 | 39,169 | |
| Fri-3/4/22 | 3,398 | 2 | 24.00 | 35,783 | 25 | 24.00 | 27 | 39,181 | |
| Sat-3/5/22 | 3,427 | 2 | 24.00 | 35,772 | 25 | 24.00 | 27 | 39,199 | |
| Sun-3/6/22 | 3,410 | 2 | 24.00 | 35,744 | 25 | 24.00 | 27 | 39,154 | |
| Mon-3/7/22 | 3,405 | 2 | 24.00 | 35,762 | 25 | 24.00 | 27 | 39,167 | |
| Tue-3/8/22 | 3,397 | 2 | 24.00 | 35,738 | 25 | 24.00 | 27 | 39,135 | |
| Wed-3/9/22 | 3,404 | 2 | 24.00 | 35,756 | 25 | 24.00 | 27 | 39,160 | |
| Thu-3/10/22 | 3,401 | 2 | 24.00 | 35,734 | 25 | 24.00 | 27 | 39,135 | |
| Fri-3/11/22 | 3,410 | 2 | 24.00 | 35,741 | 25 | 24.00 | 27 | 39,151 | |
| Sat-3/12/22 | 3,400 | 2 | 24.00 | 35,751 | 25 | 24.00 | 27 | 39,151 | |
| Sun-3/13/22 | 3,226 | 2 | 22.98 | 34,783 | 25 | 22.98 | 28 | 38,009 | |
| Mon-3/14/22 | 3,375 | 2 | 24.00 | 36,301 | 25 | 24.00 | 28 | 39,676 | |
| Tue-3/15/22 | 3,366 | 2 | 24.00 | 36,307 | 25 | 24.00 | 28 | 39,673 | |
| Wed-3/16/22 | 2,421 | 2 | 17.22 | 36,148 | 25 | 24.00 | 27 | 38,569 | |
| Thu-3/17/22 | 2,086 | 2 | 16.00 | 36,009 | 25 | 24.00 | 27 | 38,095 | |
| Fri-3/18/22 | 3,191 | 2 | 24.00 | 35,916 | 25 | 24.00 | 27 | 39,107 | |
| Sat-3/19/22 | 3,182 | 2 | 24.00 | 35,867 | 25 | 24.00 | 27 | 39,049 | |
| Sun-3/20/22 | 3,169 | 2 | 24.00 | 35,814 | 25 | 24.00 | 27 | 38,983 | |
| Mon-3/21/22 | 3,167 | 2 | 24.00 | 35,827 | 25 | 24.00 | 27 | 38,994 | |
| Tue-3/22/22 | 3,170 | 2 | 24.00 | 35,821 | 25 | 24.00 | 27 | 38,991 | |
| Wed-3/23/22 | 2,455 | 2 | 18.57 | 27,746 | 25 | 18.57 | 27 | 30,201 | |
| Thu-3/24/22 | 1,707 | 2 | 15.62 | 23,444 | 25 | 15.62 | 27 | 25,151 | |
| Fri-3/25/22 | 2,600 | 2 | 24.00 | 35,950 | 25 | 24.00 | 27 | 38,550 | |
| Sat-3/26/22 | 2,589 | 2 | 24.00 | 35,908 | 25 | 24.00 | 27 | 38,497 | |
| Sun-3/27/22 | 2,586 | 2 | 24.00 | 35,919 | 25 | 24.00 | 27 | 38,505 | |
| Mon-3/28/22 | 2,445 | 2 | 23.93 | 35,912 | 25 | 24.00 | 27 | 38,357 | |
| Tue-3/29/22 | 2,907 | 2 | 24.00 | 36,095 | 25 | 24.00 | 27 | 39,002 | |
| Wed-3/30/22 | 1,039 | 2 | 7.67 | 11,603 | 25 | 7.67 | 27 | 12,642 | |
| Thu-3/31/22 | 1,080 | 2 | 9.48 | 14,299 | 25 | 9.48 | 27 | 15,379 | |
| TOTALS | 90,613 | 2 | 683.47 | 1,044,928 | 25 | 698.32 | 27 | 1,135,541 | |

| | |
|-----------------------------|-------------------|
| TOTAL VOLUME EXTRACTED : | 1,135,541 GALLONS |
| DAYS IN MONTH : | 31 DAYS |
| MONTHLY AVERAGE FLOW RATE : | 25.44 GPM |

3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.
 3/16/22-3/17/22 - TW-22 was shut down due to flows dropping below detectable levels during/after sampling.
 3/23/22-3/24/22 - TW-22 and TW-28 were shut down due to communication loss from Comcast work in the area.
 3/30/22-3/31/22 - TW-22 and TW-28 were shut down for system maintenance.

TABLE #6

UNIT "E" EXTRACTION DATA

Month of: Mar-22

| Date | TW-11 | | | TW-17 | | | TW-18 | | | TW-29 | | | TW-23 | | | Daily Flow GPM | Daily Total Gallons |
|---------------|---------|-----|----------|------------------|-----------|---------------|------------------|------------|---------------|------------------|-----------|---------------|------------------|-----------|---------------|----------------|---------------------|
| | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | Gallons | GPM | Run Hrs. | | |
| Tue-3/1/22 | - | - | - | 76,862 | 53 | 24.00 | 153,782 | 107 | 24.00 | 71,955 | 50 | 24.00 | 72,288 | 50 | 24.00 | 260 | 374,887 |
| Wed-3/2/22 | - | - | - | 79,433 | 55 | 24.00 | 153,794 | 107 | 24.00 | 71,933 | 50 | 24.00 | 72,259 | 50 | 24.00 | 262 | 377,419 |
| Thu-3/3/22 | - | - | - | 79,350 | 55 | 24.00 | 149,171 | 104 | 24.00 | 71,965 | 50 | 24.00 | 72,295 | 50 | 24.00 | 259 | 372,781 |
| Fri-3/4/22 | - | - | - | 79,370 | 55 | 24.00 | 146,539 | 102 | 24.00 | 71,989 | 50 | 24.00 | 72,289 | 50 | 24.00 | 257 | 370,187 |
| Sat-3/5/22 | - | - | - | 79,430 | 55 | 24.00 | 147,731 | 103 | 24.00 | 71,950 | 50 | 24.00 | 72,311 | 50 | 24.00 | 258 | 371,422 |
| Sun-3/6/22 | - | - | - | 79,452 | 55 | 24.00 | 159,518 | 112 | 23.77 | 71,784 | 50 | 24.00 | 72,265 | 50 | 24.00 | 266 | 383,019 |
| Mon-3/7/22 | - | - | - | - | 0 | 0.02 | 156,240 | 109 | 24.00 | 71,970 | 50 | 24.00 | 72,246 | 50 | 24.00 | 209 | 300,456 |
| Tue-3/8/22 | - | - | - | 91,207 | 63 | 24.00 | 153,784 | 107 | 24.00 | 71,977 | 50 | 24.00 | 72,363 | 50 | 24.00 | 270 | 389,331 |
| Wed-3/9/22 | - | - | - | 93,822 | 65 | 24.00 | 149,298 | 104 | 24.00 | 71,953 | 50 | 24.00 | 72,250 | 50 | 24.00 | 269 | 387,323 |
| Thu-3/10/22 | - | - | - | 93,738 | 65 | 24.00 | 146,495 | 102 | 24.00 | 71,886 | 50 | 24.00 | 72,189 | 50 | 24.00 | 267 | 384,308 |
| Fri-3/11/22 | - | - | - | 93,702 | 65 | 24.00 | 146,511 | 102 | 24.00 | 71,878 | 50 | 24.00 | 72,236 | 50 | 24.00 | 267 | 384,327 |
| Sat-3/12/22 | - | - | - | 93,643 | 65 | 24.00 | 146,533 | 102 | 24.00 | 71,895 | 50 | 24.00 | 72,234 | 50 | 24.00 | 267 | 384,305 |
| Sun-3/13/22 | - | - | - | 89,749 | 65 | 23.00 | 140,453 | 102 | 22.98 | 68,861 | 50 | 22.98 | 69,197 | 50 | 22.98 | 256 | 368,260 |
| Mon-3/14/22 | - | - | - | 93,724 | 65 | 24.00 | 146,579 | 102 | 24.00 | 71,818 | 50 | 24.00 | 72,342 | 50 | 24.00 | 267 | 384,463 |
| Tue-3/15/22 | - | - | - | 93,743 | 65 | 24.00 | 146,589 | 102 | 24.00 | 72,070 | 50 | 24.00 | 72,359 | 50 | 24.00 | 267 | 384,761 |
| Wed-3/16/22 | - | - | - | 93,809 | 65 | 24.00 | 146,598 | 102 | 24.00 | 71,100 | 50 | 23.73 | 29,883 | 50 | 9.90 | 237 | 341,390 |
| Thu-3/17/22 | - | - | - | 98,477 | 68 | 24.00 | 146,644 | 102 | 24.00 | 71,936 | 50 | 24.00 | 48,133 | 50 | 16.00 | 254 | 365,190 |
| Fri-3/18/22 | - | - | - | 93,808 | 65 | 24.00 | 146,596 | 102 | 24.00 | 71,985 | 50 | 24.00 | 72,178 | 50 | 24.00 | 267 | 384,567 |
| Sat-3/19/22 | - | - | - | 93,678 | 65 | 24.00 | 146,558 | 102 | 24.00 | 72,033 | 50 | 24.00 | 72,207 | 50 | 24.00 | 267 | 384,476 |
| Sun-3/20/22 | - | - | - | 93,713 | 65 | 24.00 | 146,561 | 102 | 24.00 | 71,979 | 50 | 24.00 | 72,184 | 50 | 24.00 | 267 | 384,437 |
| Mon-3/21/22 | - | - | - | 93,742 | 65 | 24.00 | 146,604 | 102 | 24.00 | 71,889 | 50 | 24.00 | 72,245 | 50 | 24.00 | 267 | 384,480 |
| Tue-3/22/22 | - | - | - | 93,672 | 65 | 24.00 | 146,563 | 102 | 24.00 | 72,083 | 50 | 24.00 | 72,236 | 50 | 24.00 | 267 | 384,554 |
| Wed-3/23/22 | - | - | - | 93,678 | 65 | 24.00 | 146,568 | 102 | 24.00 | 72,022 | 50 | 24.00 | 72,267 | 50 | 24.00 | 267 | 384,535 |
| Thu-3/24/22 | - | - | - | 93,699 | 65 | 24.00 | 146,575 | 102 | 24.00 | 71,909 | 50 | 24.00 | 72,234 | 50 | 24.00 | 267 | 384,417 |
| Fri-3/25/22 | - | - | - | 93,692 | 65 | 24.00 | 146,572 | 102 | 24.00 | 71,880 | 50 | 24.00 | 72,223 | 50 | 24.00 | 267 | 384,367 |
| Sat-3/26/22 | - | - | - | 93,649 | 65 | 24.00 | 146,543 | 102 | 24.00 | 71,880 | 50 | 24.00 | 72,267 | 50 | 24.00 | 267 | 384,339 |
| Sun-3/27/22 | - | - | - | 93,791 | 65 | 24.00 | 146,514 | 102 | 24.00 | 71,772 | 50 | 24.00 | 72,221 | 50 | 24.00 | 267 | 384,298 |
| Mon-3/28/22 | - | - | - | 93,710 | 65 | 24.00 | 146,530 | 102 | 24.00 | 71,870 | 50 | 24.00 | 72,250 | 50 | 24.00 | 267 | 384,360 |
| Tue-3/29/22 | - | - | - | 93,696 | 65 | 24.00 | 146,535 | 102 | 24.00 | 71,870 | 50 | 24.00 | 72,253 | 50 | 24.00 | 267 | 384,354 |
| Wed-3/30/22 | - | - | - | 29,981 | 65 | 7.68 | 46,974 | 102 | 7.70 | 23,047 | 50 | 7.68 | 23,178 | 50 | 7.68 | 86 | 123,180 |
| Thu-3/31/22 | - | - | - | 37,158 | 65 | 9.50 | 58,023 | 102 | 9.50 | 27,930 | 50 | 9.30 | 27,908 | 50 | 9.26 | 105 | 151,019 |
| TOTALS | - | - | - | 2,601,178 | 61 | 688.20 | 4,399,975 | 103 | 711.95 | 2,133,069 | 50 | 711.69 | 2,076,990 | 50 | 689.82 | 251 | 11,211,212 |

| | |
|-----------------------------|--------------------|
| TOTAL VOLUME EXTRACTED : | 11,211,212 GALLONS |
| DAYS IN MONTH : | 31 DAYS |
| MONTHLY AVERAGE FLOW RATE : | 251.15 GPM |

3/7/22 - TW-17 was shut down during work at TW-25.
 3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.
 3/16/22-3/17/22 - TW-23 was shut down due to flows dropping below detectable levels during/after sampling
 3/30/22-3/31/22 - TW-17, TW-18, TW-29, and TW-23 were shut down for system maintenance.

TABLE #7

Little Lake Area System

| MW-53i | |
|----------|------------------|
| Date | 1,4-Dioxane ug/L |
| 12/01/21 | 40 |
| 01/12/22 | 54 |
| 02/10/22 | 43 |
| 03/14/22 | 39 |

TABLE #8

INDIVIDUAL PURGE WELL CONCENTRATIONS

| SAMPLE ID | Date Sampled | 1,4-DIOXANE (ppb) |
|------------------------|---------------------|--------------------------|
| DOLPH-03-16-22-11:25-1 | 03/16/22 | 150 |
| TW-10-03-16-22-11:00-1 | 03/16/22 | 910 |
| TW-14-03-16-22-10:35-1 | 03/16/22 | 130 |
| TW-20-03-16-22-11:15-1 | 03/16/22 | 750 |
| TW-24-03-16-22-11:30-1 | 03/16/22 | 2500 |
| LB-4-03-16-22-09:50-1 | 03/16/22 | 490 |
| TW-21-03-16-22-12:00-1 | 03/16/22 | 280 |
| TW-17-03-16-22-10:40-1 | 03/16/22 | 54 |
| TW-18-03-16-22-12:10-1 | 03/16/22 | 260 |
| TW-23-03-16-22-09:55-1 | 03/16/22 | 410 |
| TW-29-03-16-22-10:10-1 | 03/16/22 | 440 |
| PW-1-03-16-22-11:20-1 | 03/16/22 | 1000 |
| TW-22-03-16-22-11:05-1 | 03/16/22 | 500 |
| TW-28-03-16-22-11:10-1 | 03/16/22 | 680 |

RED POND DATA

Month of: Mar-22

| Date | Time | Notes | Red Pond | | | | |
|---------------|--------------|-------|------------|-------|----------|----------|----------|
| | | | Pond | Level | Aeration | Influent | Influent |
| | | | Visual Chk | Feet | Hours | Hours | GPM |
| Tue-3/1/22 | 04:00:00.000 | | Y | 4.7 | - | 24.00 | 626 |
| Wed-3/2/22 | 04:00:00.000 | | Y | 4.7 | - | 24.00 | 627 |
| Thu-3/3/22 | 04:00:00.000 | | Y | 4.5 | - | 24.00 | 615 |
| Fri-3/4/22 | 04:00:00.000 | | Y | 4.3 | - | 24.00 | 611 |
| Sat-3/5/22 | 04:00:00.000 | (1) | | 4.1 | - | 24.00 | 619 |
| Sun-3/6/22 | 04:00:00.000 | (1) | | 4.2 | - | 24.00 | 631 |
| Mon-3/7/22 | 04:00:00.000 | | Y | 4.3 | - | 24.00 | 542 |
| Tue-3/8/22 | 04:00:00.000 | | Y | 4.3 | - | 24.00 | 625 |
| Wed-3/9/22 | 04:00:00.000 | | Y | 4.4 | - | 24.00 | 624 |
| Thu-3/10/22 | 04:00:00.000 | | Y | 4.6 | - | 24.00 | 623 |
| Fri-3/11/22 | 04:00:00.000 | | Y | 4.6 | - | 24.00 | 623 |
| Sat-3/12/22 | 04:00:00.000 | (1) | | 4.6 | - | 24.00 | 623 |
| Sun-3/13/22 | 04:00:00.000 | (1) | | 4.5 | - | 23.00 | 623 |
| Mon-3/14/22 | 04:00:00.000 | | Y | 4.5 | - | 24.00 | 623 |
| Tue-3/15/22 | 04:00:00.000 | | Y | 4.4 | - | 24.00 | 623 |
| Wed-3/16/22 | 04:00:00.000 | | Y | 3.8 | - | 24.00 | 592 |
| Thu-3/17/22 | 04:00:00.000 | | Y | 3.9 | - | 24.00 | 629 |
| Fri-3/18/22 | 04:00:00.000 | | Y | 4.0 | - | 24.00 | 628 |
| Sat-3/19/22 | 04:00:00.000 | (1) | | 4.2 | - | 24.00 | 628 |
| Sun-3/20/22 | 04:00:00.000 | (1) | | 4.2 | - | 24.00 | 628 |
| Mon-3/21/22 | 04:00:00.000 | | Y | 4.3 | - | 24.00 | 628 |
| Tue-3/22/22 | 04:00:00.000 | | Y | 4.3 | - | 24.00 | 628 |
| Wed-3/23/22 | 04:00:00.000 | | Y | 4.3 | - | 24.00 | 622 |
| Thu-3/24/22 | 04:00:00.000 | | Y | 3.8 | - | 24.00 | 618 |
| Fri-3/25/22 | 04:00:00.000 | | Y | 5.6 | - | 24.00 | 585 |
| Sat-3/26/22 | 04:00:00.000 | (1) | | 5.4 | - | 24.00 | 564 |
| Sun-3/27/22 | 04:00:00.000 | (1) | | 4.7 | - | 24.00 | 564 |
| Mon-3/28/22 | 04:00:00.000 | | Y | 4.4 | - | 24.00 | 588 |
| Tue-3/29/22 | 04:00:00.000 | | Y | 4.6 | - | 24.00 | 623 |
| Wed-3/30/22 | 04:00:00.000 | | Y | 4.7 | - | 24.00 | 211 |
| Thu-3/31/22 | 04:00:00.000 | | Y | 4.8 | - | 15.62 | 388 |
| TOTALS | | | - | - | - | 735 | |

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

TABLE #10

RED POND CONCENTRATIONS

| SAMPLE ID | Date Sampled | 1,4-DIOXANE (ppb) |
|---------------------------|--------------|-------------------|
| Red Pond-03-01-22-07:30-1 | 3/1/2022 | 460 |
| Red Pond-03-02-22-07:25-1 | 3/2/2022 | 440 |
| Red Pond-03-03-22-07:35-1 | 3/3/2022 | 440 |
| Red Pond-03-04-22-07:35- | 3/4/2022 | 520 |
| Red Pond-03-07-22-07:30-1 | 3/7/2022 | 460 |
| Red Pond-03-08-22-07:45-1 | 3/8/2022 | 510 |
| Red Pond-03-09-22-07:55-1 | 3/9/2022 | 440 |
| Red Pond-03-10-22-07:30-1 | 3/10/2022 | 430 |
| Red Pond-03-11-22-07:20-1 | 3/11/2022 | 440 |
| Red Pond-03-14-22-07:45-1 | 3/14/2022 | 430 |
| Red Pond-03-15-22-07:10-1 | 3/15/2022 | 460 |
| Red Pond-03-16-22-07:35-1 | 3/16/2022 | 420 |
| Red Pond-03-17-22-07:35-1 | 3/17/2022 | 470 |
| Red Pond-03-18-22-07:00-1 | 3/18/2022 | 470 |
| Red Pond-03-21-22-07:15-1 | 3/21/2022 | 440 |
| Red Pond-03-22-22-07:35-1 | 3/22/2022 | 440 |
| Red Pond-03-23-22-07:40-1 | 3/23/2022 | 460 |
| Red Pond-03-24-22-07:00-1 | 3/24/2022 | 420 |
| Red Pond-03-28-22-07:05-1 | 3/28/2022 | 420 |
| Red Pond-03-29-22-07:00-1 | 3/29/2022 | 430 |
| Red Pond-03-30-22-06:30-1 | 3/30/2022 | 370 |
| Red Pond-03-31-22-15:25-1 | 3/31/2022 | 520 |

Analyte value quantified from a dilution, reporting limit is raised to reflect dilution

OZONE OPERATION REPORT

Month of: Mar-22

| Date | Time | Notes | SYSTEM-1A | | SYSTEM-1B | | SYSTEM-2A | | SYSTEM-2B | |
|-------------|--------------|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | Flow GPM | Run Hours | Flow GPM | Run Hours | Flow GPM | Run Hours | Flow GPM | Run Hours |
| Tue-3/1/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Wed-3/2/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Thu-3/3/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Fri-3/4/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 381 | 24.00 | 0 | 0.00 |
| Sat-3/5/22 | 04:00:00.000 | (1) | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Sun-3/6/22 | 04:00:00.000 | (1) | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Mon-3/7/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Tue-3/8/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 379 | 24.00 | 0 | 0.00 |
| Wed-3/9/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Thu-3/10/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 379 | 24.00 | 0 | 0.00 |
| Fri-3/11/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Sat-3/12/22 | 04:00:00.000 | (1) | 241 | 24.00 | 0 | 0.00 | 379 | 24.00 | 0 | 0.00 |
| Sun-3/13/22 | 04:00:00.000 | (1) | 241 | 22.98 | 0 | 0.00 | 380 | 22.98 | 0 | 0.00 |
| Mon-3/14/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Tue-3/15/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Wed-3/16/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Thu-3/17/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Fri-3/18/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 379 | 24.00 | 0 | 0.00 |
| Sat-3/19/22 | 04:00:00.000 | (1) | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Sun-3/20/22 | 04:00:00.000 | (1) | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Mon-3/21/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Tue-3/22/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 381 | 24.00 | 0 | 0.00 |
| Wed-3/23/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 379 | 24.00 | 0 | 0.00 |
| Thu-3/24/22 | 04:00:00.000 | | 240 | 24.00 | 0 | 0.00 | 380 | 23.72 | 0 | 0.00 |
| Fri-3/25/22 | 04:00:00.000 | | 240 | 17.93 | 0 | 0.00 | 380 | 19.48 | 0 | 0.00 |
| Sat-3/26/22 | 04:00:00.000 | (1) | 240 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Sun-3/27/22 | 04:00:00.000 | (1) | 240 | 23.13 | 0 | 0.00 | 379 | 22.60 | 0 | 0.00 |
| Mon-3/28/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 380 | 24.00 | 0 | 0.00 |
| Tue-3/29/22 | 04:00:00.000 | | 241 | 24.00 | 0 | 0.00 | 381 | 22.98 | 0 | 0.00 |
| Wed-3/30/22 | 04:00:00.000 | | 240 | 7.50 | 0 | 0.00 | 380 | 6.47 | 0 | 0.00 |
| Thu-3/31/22 | 04:00:00.000 | | 241 | 9.25 | 0 | 0.00 | 380 | 10.57 | 0 | 0.00 |

Daily readings are collected by the Operator at various times of the day, resulting in varied readings and calculations.

(1) Manual readings were not taken due to weekend and/or holiday.

3/13/22 - Due to the start of daylight savings, the maximum run time on this date is 23 hours.

3/25/22 - Treatment was shut down due to power failure and associated repairs.

3/27/22 - Treatment System 2A was shut down briefly due to a VFD fault.

3/29/22 - Treatment System 2A was shut down briefly due to a VFD fault.

3/30/22-3/31/22 - Treatment was shut down for system maintenance.

