

ADULT FOSTER & CARE FACILITY SAMPLING RESULTS REPORT



INTRODUCTION

During the months of November and December 2017, the Department of Licensing and Regulatory Affairs (DLARA) flushed the plumbing lines at each of the Flint care facilities to prepare for sampling by the Department of Environmental Quality (DEQ). The dates of flushing and sampling for each facility is listed below:

Facility Name	Flushing Date	Sampling Date
Clifford St. Adult Foster Care (AFC)	12/1 *	12/2
Flatrock Manor of Flint, LLC	11/24*	11/25
Genesee Regional Crisis Residential	11/24*	11/25
Harmony Manor Avon Street	11/19*	11/20
Harmony Manor Court Street	11/19*	11/20
Heartland Health Care	11/16	11/17
JJS AFC	11/16*	11/17
McFarlan Home	11/16	11/17
New Beginnings	11/19	11/20
New Hope Behavioral	11/19	11/20
Paige AFC	11/24*	11/25
Thorn AFC	11/24*	11/25
Transitional Living	12/8*	12/09
Washington AFC	12/1*	12/2
Whaley Kiwanis House	11/17*	11/18
Whaley Optimist House	11/17*	11/18
Whaley Rotary House	11/17*	11/18
Whaley Zonta House	11/17*	11/18
Women's Center of Flint	11/30*	12/1

* Flushed by Facility Maintenance Staff

SAMPLING METHOD

Each operational drinking water fixture at the facility was identified and sampled. One 250 ml sample was collected at each of the fixtures identified.

RESULTS AND NOTES

When reviewing the lab sample results, the sample description will contain letters to indicate the fixture type. Specifically, kitchen sinks have "KC" in the name, restroom sinks are noted "BF," and Nurses Stations are "NS." Samples from these fixtures are non-filtered water, unless noted in sample notes. Alternatively, water coolers are noted "WC" and drinking water bubblers are noted "DW". Both water coolers and bubblers have inline filters installed, so the samples are of filtered water, unless otherwise noted. Not Detected (ND) means; for lead the amount in water is less than 1 parts per billion (ppb), and for copper the amount in water is less than 50 ppb.

Sample results can be found online at www.michigan.gov/flintwater, select "Testing Results" and "Establishment Testing."

Clifford St. AFC

December 2, 2017

Of the four (4) samples:

- All samples were ND for lead. Lead Range: ND to ND
- No sample exceeded 1,300 ppb for copper. Copper Range: ND to 140 ppb

Flatrock Manor of Flint, LLC.

November 25, 2017

Of the five (5) samples:

- No samples exceeded 15 ppb for lead.
Lead Range: ND to 2 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to ND

Genesee Regional Crisis Residential Unit

November 25, 2017

Of the ten (10) samples:

- No sample exceeded 15 ppb for lead.
Lead Range: ND to 1 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 120 ppb

Harmony Manor Avon Street

November 20, 2017

Of the four (4) samples:

- No samples exceeded 15 ppb for lead.
Lead Range: ND to 2 ppb
- All samples were ND for copper.
Copper Range: ND to ND

Harmony Manor Court Street

November 20, 2017

Of the five (5) samples:

- All samples were ND for lead
Lead Range: ND to ND
- All samples were ND for copper.
Copper Range: ND to ND

Heartland Health Care

November 17, 2017

Of the sixty-one (61) samples:

- One sample exceeded 15 ppb for lead.
Lead Range: ND to 19 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 260 ppb

Field Notes:

The exceedance was fixture 01BF018 in Room 209-211.

JJS AFC

November 17, 2017

Of the eight (8) samples:

- All samples were ND for lead
Lead Range: ND to ND
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 50 ppb

McFarlan Home

November 17, 2017

Of the fifty (50) samples:

- No sample exceeded 15 ppb for lead.
Lead Range: ND to 7 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 180 ppb

New Beginnings

November 20, 2017

Of the nine (9) samples:

- One sample exceeded 15 ppb for lead.
Lead Range: ND to 25 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 160 ppb

Field Notes:

The exceedance was fixture 03BF008 on the 3rd Floor. During sampling, facility staff mentioned that the 3rd floor is vacant.

New Hope Behavioral

December 20, 2017

Of the thirty-one (31) samples:

- No sample exceeded 15 ppb for lead.
Lead Range: ND to 1 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 200 ppb

Paige AFC

November 25, 2017

Of the four (4) samples:

- All samples were ND for lead.
Lead Range: ND to ND
- All samples were ND for copper.
Copper Range: ND to ND

Thorn AFC

November 25, 2017

Of the four (4) samples:

- All samples were ND
Lead Range: ND to ND
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 60 ppb

Transitional Living

December 9, 2017

Of the six (6) samples:

- No sample exceeded 15 ppb for lead.
Lead Range: ND to 11 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 80 ppb

Washington AFC

December 2, 2017

Of the four (4) samples:

- All samples were ND for lead.
Lead Range: ND to ND
- All samples were ND for copper.
Copper Range: ND to ND

Whaley Kiwanis House

November 18, 2017

Of the three (3) samples:

- All samples were ND for lead.
Lead Range: ND to ND
- All samples were ND for copper.
Copper Range: ND to ND

Whaley Optimist House

November 18, 2017

Of the three (3) samples:

- All samples were ND for lead.
Lead Range: ND to ND
- All samples were ND for copper.
Copper Range: ND to ND

Whaley Rotary House

November 18, 2017

Of the three (3) samples:

- No sample exceeded 15 ppb for lead.
Lead Range: ND to 11 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 600 ppb

Whaley Zonta House

November 18, 2017

Of the four (4) samples:

- No sample exceeded 15 ppb for lead.
Lead Range: ND to 2 ppb
- No sample exceeded 1,300 ppb for copper.
Copper Range: ND to 60 ppb

Women's Center of Flint

December 1, 2017

Of the one (1) sample:

- The sample was ND for lead.
- The sample was 90 ppb for copper.