

Flint Community Schools
Round 3, Week 2
3/9/18

| Sample Number | Lead | Lead (PPB) | Sample Description | Site Code | Copper | Copper (PPB) | Street Name | City | Zip | School | Comments |
|---------------|----------|------------|-----------------------|-----------|------------|--------------|----------------|-------|-------|-----------------------|--|
| LH69766 | Lead 250 | 0 | CF003 ROOM 15 | PRE | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69780 | Lead 250 | 3 | CF003 ROOM 15 | 351 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69794 | Lead 250 | 0 | CF003 ROOM 15 | 352 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69767 | Lead 250 | 3 | CF004 ROOM 17 | PRE | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | No filter unit present, Science lab faucet |
| LH69781 | Lead 250 | 2 | CF004 ROOM 17 | 351 | Copper 250 | 120 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Water was hot |
| LH69795 | Lead 250 | 2 | CF004 ROOM 17 | 352 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Water was hot |
| LH69768 | Lead 250 | 26 | CF005 ROOM 17 | PRE | Copper 250 | 90 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Science lab-warm, discolored water |
| LH69782 | Lead 250 | 30 | CF005 ROOM 17 | 351 | Copper 250 | 180 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Faucet was not replaced |
| LH69796 | Lead 250 | 5 | CF005 ROOM 17 | 352 | Copper 250 | 70 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69769 | Lead 250 | 6 | CF006 ROOM 26 LIBRARY | PRE | Copper 250 | 250 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69783 | Lead 250 | 1 | CF006 ROOM 26 LIBRARY | 351 | Copper 250 | 110 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Low flow |
| LH69797 | Lead 250 | 0 | CF006 ROOM 26 LIBRARY | 352 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Low flow |
| LH69798 | Lead 250 | 0 | CF007 ROOM 026 | 352 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Low flow |
| LH69770 | Lead 250 | 5 | CF007 ROOM 26 LIBRARY | PRE | Copper 250 | 280 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69784 | Lead 250 | 0 | CF007 ROOM 26 LIBRARY | 351 | Copper 250 | 110 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69771 | Lead 250 | 0 | CF010 ROOM 27 LOUNGE | PRE | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69785 | Lead 250 | 0 | CF010 ROOM 27 LOUNGE | 351 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69799 | Lead 250 | 0 | CF010 ROOM 27 LOUNGE | 352 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69772 | Lead 250 | 0 | CF012 COMMUNITY ROOM | PRE | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69786 | Lead 250 | 87 | CF012 COMMUNITY ROOM | 351 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69800 | Lead 250 | 7 | CF012 COMMUNITY ROOM | 352 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69776 | Lead 250 | 1 | CF018 ROOM 4 RESTROOM | PRE | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Hand washing sink only, no filter unit present |
| LH69790 | Lead 250 | 0 | CF018 ROOM 4 RESTROOM | 351 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69804 | Lead 250 | 0 | CF018 ROOM 4 RESTROOM | 352 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Hand washing sink only |
| LH69778 | Lead 250 | 1 | CF022 ROOM 6 | PRE | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69792 | Lead 250 | 2 | CF022 ROOM 6 | 351 | Copper 250 | 50 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69806 | Lead 250 | 3 | CF022 ROOM 6 | 352 | Copper 250 | 0 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69779 | Lead 250 | 2 | CF023 ROOM 7 | PRE | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69793 | Lead 250 | 2 | CF023 ROOM 7 | 351 | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69807 | Lead 250 | 1 | CF023 ROOM 7 | 352 | Copper 250 | 50 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69773 | Lead 250 | 0 | KC015 ROOM 1 | PRE | Copper 250 | 160 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69787 | Lead 250 | 1 | KC015 ROOM 1 | 351 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69801 | Lead 250 | 0 | KC015 ROOM 1 | 352 | Copper 250 | 90 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69774 | Lead 250 | 0 | KC016 ROOM 1 | PRE | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69788 | Lead 250 | 0 | KC016 ROOM 1 | 351 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69802 | Lead 250 | 1 | KC016 ROOM 1 | 352 | Copper 250 | 100 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69775 | Lead 250 | 0 | KC017 ROOM 2 | PRE | Copper 250 | 110 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69789 | Lead 250 | 0 | KC017 ROOM 2 | 351 | Copper 250 | 80 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69803 | Lead 250 | 0 | KC017 ROOM 2 | 352 | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69777 | Lead 250 | 0 | KC019 ROOM 4 | PRE | Copper 250 | 50 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | |
| LH69791 | Lead 250 | 2 | KC019 ROOM 4 | 351 | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Urinal on constant flow |
| LH69805 | Lead 250 | 0 | KC019 ROOM 4 | 352 | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | BROWNELL STEM ACADEMY | Urinal on constant flow |
| LH69862 | Lead 250 | 0 | 01CF001 ROOM 159 | PRE | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69883 | Lead 250 | 1 | 01CF001 ROOM 159 | 351 | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69904 | Lead 250 | 0 | 01CF001 ROOM 159 | 352 | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69863 | Lead 250 | 0 | 01CF003 ROOM 160 | PRE | Copper 250 | 90 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69884 | Lead 250 | 0 | 01CF003 ROOM 160 | 351 | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69905 | Lead 250 | 0 | 01CF003 ROOM 160 | 352 | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69866 | Lead 250 | 0 | 01CF008 ROOM 156 | PRE | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69887 | Lead 250 | 0 | 01CF008 ROOM 156 | 351 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69908 | Lead 250 | 0 | 01CF008 ROOM 156 | 352 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69868 | Lead 250 | 2 | 01CF009 ROOM 154 | PRE | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69889 | Lead 250 | 155 | 01CF009 ROOM 154 | 351 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69910 | Lead 250 | 2 | 01CF009 ROOM 154 | 352 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69869 | Lead 250 | 2 | 01CF012 ROOM 153 | PRE | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69890 | Lead 250 | 8 | 01CF012 ROOM 153 | 351 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69911 | Lead 250 | 2 | 01CF012 ROOM 153 | 352 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69874 | Lead 250 | 22 | 01CF014 ROOM 152 | PRE | Copper 250 | 110 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69895 | Lead 250 | 4 | 01CF014 ROOM 152 | 351 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | Low flow |
| LH69916 | Lead 250 | 6 | 01CF014 ROOM 152 | 352 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | Low flow |

Flint Community Schools
Round 3, Week 2
3/9/18

| Sample Number | Lead | Lead (PPB) | Sample Description | Site Code | Copper | Copper (PPB) | Street Name | City | Zip | School | Comments |
|---------------|----------|------------|--------------------------|-----------|------------|--------------|----------------|-------|-------|---------------------|--|
| LH69875 | Lead 250 | 1 | 01CF016 ROOM 151 | PRE | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69896 | Lead 250 | 10 | 01CF016 ROOM 151 | 351 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69917 | Lead 250 | 22 | 01CF016 ROOM 151 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69888 | Lead 250 | 1 | 01CF018 ROOM 155 | 351 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69909 | Lead 250 | 0 | 01CF018 ROOM 155 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69867 | Lead 250 | 0 | 01CF019 ROOM 155 | PRE | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69880 | Lead 250 | 0 | 01KC048 ROOM 110 | PRE | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69901 | Lead 250 | 0 | 01KC048 ROOM 110 | 351 | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69922 | Lead 250 | 0 | 01KC048 ROOM 110 | 352 | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69907 | Lead 250 | 0 | 02CF021 ROOM 257 | 352 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69864 | Lead 250 | 2 | 02CF019 ROOM 258 | PRE | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69885 | Lead 250 | 4 | 02CF019 ROOM 258 | 351 | Copper 250 | 90 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69906 | Lead 250 | 2 | 02CF019 ROOM 258 | 352 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69865 | Lead 250 | 0 | 02CF021 ROOM 257 | PRE | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69886 | Lead 250 | 1 | 02CF021 ROOM 257 | 351 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69881 | Lead 250 | 1 | 02CF024 ROOM 256 | PRE | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69902 | Lead 250 | 2 | 02CF024 ROOM 256 | 351 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69923 | Lead 250 | 1 | 02CF024 ROOM 256 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69882 | Lead 250 | 0 | 02CF026 ROOM 259 | PRE | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69903 | Lead 250 | 0 | 02CF026 ROOM 259 | 351 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69924 | Lead 250 | 0 | 02CF026 ROOM 259 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69870 | Lead 250 | 2 | 02CF030 ROOM 254 | PRE | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69891 | Lead 250 | 2 | 02CF030 ROOM 254 | 351 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69912 | Lead 250 | 1 | 02CF030 ROOM 254 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69871 | Lead 250 | 3 | 02CF032 ROOM 253 | PRE | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69892 | Lead 250 | 4 | 02CF032 ROOM 253 | 351 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69913 | Lead 250 | 4 | 02CF032 ROOM 253 | 352 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69872 | Lead 250 | 1 | 02CF034 ROOM 252 | PRE | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69893 | Lead 250 | 2 | 02CF034 ROOM 252 | 351 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69914 | Lead 250 | 1 | 02CF034 ROOM 252 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69873 | Lead 250 | 0 | 02CF036 ROOM 251 | PRE | Copper 250 | 0 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69894 | Lead 250 | 3 | 02CF036 ROOM 251 | 351 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69915 | Lead 250 | 0 | 02CF036 ROOM 251 | 352 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69876 | Lead 250 | 105 | 02CF039 ROOM 260 | PRE | Copper 250 | 140 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69897 | Lead 250 | 4 | 02CF039 ROOM 260 | 351 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69918 | Lead 250 | 8 | 02CF039 ROOM 260 | 352 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69877 | Lead 250 | 32 | 02CF041 ROOM 262 | PRE | Copper 250 | 100 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69898 | Lead 250 | 9 | 02CF041 ROOM 262 | 351 | Copper 250 | 50 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69919 | Lead 250 | 126 | 02CF041 ROOM 262 | 352 | Copper 250 | 70 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69878 | Lead 250 | 10 | 02KC052 TEACHER'S LOUNGE | PRE | Copper 250 | 160 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69899 | Lead 250 | 2 | 02KC052 TEACHER'S LOUNGE | 351 | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69920 | Lead 250 | 2 | 02KC052 TEACHER'S LOUNGE | 352 | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | |
| LH69879 | Lead 250 | 0 | 03KC055 KITCHEN | PRE | Copper 250 | 80 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | Hand washing sink only, no filter unit present |
| LH69900 | Lead 250 | 0 | 03KC055 KITCHEN | 351 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | Hand washing sink only |
| LH69921 | Lead 250 | 0 | 03KC055 KITCHEN | 352 | Copper 250 | 60 | SAGINAW STREET | FLINT | 48503 | DOYLE RYDER SCHOOL | Hand washing sink only, no filter unit present |
| LH69709 | Lead 250 | 0 | 01CF013 ROOM B110 | PRE | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69728 | Lead 250 | 0 | 01CF013 ROOM B110 | 351 | Copper 250 | 100 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69747 | Lead 250 | 0 | 01CF013 ROOM B110 | 352 | Copper 250 | 120 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69712 | Lead 250 | 0 | 01CF015 ROOM B109 | PRE | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69731 | Lead 250 | 0 | 01CF015 ROOM B109 | 351 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69750 | Lead 250 | 0 | 01CF015 ROOM B109 | 352 | Copper 250 | 170 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69715 | Lead 250 | 0 | 01CF020 ROOM B102 | PRE | Copper 250 | 170 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69734 | Lead 250 | 0 | 01CF020 ROOM B102 | 351 | Copper 250 | 120 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69753 | Lead 250 | 0 | 01CF020 ROOM B102 | 352 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69718 | Lead 250 | 0 | 01CF024 ROOM B105 | PRE | Copper 250 | 160 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69737 | Lead 250 | 0 | 01CF024 ROOM B105 | 351 | Copper 250 | 110 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69756 | Lead 250 | 0 | 01CF024 ROOM B105 | 352 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69721 | Lead 250 | 0 | 01CF028 ROOM B114 | PRE | Copper 250 | 70 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | Sink overflowed, unable to complete flush |
| LH69740 | Lead 250 | 0 | 01CF028 ROOM B114 | 351 | Copper 250 | 80 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69759 | Lead 250 | 36 | 01CF028 ROOM B114 | 352 | Copper 250 | 80 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |

Flint Community Schools
Round 3, Week 2
3/9/18

| Sample Number | Lead | Lead (PPB) | Sample Description | Site Code | Copper | Copper (PPB) | Street Name | City | Zip | School | Comments |
|---------------|----------|------------|------------------------|-----------|------------|--------------|----------------|-------|-------|---------------------|-------------------|
| LH69724 | Lead 250 | 3 | 01CF032 COMMUNITY ROOM | PRE | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69743 | Lead 250 | 2 | 01CF032 COMMUNITY ROOM | 351 | Copper 250 | 100 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69762 | Lead 250 | 2 | 01CF032 COMMUNITY ROOM | 352 | Copper 250 | 70 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69710 | Lead 250 | 0 | 01KC010 ROOM B110 | PRE | Copper 250 | 190 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69729 | Lead 250 | 0 | 01KC010 ROOM B110 | 351 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69748 | Lead 250 | 0 | 01KC010 ROOM B110 | 352 | Copper 250 | 160 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69711 | Lead 250 | 0 | 01KC011 ROOM B110 | PRE | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69730 | Lead 250 | 0 | 01KC011 ROOM B110 | 351 | Copper 250 | 120 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69749 | Lead 250 | 0 | 01KC011 ROOM B110 | 352 | Copper 250 | 160 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69713 | Lead 250 | 0 | 01KC016 ROOM B109 | PRE | Copper 250 | 220 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69732 | Lead 250 | 0 | 01KC016 ROOM B109 | 351 | Copper 250 | 230 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69751 | Lead 250 | 0 | 01KC016 ROOM B109 | 352 | Copper 250 | 220 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69714 | Lead 250 | 0 | 01KC017 ROOM B109 | PRE | Copper 250 | 220 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69733 | Lead 250 | 0 | 01KC017 ROOM B109 | 351 | Copper 250 | 220 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69752 | Lead 250 | 0 | 01KC017 ROOM B109 | 352 | Copper 250 | 210 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69716 | Lead 250 | 0 | 01KC021 ROOM B102 | PRE | Copper 250 | 210 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69735 | Lead 250 | 0 | 01KC021 ROOM B102 | 351 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69754 | Lead 250 | 0 | 01KC021 ROOM B102 | 352 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69717 | Lead 250 | 0 | 01KC022 ROOM B102 | PRE | Copper 250 | 200 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69736 | Lead 250 | 0 | 01KC022 ROOM B102 | 351 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69755 | Lead 250 | 0 | 01KC022 ROOM B102 | 352 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69719 | Lead 250 | 0 | 01KC025 ROOM B105 | PRE | Copper 250 | 230 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69738 | Lead 250 | 0 | 01KC025 ROOM B105 | 351 | Copper 250 | 190 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69757 | Lead 250 | 0 | 01KC025 ROOM B105 | 352 | Copper 250 | 180 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69720 | Lead 250 | 0 | 01KC026 ROOM B105 | PRE | Copper 250 | 230 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69739 | Lead 250 | 0 | 01KC026 ROOM B105 | 351 | Copper 250 | 210 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69758 | Lead 250 | 0 | 01KC026 ROOM B105 | 352 | Copper 250 | 210 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69722 | Lead 250 | 0 | 01KC029 ROOM B114 | PRE | Copper 250 | 90 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69741 | Lead 250 | 0 | 01KC029 ROOM B114 | 351 | Copper 250 | 140 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69760 | Lead 250 | 0 | 01KC029 ROOM B114 | 352 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69723 | Lead 250 | 0 | 01KC030 ROOM B114 | PRE | Copper 250 | 80 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69742 | Lead 250 | 0 | 01KC030 ROOM B114 | 351 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69761 | Lead 250 | 0 | 01KC030 ROOM B114 | 352 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69725 | Lead 250 | 0 | 01KC033 COMMUNITY ROOM | PRE | Copper 250 | 280 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69744 | Lead 250 | 1 | 01KC033 COMMUNITY ROOM | 351 | Copper 250 | 220 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69763 | Lead 250 | 0 | 01KC033 COMMUNITY ROOM | 352 | Copper 250 | 130 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69726 | Lead 250 | 1 | 01KC034 COMMUNITY ROOM | PRE | Copper 250 | 250 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69745 | Lead 250 | 3 | 01KC034 COMMUNITY ROOM | 351 | Copper 250 | 250 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69764 | Lead 250 | 1 | 01KC034 COMMUNITY ROOM | 352 | Copper 250 | 190 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69727 | Lead 250 | 5 | 01KC037 SUPPLY ROOM | PRE | Copper 250 | 120 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69746 | Lead 250 | 2 | 01KC037 SUPPLY ROOM | 351 | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69765 | Lead 250 | 2 | 01KC037 SUPPLY ROOM | 352 | Copper 250 | 60 | OXLEY DRIVE | FLINT | 48504 | HOLMES STEM ACADEMY | |
| LH69808 | Lead 250 | 15 | 01CF003 ROOM 109 | PRE | Copper 250 | 1060 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69826 | Lead 250 | 2 | 01CF003 ROOM 109 | 351 | Copper 250 | 150 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69844 | Lead 250 | 1 | 01CF003 ROOM 109 | 352 | Copper 250 | 170 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69809 | Lead 250 | 1 | 01CF005 ROOM 110 | PRE | Copper 250 | 160 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69827 | Lead 250 | 0 | 01CF005 ROOM 110 | 351 | Copper 250 | 90 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69845 | Lead 250 | 0 | 01CF005 ROOM 110 | 352 | Copper 250 | 90 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69810 | Lead 250 | 0 | 01CF007 ROOM 108 | PRE | Copper 250 | 120 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69828 | Lead 250 | 0 | 01CF007 ROOM 108 | 351 | Copper 250 | 110 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Low pressure |
| LH69846 | Lead 250 | 0 | 01CF007 ROOM 108 | 352 | Copper 250 | 80 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Very low pressure |
| LH69811 | Lead 250 | 0 | 01CF010 ROOM 111 | PRE | Copper 250 | 130 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69829 | Lead 250 | 0 | 01CF010 ROOM 111 | 351 | Copper 250 | 140 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69847 | Lead 250 | 0 | 01CF010 ROOM 111 | 352 | Copper 250 | 110 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69812 | Lead 250 | 0 | 01CF011 ROOM 107 | PRE | Copper 250 | 80 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69830 | Lead 250 | 1 | 01CF011 ROOM 107 | 351 | Copper 250 | 100 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Low pressure |
| LH69848 | Lead 250 | 2 | 01CF011 ROOM 107 | 352 | Copper 250 | 110 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Low pressure |
| LH69813 | Lead 250 | 0 | 01CF013 ROOM 100 | PRE | Copper 250 | 0 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69831 | Lead 250 | 0 | 01CF013 ROOM 100 | 351 | Copper 250 | 60 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69849 | Lead 250 | 0 | 01CF013 ROOM 100 | 352 | Copper 250 | 50 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |

Flint Community Schools
Round 3, Week 2
3/9/18

| Sample Number | Lead | Lead (PPB) | Sample Description | Site Code | Copper | Copper (PPB) | Street Name | City | Zip | School | Comments |
|---------------|----------|------------|--|-----------|------------|--------------|------------------|-------|-------|-------------------|--|
| LH69814 | Lead 250 | 0 | 01CF014 ROOM 100 | PRE | Copper 250 | 0 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Hand washing sink only, no filter unit present |
| LH69850 | Lead 250 | 0 | 01CF014 ROOM 100 | 352 | Copper 250 | 60 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69832 | Lead 250 | 0 | 01CF014 ROOM 100 | 351 | Copper 250 | 70 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69816 | Lead 250 | 0 | 01CF018 ROOM 301 | PRE | Copper 250 | 0 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Low pressure |
| LH69834 | Lead 250 | 0 | 01CF018 ROOM 301 | 351 | Copper 250 | 70 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69852 | Lead 250 | 0 | 01CF018 ROOM 301 | 352 | Copper 250 | 60 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69817 | Lead 250 | 0 | 01CF020 ROOM 302 | PRE | Copper 250 | 140 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69835 | Lead 250 | 0 | 01CF020 ROOM 302 | 351 | Copper 250 | 120 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69853 | Lead 250 | 0 | 01CF020 ROOM 302 | 352 | Copper 250 | 130 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69818 | Lead 250 | 1 | 01CF021 ROOM 306 | PRE | Copper 250 | 80 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69836 | Lead 250 | 1 | 01CF021 ROOM 306 | 351 | Copper 250 | 100 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69854 | Lead 250 | 1 | 01CF021 ROOM 306 | 352 | Copper 250 | 90 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69819 | Lead 250 | 1 | 01CF023 ROOM 312 | PRE | Copper 250 | 140 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69837 | Lead 250 | 0 | 01CF023 ROOM 312 | 351 | Copper 250 | 90 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69855 | Lead 250 | 0 | 01CF023 ROOM 312 | 352 | Copper 250 | 100 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69820 | Lead 250 | 3 | 01CF026 ROOM 307 | PRE | Copper 250 | 170 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69838 | Lead 250 | 1 | 01CF026 ROOM 307 | 351 | Copper 250 | 190 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69856 | Lead 250 | 2 | 01CF026 ROOM 307 | 352 | Copper 250 | 140 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | Low pressure |
| LH69821 | Lead 250 | 0 | 01CF028 ROOM 311 | PRE | Copper 250 | 70 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69839 | Lead 250 | 9 | 01CF028 ROOM 311 | 351 | Copper 250 | 80 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69857 | Lead 250 | 4 | 01CF028 ROOM 311 | 352 | Copper 250 | 80 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69822 | Lead 250 | 2 | 01CF030 ROOM 308 | PRE | Copper 250 | 130 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69840 | Lead 250 | 3 | 01CF030 ROOM 308 | 351 | Copper 250 | 90 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69858 | Lead 250 | 3 | 01CF030 ROOM 308 | 352 | Copper 250 | 90 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69823 | Lead 250 | 1 | 01CF032 ROOM 310 | PRE | Copper 250 | 210 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69841 | Lead 250 | 0 | 01CF032 ROOM 310 | 351 | Copper 250 | 140 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69859 | Lead 250 | 0 | 01CF032 ROOM 310 | 352 | Copper 250 | 110 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69825 | Lead 250 | 1 | 01CF035 ROOM 112 | PRE | Copper 250 | 130 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69843 | Lead 250 | 0 | 01CF035 ROOM 112 | 351 | Copper 250 | 120 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69861 | Lead 250 | 0 | 01CF035 ROOM 112 | 352 | Copper 250 | 100 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69815 | Lead 250 | 0 | 01KC016 TEACHER'S LOUNGE | PRE | Copper 250 | 120 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69833 | Lead 250 | 0 | 01KC016 TEACHER'S LOUNGE | 351 | Copper 250 | 120 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69851 | Lead 250 | 0 | 01KC016 TEACHER'S LOUNGE | 352 | Copper 250 | 100 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69824 | Lead 250 | 0 | 02KC033 TEMP CLASS ROOM CLOSEST TO PARKI | PRE | Copper 250 | 130 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69842 | Lead 250 | 0 | 02KC033 TEMP CLASS ROOM CLOSEST TO PARKI | 351 | Copper 250 | 130 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69860 | Lead 250 | 0 | 02KC033 TEMP CLASS ROOM CLOSEST TO PARKI | 352 | Copper 250 | 170 | W VERNON DRIVE | FLINT | 48503 | PIERCE ELEMENTARY | |
| LH69940 | Lead 250 | 0 | 01BF031 ROOM 3 | PRE | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69968 | Lead 250 | 0 | 01BF031 ROOM 3 | 351 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69997 | Lead 250 | 0 | 01BF031 ROOM 3 | 352 | Copper 250 | 60 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69925 | Lead 250 | 1 | 01CF001 ROOM 22 | PRE | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69953 | Lead 250 | 1 | 01CF001 ROOM 22 | 351 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69982 | Lead 250 | 17 | 01CF001 ROOM 22 | 352 | Copper 250 | 150 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69926 | Lead 250 | 9 | 01CF003 ROOM 17 | PRE | Copper 250 | 770 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69954 | Lead 250 | 0 | 01CF003 ROOM 17 | 351 | Copper 250 | 110 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69983 | Lead 250 | 1 | 01CF003 ROOM 17 | 352 | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69927 | Lead 250 | 1 | 01CF004 ROOM 20 | PRE | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69955 | Lead 250 | 2 | 01CF004 ROOM 20 | 351 | Copper 250 | 70 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69984 | Lead 250 | 2 | 01CF004 ROOM 20 | 352 | Copper 250 | 70 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69928 | Lead 250 | 0 | 01CF007 ROOM 15 | PRE | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69956 | Lead 250 | 4 | 01CF007 ROOM 15 | 351 | Copper 250 | 120 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69985 | Lead 250 | 0 | 01CF007 ROOM 15 | 352 | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69931 | Lead 250 | 0 | 01CF013 ROOM 12 | PRE | Copper 250 | 60 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69959 | Lead 250 | 1 | 01CF013 ROOM 12 | 351 | Copper 250 | 60 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69988 | Lead 250 | 0 | 01CF013 ROOM 12 | 352 | Copper 250 | 0 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69932 | Lead 250 | 3 | 01CF014 ROOM 9 | PRE | Copper 250 | 170 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69960 | Lead 250 | 3 | 01CF014 ROOM 9 | 351 | Copper 250 | 150 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69989 | Lead 250 | 3 | 01CF014 ROOM 9 | 352 | Copper 250 | 160 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69933 | Lead 250 | 0 | 01CF015 ROOM 10 | PRE | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69961 | Lead 250 | 6 | 01CF015 ROOM 10 | 351 | Copper 250 | 120 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69990 | Lead 250 | 3 | 01CF015 ROOM 10 | 352 | Copper 250 | 120 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |

Flint Community Schools
Round 3, Week 2
3/9/18

| Sample Number | Lead | Lead (PPB) | Sample Description | Site Code | Copper | Copper (PPB) | Street Name | City | Zip | School | Comments |
|---------------|----------|------------|-------------------------|-----------|------------|--------------|------------------|-------|-------|-------------------|----------|
| LH69934 | Lead 250 | 0 | 01CF017 ROOM 8 | PRE | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69962 | Lead 250 | 3 | 01CF017 ROOM 8 | 351 | Copper 250 | 120 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69991 | Lead 250 | 2 | 01CF017 ROOM 8 | 352 | Copper 250 | 130 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69935 | Lead 250 | 0 | 01CF019 ROOM 7 | PRE | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69963 | Lead 250 | 3 | 01CF019 ROOM 7 | 351 | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69992 | Lead 250 | 2 | 01CF019 ROOM 7 | 352 | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69936 | Lead 250 | 0 | 01CF021 ROOM 6 | PRE | Copper 250 | 160 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69964 | Lead 250 | 5 | 01CF021 ROOM 6 | 351 | Copper 250 | 220 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69993 | Lead 250 | 8 | 01CF021 ROOM 6 | 352 | Copper 250 | 300 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69937 | Lead 250 | 0 | 01CF024 ROOM 5 | PRE | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69965 | Lead 250 | 1 | 01CF024 ROOM 5 | 351 | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69994 | Lead 250 | 0 | 01CF024 ROOM 5 | 352 | Copper 250 | 70 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69941 | Lead 250 | 2 | 01CF027 ROOM 4 | PRE | Copper 250 | 280 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69969 | Lead 250 | 2 | 01CF027 ROOM 4 | 351 | Copper 250 | 110 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69998 | Lead 250 | 2 | 01CF027 ROOM 4 | 352 | Copper 250 | 110 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69942 | Lead 250 | 33 | 01CF029 ROOM 3 | PRE | Copper 250 | 230 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69970 | Lead 250 | 5 | 01CF029 ROOM 3 | 351 | Copper 250 | 150 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69999 | Lead 250 | 4 | 01CF029 ROOM 3 | 352 | Copper 250 | 160 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69943 | Lead 250 | 1 | 01CF033 ROOM 1A LIBRARY | PRE | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69971 | Lead 250 | 1 | 01CF033 ROOM 1A LIBRARY | 351 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70000 | Lead 250 | 2 | 01CF033 ROOM 1A LIBRARY | 352 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69944 | Lead 250 | 0 | 01CF035 ROOM 2A LIBRARY | PRE | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69972 | Lead 250 | 1 | 01CF035 ROOM 2A LIBRARY | 351 | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70001 | Lead 250 | 0 | 01CF035 ROOM 2A LIBRARY | 352 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69945 | Lead 250 | 2 | 01CF037 ROOM 38 | PRE | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69973 | Lead 250 | 3 | 01CF037 ROOM 38 | 351 | Copper 250 | 70 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70002 | Lead 250 | 2 | 01CF037 ROOM 38 | 352 | Copper 250 | 50 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69946 | Lead 250 | 1 | 01CF039 ROOM 39 | PRE | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69974 | Lead 250 | 4 | 01CF039 ROOM 39 | 351 | Copper 250 | 110 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70003 | Lead 250 | 6 | 01CF039 ROOM 39 | 352 | Copper 250 | 110 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69947 | Lead 250 | 0 | 01CF041 ROOM 36 | PRE | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69975 | Lead 250 | 0 | 01CF041 ROOM 36 | 351 | Copper 250 | 70 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70004 | Lead 250 | 1 | 01CF041 ROOM 36 | 352 | Copper 250 | 60 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69976 | Lead 250 | 2 | 01CF043 ROOM 37 | 351 | Copper 250 | 130 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70005 | Lead 250 | 2 | 01CF043 ROOM 37 | 352 | Copper 250 | 120 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69948 | Lead 250 | 0 | 01CF045 ROOM 34 | PRE | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69977 | Lead 250 | 10 | 01CF045 ROOM 34 | 351 | Copper 250 | 330 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70006 | Lead 250 | 16 | 01CF045 ROOM 34 | 352 | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69949 | Lead 250 | 3 | 01CF047 ROOM 35 | PRE | Copper 250 | 240 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69978 | Lead 250 | 5 | 01CF047 ROOM 35 | 351 | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70007 | Lead 250 | 5 | 01CF047 ROOM 35 | 352 | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69950 | Lead 250 | 0 | 01CF050 ROOM 33 | PRE | Copper 250 | 190 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69979 | Lead 250 | 2 | 01CF050 ROOM 33 | 351 | Copper 250 | 140 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70008 | Lead 250 | 2 | 01CF050 ROOM 33 | 352 | Copper 250 | 130 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69951 | Lead 250 | 0 | 01CF052 ROOM 31 | PRE | Copper 250 | 200 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69980 | Lead 250 | 2 | 01CF052 ROOM 31 | 351 | Copper 250 | 130 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70009 | Lead 250 | 2 | 01CF052 ROOM 31 | 352 | Copper 250 | 150 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69929 | Lead 250 | 0 | 01KC008 COMMUNITY ROOM | PRE | Copper 250 | 60 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69957 | Lead 250 | 7 | 01KC008 COMMUNITY ROOM | 351 | Copper 250 | 70 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69986 | Lead 250 | 2 | 01KC008 COMMUNITY ROOM | 352 | Copper 250 | 90 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69930 | Lead 250 | 0 | 01KC009 DHHS | PRE | Copper 250 | 110 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69958 | Lead 250 | 0 | 01KC009 DHHS | 351 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69987 | Lead 250 | 0 | 01KC009 DHHS | 352 | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69938 | Lead 250 | 0 | 01KC025 ROOM 5 | PRE | Copper 250 | 260 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69966 | Lead 250 | 1 | 01KC025 ROOM 5 | 351 | Copper 250 | 180 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69995 | Lead 250 | 0 | 01KC025 ROOM 5 | 352 | Copper 250 | 160 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69939 | Lead 250 | 1 | 01KC026 ROOM 5 | PRE | Copper 250 | 250 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69967 | Lead 250 | 1 | 01KC026 ROOM 5 | 351 | Copper 250 | 190 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69996 | Lead 250 | 1 | 01KC026 ROOM 5 | 352 | Copper 250 | 130 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH69952 | Lead 250 | 0 | 02KC056 OUTBUILDING #2 | PRE | Copper 250 | 100 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |

Flint Community Schools
Round 3, Week 2
3/9/18

| Sample Number | Lead | Lead (PPB) | Sample Description | Site Code | Copper | Copper (PPB) | Street Name | City | Zip | School | Comments |
|---------------|----------|------------|------------------------|-----------|------------|--------------|------------------|-------|-------|-------------------|----------|
| LH69981 | Lead 250 | 0 | 02KC056 OUTBUILDING #2 | 3S1 | Copper 250 | 80 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |
| LH70010 | Lead 250 | 0 | 02KC056 OUTBUILDING #2 | 3S2 | Copper 250 | 150 | N AVERILL AVENUE | FLINT | 48506 | POTTER ELEMENTARY | |