

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ65549	7/8/2021	Lead				1	Copper				0	910	ADDISON ST	FLINT	48505
LJ65550	7/8/2021	Lead				2	Copper				0	910	ADDISON ST	FLINT	48505
LJ82194	9/30/2021	Lead	0	0	0		Copper	0	0	0		2547	BAGLEY ST	FLINT	48504
LJ74247	8/24/2021	Lead				0	Copper				0	1122	BARRIE AVE	FLINT	48507
LJ74248	8/24/2021	Lead				0	Copper				0	1122	BARRIE AVE	FLINT	48507
LJ66162	7/13/2021	Lead				0	Copper				60	1120	BEACH	FLINT	48502
LJ66161	7/13/2021	Lead				2	Copper				0	1120	BEACH	FLINT	48502
LJ65536	7/8/2021	Lead				1	Copper				0	718	BEACH ST	FLINT	48502
LJ78873	9/16/2021	Lead	8	21	18		Copper	50	0	0		718	BEACH ST	FLINT	48502
LJ65535	7/8/2021	Lead				53	Copper				80	718	BEACH ST	FLINT	48502
LJ82646	10/4/2021	Lead	11	84	66		Copper	50	230	190		718	BEACH ST	FLINT	48502
LJ66143	7/13/2021	Lead				1	Copper				0	1114	BEACH ST	FLINT	48502
LJ66144	7/13/2021	Lead				1	Copper				0	1114	BEACH ST	FLINT	48502
LJ65556	7/8/2021	Lead				0	Copper				60	1226	BEACH ST	FLINT	48502
LJ65555	7/8/2021	Lead				1	Copper				70	1226	BEACH ST	FLINT	48502
LJ70657	8/5/2021	Lead				0	Copper				0	3310	BEECHER RD	FLINT	48503
LJ70658	8/5/2021	Lead				0	Copper				0	3310	BEECHER RD	FLINT	48503
LJ68097	7/22/2021	Lead	0	0	0		Copper	0	0	0		2309	BENNETT AVE	FLINT	48506
LJ91196	12/6/2021	Lead	2	0	0		Copper	70	0	0		3127	BENNETT AVE	FLINT	48506
LJ88831	11/15/2021	Lead	3	1	2		Copper	100	0	0		1310	BLANCHARD AVE	FLINT	48503
LJ76618	9/7/2021	Lead	0	0	0		Copper	0	0	0		4109	BRONSWICK AVE	FLINT	48507
LJ82195	9/30/2021	Lead	0	0	0		Copper	0	0	0		4001	BROWHELL BLVD	FLINT	48504
LJ75055	8/26/2021	Lead	0	0	0		Copper	0	0	0		2734	BROWN ST	FLINT	48503
LJ76619	9/7/2021	Lead	0	0	0		Copper	0	0	0		2707	BROWNELL BLVD	FLINT	48504
LJ70656	8/5/2021	Lead				122	Copper				60	2707	BROWNELL BLVD	FLINT	48504
LJ70655	8/5/2021	Lead				293	Copper				140	2707	BROWNELL BLVD	FLINT	48504
LJ70125	8/3/2021	Lead	0	0	0		Copper	100	90	90		1843	CHELAN ST	FLINT	48503
LJ83874	10/11/2021	Lead				0	Copper				0	1802	CHELSEA CIR	FLINT	48503
LJ83875	10/11/2021	Lead				0	Copper				0	1802	CHELSEA CIR	FLINT	48503
LJ70120	8/3/2021	Lead				0	Copper				0	2725	CHICAGO BLVD	FLINT	48503
LJ70121	8/3/2021	Lead				0	Copper				0	2725	CHICAGO BLVD	FLINT	48503
LJ85802	10/25/2021	Lead	0	0	0		Copper	0	0	0		1129	CHIPPEWA	FLINT	48503
LJ65517	7/8/2021	Lead				5	Copper				90	726	CHURCH ST	FLINT	48502
LJ65518	7/8/2021	Lead				5	Copper				0	726	CHURCH ST	FLINT	48502
LJ65509	7/8/2021	Lead				0	Copper				50	1019	CHURCH ST	FLINT	48502
LJ65510	7/8/2021	Lead				0	Copper				0	1019	CHURCH ST	FLINT	48502
LJ65516	7/8/2021	Lead				0	Copper				0	1027	CHURCH ST	FLINT	48502
LJ65515	7/8/2021	Lead				1	Copper				0	1027	CHURCH ST	FLINT	48502
LJ66145	7/13/2021	Lead				0	Copper				0	4101	CIRCLE DR	FLINT	48507
LJ66146	7/13/2021	Lead				0	Copper				0	4101	CIRCLE DR	FLINT	48507
LJ78870	9/16/2021	Lead	0	0	0		Copper	0	0	0		3214	CLEMENT ST	FLINT	48504
LJ72759	8/16/2021	Lead	0	0	0		Copper	0	60	0		652	CLINTON ST	FLINT	48507
LJ66159	7/13/2021	Lead				0	Copper				0	2500	CLIO RD	FLINT	48504
LJ66160	7/13/2021	Lead				0	Copper				0	2500	CLIO RD	FLINT	48504
LJ67011	7/15/2021	Lead				0	Copper				0	1701	COLORADO AVE APT #1	FLINT	48506
LJ67012	7/15/2021	Lead				0	Copper				0	1701	COLORADO AVE APT #1	FLINT	48506

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ84932	10/18/2021	Lead	0	0	0		Copper	0	0	0		3509	COMANCHE AVE	FLINT	48507
LJ66139	7/13/2021	Lead				0	Copper				0	134	COMMONWEALTH AVE	FLINT	48503
LJ66140	7/13/2021	Lead				0	Copper				0	134	COMMONWEALTH AVE	FLINT	48503
LJ92665	12/13/2021	Lead	0	0	0		Copper	0	0	0		2629	CONCORD ST	FLINT	48504
LJ74245	8/24/2021	Lead				1	Copper				0	919	COPEMAN BLVD	FLINT	48504
LJ74246	8/24/2021	Lead				1	Copper				0	919	COPEMAN BLVD	FLINT	48504
LJ66141	7/13/2021	Lead				0	Copper				0	2820	CORUNNA	FLINT	48503
LJ66142	7/13/2021	Lead				0	Copper				0	2820	CORUNNA	FLINT	48503
LJ70667	8/5/2021	Lead				0	Copper				0	2317	CORUNNA RD	FLINT	48503
LJ70668	8/5/2021	Lead				0	Copper				0	2317	CORUNNA RD	FLINT	48503
LJ66151	7/13/2021	Lead				2	Copper				0	2608	CORUNNA RD	FLINT	48503
LJ66152	7/13/2021	Lead				4	Copper				0	2608	CORUNNA RD	FLINT	48503
LJ66163	7/13/2021	Lead				0	Copper				0	3910	CORUNNA RD	FLINT	48532
LJ66164	7/13/2021	Lead				0	Copper				0	3910	CORUNNA RD	FLINT	48532
LJ70108	8/3/2021	Lead				1	Copper				0	509	COTTAGE GROVE	FLINT	48504
LJ70109	8/3/2021	Lead				2	Copper				0	509	COTTAGE GROVE	FLINT	48504
LJ70665	8/5/2021	Lead				0	Copper				0	1703	CRESCENT DR	FLINT	48503
LJ70666	8/5/2021	Lead				0	Copper				0	1703	CRESCENT DR	FLINT	48503
LJ76621	9/7/2021	Lead	0	0	0		Copper	60	0	0		4701	CRESTBROOK LANE	FLINT	48507
LJ70660	8/5/2021	Lead				0	Copper				0	2302	CUMMINGS	FLINT	48503
LJ70659	8/5/2021	Lead				2	Copper				190	2302	CUMMINGS	FLINT	48503
LJ67001	7/15/2021	Lead				0	Copper				0	1720	DAVISON	FLINT	48506
LJ67628	7/20/2021	Lead				0	Copper				0	2221	DAVISON	FLINT	48506
LJ67627	7/20/2021	Lead				1	Copper				120	2221	DAVISON	FLINT	48506
LJ67002	7/15/2021	Lead				0	Copper				0	1720	DAVISON RD	FLINT	48506
LJ71312	8/10/2021	Lead				0	Copper				0	726	DICKINSON ST	FLINT	48504
LJ71313	8/10/2021	Lead				0	Copper				0	726	DICKINSON ST	FLINT	48504
LJ70100	8/3/2021	Lead				9	Copper				0	733	DICKINSON ST	FLINT	48504
LJ70101	8/3/2021	Lead				9	Copper				0	733	DICKINSON ST	FLINT	48504
LJ64753	7/1/2021	Lead	0	0	0		Copper	0	0	0		914	DOWNEY	FLINT	48503
LJ65541	7/8/2021	Lead				0	Copper				0	1670	DUPONT ST	FLINT	48503
LJ65542	7/8/2021	Lead				0	Copper				0	1670	DUPONT ST	FLINT	48503
LJ66991	7/15/2021	Lead				0	Copper				0	4512	DUPONT ST	FLINT	48505
LJ66992	7/15/2021	Lead				0	Copper				0	4512	DUPONT ST	FLINT	48505
LJ73066	8/17/2021	Lead				0	Copper				110	1415	DURAND ST	FLINT	48503
LJ73067	8/17/2021	Lead				0	Copper				0	1415	DURAND ST	FLINT	48503
LJ70107	8/3/2021	Lead				1	Copper				0	902	E 6TH ST	FLINT	48503
LJ70106	8/3/2021	Lead				2	Copper				0	902	E 6TH ST	FLINT	48503
LJ67014	7/15/2021	Lead				0	Copper				0	311	E COURT ST	FLINT	48502
LJ67013	7/15/2021	Lead				1	Copper				0	311	E COURT ST	FLINT	48502
LJ89693	11/22/2021	Lead	0	0	0		Copper	0	0	0		224	E COURT ST APT 102	FLINT	48502
LJ67005	7/15/2021	Lead				0	Copper				0	915	E COURT ST APT 205	FLINT	48503
LJ67006	7/15/2021	Lead				0	Copper				0	915	E COURT ST APT 205	FLINT	48503
LJ76445	9/7/2021	Lead				0	Copper				0	217	E FLINT PARK BLVD	FLINT	48505
LJ76446	9/7/2021	Lead				0	Copper				0	217	E FLINT PARK BLVD	FLINT	48505
LJ72027	8/12/2021	Lead				0	Copper				0	926	E FORK DR	FLINT	48503

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ72028	8/12/2021	Lead				0	Copper				0	926	E FORK DR	FLINT	48503
LJ69269	7/29/2021	Lead				0	Copper				0	721	E HOLBROOK	FLINT	48505
LJ69270	7/29/2021	Lead				0	Copper				0	721	E HOLBROOK	FLINT	48505
LJ69271	7/29/2021	Lead				0	Copper				0	810	E HOLBROOK	FLINT	48505
LJ69272	7/29/2021	Lead				0	Copper				0	810	E HOLBROOK	FLINT	48505
LJ70664	8/5/2021	Lead				0	Copper				0	725	E HOLBROOK AVE	FLINT	48505
LJ70663	8/5/2021	Lead				1	Copper				0	725	E HOLBROOK AVE	FLINT	48505
LJ78869	9/16/2021	Lead	0	0	0		Copper	130	90	100		609	E HOME AVE	FLINT	48505
LJ76444	9/7/2021	Lead				2	Copper				0	201	E JACKSON AVE	FLINT	48505
LJ76443	9/7/2021	Lead				3	Copper				0	201	E JACKSON AVE	FLINT	48505
LJ78868	9/16/2021	Lead	0	0	0		Copper	0	60	0		822	E MOORE ST	FLINT	48505
LJ70122	8/3/2021	Lead				0	Copper				0	209	E PHILADELPHIA BLVD	FLINT	48503
LJ70123	8/3/2021	Lead				0	Copper				0	209	E PHILADELPHIA BLVD	FLINT	48503
LJ76244	9/2/2021	Lead				3	Copper				0	410	E. COURT	FLINT	48503
LJ76243	9/2/2021	Lead				8	Copper				70	410	E. COURT	FLINT	48503
LJ65537	7/8/2021	Lead				0	Copper				0	807	EAST 2ND ST	FLINT	48503
LJ65538	7/8/2021	Lead				0	Copper				0	807	EAST 2ND ST	FLINT	48503
LJ66996	7/15/2021	Lead				3	Copper				90	3608	FENTON RD	FLINT	48504
LJ66995	7/15/2021	Lead				6	Copper				60	3608	FENTON RD	FLINT	48504
LJ65553	7/8/2021	Lead				0	Copper				180	4517	FENTON RD	FLINT	48507
LJ65554	7/8/2021	Lead				0	Copper				0	4517	FENTON RD	FLINT	48507
LJ66137	7/13/2021	Lead				0	Copper				0	728	GARLAND ST	FLINT	48503
LJ66138	7/13/2021	Lead				0	Copper				0	728	GARLAND ST	FLINT	48503
LJ70124	8/3/2021	Lead	0	0	0		Copper	0	0	0		421	GARLAND ST APT 201	FLINT	48503
LJ70102	8/3/2021	Lead				0	Copper				0	2812	GIBSON ST	FLINT	48503
LJ70103	8/3/2021	Lead				0	Copper				0	2812	GIBSON ST	FLINT	48503
LJ66236	7/13/2021	Lead	0	0	0		Copper	0	0	0		5801	GRIGGS DR	FLINT	48504
LJ70118	8/3/2021	Lead				1	Copper				80	964	HUGHES	FLINT	48503
LJ70119	8/3/2021	Lead				2	Copper				100	964	HUGHES	FLINT	48503
LJ68092	7/22/2021	Lead				0	Copper				0	857	INGLESIDE	FLINT	48507
LJ68093	7/22/2021	Lead				0	Copper				0	857	INGLESIDE	FLINT	48507
LJ65513	7/8/2021	Lead				0	Copper				0	2000	JOLIET ST	FLINT	48504
LJ65514	7/8/2021	Lead				0	Copper				0	2000	JOLIET ST	FLINT	48504
LJ76251	9/2/2021	Lead	0	0	0		Copper	190	0	0		1036	KNICKERBOCKER AVE	FLINT	48505
LJ66997	7/15/2021	Lead				0	Copper				0	1113	LAPEER RD	FLINT	48503
LJ66998	7/15/2021	Lead				0	Copper				0	1113	LAPEER RD	FLINT	48503
LJ66147	7/13/2021	Lead				0	Copper				60	2301	LEVERN ST	FLINT	48506
LJ66148	7/13/2021	Lead				1	Copper				0	2301	LEVERN ST	FLINT	48506
LJ84931	10/18/2021	Lead	0	0	0		Copper	0	0	0		3529	LIPPINCOT	FLINT	48507
LJ82193	9/30/2021	Lead	0	0	0		Copper	50	0	0		3833	LORRAINE AVE	FLINT	48509
LJ70110	8/3/2021	Lead				0	Copper				0	4010	M LUTHER KING AVE	FLINT	48505
LJ70111	8/3/2021	Lead				0	Copper				0	4010	M LUTHER KING AVE	FLINT	48505
LJ65511	7/8/2021	Lead				0	Copper				0	948	MAJOR ST	FLINT	48507
LJ65512	7/8/2021	Lead				2	Copper				0	948	MAJOR ST	FLINT	48507
LJ78872	9/16/2021	Lead	0	0	0		Copper	0	0	0		2929	MALLERY ST	FLINT	48504
LJ67625	7/20/2021	Lead				0	Copper				0	927	MANN AVE	FLINT	48503

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ67626	7/20/2021	Lead				0	Copper				0	927	MANN AVE	FLINT	48503
LJ76622	9/7/2021	Lead	0	0	0		Copper	0	0	0		5713	MARLOWE DR	FLINT	48504
LJ66993	7/15/2021	Lead				0	Copper				0	808	MARQUETTE	FLINT	48504
LJ66994	7/15/2021	Lead				0	Copper				0	808	MARQUETTE	FLINT	48504
LJ81161	9/28/2021	Lead				0	Copper				0	3702	MARTIN LUTHER KING	FLINT	48505
LJ81162	9/28/2021	Lead				0	Copper				0	3702	MARTIN LUTHER KING	FLINT	48505
LJ78171	9/14/2021	Lead				4	Copper				0	3318	MARTIN LUTHER KING BLVD	FLINT	48505
LJ78172	9/14/2021	Lead				7	Copper				0	3318	MARTIN LUTHER KING BLVD	FLINT	48505
LJ66149	7/13/2021	Lead				0	Copper				0	1538	MARYLAND AVE	FLINT	48506
LJ66150	7/13/2021	Lead				0	Copper				0	1538	MARYLAND AVE	FLINT	48506
LJ66155	7/13/2021	Lead				0	Copper				0	2112	MARYLAND AVE	FLINT	48506
LJ66156	7/13/2021	Lead				1	Copper				0	2112	MARYLAND AVE	FLINT	48506
LJ72053	8/12/2021	Lead	0	0	0		Copper	0	0	0		3010	MENOMINEE	FLINT	48507
LJ74243	8/24/2021	Lead				0	Copper				0	2239	MILBOURNE	FLINT	48504
LJ74244	8/24/2021	Lead				0	Copper				0	2239	MILBOURNE	FLINT	48504
LJ64752	7/1/2021	Lead	0	0	0		Copper	0	0	0		1209	MOHAWK AVE	FLINT	48507
LJ65558	7/8/2021	Lead				0	Copper				0	1647	MONTANA	FLINT	48506
LJ65557	7/8/2021	Lead				2	Copper				50	1647	MONTANA	FLINT	48506
LJ72052	8/12/2021	Lead	0	85	64		Copper	0	60	0		2301	MONTEITH ST	FLINT	48504
LJ71318	8/10/2021	Lead				0	Copper				0	1921	MONTIETH ST	FLINT	48504
LJ71319	8/10/2021	Lead				0	Copper				0	1921	MONTIETH ST	FLINT	48504
LJ70654	8/5/2021	Lead				2	Copper				0	1816	N BALLENGER HWY	FLINT	48504
LJ70653	8/5/2021	Lead				6	Copper				110	1816	N BALLENGER HWY	FLINT	48504
LJ88830	11/15/2021	Lead	0	0	0		Copper	0	0	0		2001	N CENTER RD	FLINT	48506
LJ76620	9/7/2021	Lead	0	0	0		Copper	0	0	0		650	N CHEVROLET	FLINT	48504
LJ67008	7/15/2021	Lead				0	Copper				0	1128	N CHEVROLET	FLINT	48504
LJ67007	7/15/2021	Lead				2	Copper				0	1128	N CHEVROLET	FLINT	48504
LJ66165	7/13/2021	Lead				9	Copper				150	1669	N CHEVROLET	FLINT	48504
LJ66166	7/13/2021	Lead				3,492	Copper				5,250	1669	N CHEVROLET	FLINT	48504
LJ78871	9/16/2021	Lead	0	1	0		Copper	0	0	0		1669	N CHEVROLET AVE OTW	FLINT	48504
LJ65529	7/8/2021	Lead				0	Copper				0	1517	N DORT HWY	FLINT	48506
LJ65530	7/8/2021	Lead				0	Copper				0	1517	N DORT HWY	FLINT	48506
LJ82867	10/5/2021	Lead				0	Copper				0	1517	N GRAND TRAVERSE ST	FLINT	48503
LJ82868	10/5/2021	Lead				0	Copper				0	1517	N GRAND TRAVERSE ST	FLINT	48503
LJ65522	7/8/2021	Lead				2	Copper				0	3817	N SAGINAW	FLINT	48505
LJ65521	7/8/2021	Lead				3	Copper				0	3817	N SAGINAW	FLINT	48505
LJ70116	8/3/2021	Lead				0	Copper				0	1633	N SAGINAW ST	FLINT	48503
LJ70117	8/3/2021	Lead				0	Copper				0	1633	N SAGINAW ST	FLINT	48503
LJ79589	9/21/2021	Lead				0	Copper				0	4901	N SAGINAW ST	FLINT	48505
LJ79590	9/21/2021	Lead				0	Copper				0	4901	N SAGINAW ST	FLINT	48505
LJ70112	8/3/2021	Lead				0	Copper				80	1902	NEBRASKA AVE	FLINT	48506
LJ70113	8/3/2021	Lead				0	Copper				80	1902	NEBRASKA AVE	FLINT	48506
LJ79587	9/21/2021	Lead				0	Copper				0	1609	NEOME DR	FLINT	48503
LJ79588	9/21/2021	Lead				0	Copper				0	1609	NEOME DR	FLINT	48503
LJ71314	8/10/2021	Lead				0	Copper				0	3518	NORWOOD DR	FLINT	48503
LJ71315	8/10/2021	Lead				0	Copper				0	3518	NORWOOD DR	FLINT	48503

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ68088	7/22/2021	Lead				0	Copper				0	718	OAK ST	FLINT	48503
LJ68089	7/22/2021	Lead				0	Copper				0	718	OAK ST	FLINT	48503
LJ75324	8/30/2021	Lead				0	Copper				0	2547	PADUCAH	FLINT	48504
LJ75325	8/30/2021	Lead				0	Copper				0	2547	PADUCAH	FLINT	48504
LJ73062	8/17/2021	Lead				0	Copper				0	2535	PADUCAH ST	FLINT	48504
LJ73063	8/17/2021	Lead				0	Copper				0	2535	PADUCAH ST	FLINT	48504
LJ67749	7/21/2021	Lead	0	0	0		Copper	0	0	0		1922	PARK FOREST DR	FLINT	48507
LJ65534	7/8/2021	Lead				3	Copper				0	1720	PENOYER CT	FLINT	48506
LJ65533	7/8/2021	Lead				5	Copper				0	1720	PENOYER CT	FLINT	48506
LJ71003	8/9/2021	Lead	0	0	0		Copper	0	0	0		4110	RED ARROW RD	FLINT	48507
LJ70104	8/3/2021	Lead				0	Copper				0	1250	ROOSEVELT AVE	FLINT	48503
LJ70105	8/3/2021	Lead				0	Copper				0	1250	ROOSEVELT AVE	FLINT	48503
LJ71323	8/10/2021	Lead				1	Copper				0	1602	S BALLENGER	FLINT	48532
LJ71322	8/10/2021	Lead				2	Copper				0	1602	S BALLENGER	FLINT	48532
LJ65539	7/8/2021	Lead				0	Copper				70	2260	S DORT HWY	FLINT	48507
LJ65540	7/8/2021	Lead				0	Copper				0	2260	S DORT HWY	FLINT	48507
LJ67631	7/20/2021	Lead				3	Copper				0	1036	S GRAND TRAVERS	FLINT	48502
LJ67632	7/20/2021	Lead				3	Copper				0	1036	S GRAND TRAVERS	FLINT	48502
LJ76449	9/7/2021	Lead				0	Copper				0	520	S GRAND TRAVERSE	FLINT	48503
LJ76450	9/7/2021	Lead				1	Copper				0	520	S GRAND TRAVERSE	FLINT	48503
LJ65524	7/8/2021	Lead				1	Copper				0	1034	S GRAND TRAVERSE	FLINT	48502
LJ65523	7/8/2021	Lead				2	Copper				0	1034	S GRAND TRAVERSE	FLINT	48502
LJ65519	7/8/2021	Lead				338	Copper				120	1036	S GRAND TRAVERSE	FLINT	48502
LJ65520	7/8/2021	Lead				513	Copper				230	1036	S GRAND TRAVERSE	FLINT	48502
LJ65525	7/8/2021	Lead				0	Copper				90	1038	S GRAND TRAVERSE	FLINT	48502
LJ65526	7/8/2021	Lead				2	Copper				0	1038	S GRAND TRAVERSE	FLINT	48502
LJ65551	7/8/2021	Lead				0	Copper				60	647	S SAGINAW	FLINT	48502
LJ65552	7/8/2021	Lead				0	Copper				0	647	S SAGINAW	FLINT	48502
LJ79585	9/21/2021	Lead				11	Copper				110	428	S SAGINAW ST	FLINT	48502
LJ79586	9/21/2021	Lead				14	Copper				0	428	S SAGINAW ST	FLINT	48502
LJ64969	7/6/2021	Lead				2	Copper				0	1201	S SAGINAW ST	FLINT	48503
LJ64968	7/6/2021	Lead				3	Copper				0	1201	S SAGINAW ST	FLINT	48503
LJ65547	7/8/2021	Lead				0	Copper				0	1208	S SAGINAW ST	FLINT	48502
LJ65548	7/8/2021	Lead				0	Copper				0	1208	S SAGINAW ST	FLINT	48502
LJ67009	7/15/2021	Lead				0	Copper				0	2304	S SAGINAW ST	FLINT	48503
LJ67010	7/15/2021	Lead				0	Copper				0	2304	S SAGINAW ST	FLINT	48503
LJ65543	7/8/2021	Lead				0	Copper				90	3404	S SAGINAW ST	FLINT	48503
LJ65544	7/8/2021	Lead				0	Copper				0	3404	S SAGINAW ST	FLINT	48503
LJ68090	7/22/2021	Lead				0	Copper				0	444	SAGINAW	FLINT	48502
LJ65532	7/8/2021	Lead				0	Copper				0	2905	SAGINAW RD	FLINT	48505
LJ65531	7/8/2021	Lead				2	Copper				0	2905	SAGINAW RD	FLINT	48505
LJ68091	7/22/2021	Lead				0	Copper				0	444	SAGINAW ST	FLINT	48502
LJ75322	8/30/2021	Lead				0	Copper				0	1302	SOUTH BALLENGER HWY	FLINT	48532
LJ75323	8/30/2021	Lead				0	Copper				0	1302	SOUTH BALLENGER HWY	FLINT	48532
LJ92664	12/13/2021	Lead	1	0	0		Copper	0	0	0		2714	STEVENSON ST	FLINT	48504
LJ82192	9/30/2021	Lead	1	0	0		Copper	0	0	0		1414	STONE ST	FLINT	48503

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LJ84929	10/18/2021	Lead	0	0	0		Copper	0	0	0		607	THAYER ST	FLINT	48503
LJ78867	9/16/2021	Lead	0	0	0		Copper	0	0	0		4301	TRUMBULL DR	FLINT	48504
LJ73064	8/17/2021	Lead				0	Copper				0	2524	TYRONE ST	FLINT	48504
LJ73065	8/17/2021	Lead				0	Copper				0	2524	TYRONE ST	FLINT	48504
LJ71316	8/10/2021	Lead				0	Copper				0	509	W 12TH ST	FLINT	48503
LJ71317	8/10/2021	Lead				0	Copper				0	509	W 12TH ST	FLINT	48503
LJ71321	8/10/2021	Lead				0	Copper				0	602	W 12TH ST	FLINT	48503
LJ71320	8/10/2021	Lead				1	Copper				0	602	W 12TH ST	FLINT	48503
LJ65546	7/8/2021	Lead				1	Copper				0	409	W 7TH ST	FLINT	48503
LJ65545	7/8/2021	Lead				2	Copper				0	409	W 7TH ST	FLINT	48503
LJ76447	9/7/2021	Lead				0	Copper				0	1201	W ATHERTON RD	FLINT	48507
LJ76448	9/7/2021	Lead				2	Copper				0	1201	W ATHERTON RD	FLINT	48507
LJ66157	7/13/2021	Lead				0	Copper				60	414	W COURT ST	FLINT	48503
LJ66158	7/13/2021	Lead				0	Copper				0	414	W COURT ST	FLINT	48503
LJ65527	7/8/2021	Lead				0	Copper				0	620	W COURT ST	FLINT	48503
LJ65528	7/8/2021	Lead				0	Copper				0	620	W COURT ST	FLINT	48503
LJ66153	7/13/2021	Lead				0	Copper				60	1428	W COURT ST	FLINT	48503
LJ66154	7/13/2021	Lead				0	Copper				0	1428	W COURT ST	FLINT	48503
LJ66136	7/13/2021	Lead				0	Copper				0	1742	W COURT ST	FLINT	48503
LJ66135	7/13/2021	Lead				2	Copper				0	1742	W COURT ST	FLINT	48503
LJ70662	8/5/2021	Lead				0	Copper				0	2225	W COURT ST	FLINT	48503
LJ70661	8/5/2021	Lead				1	Copper				0	2225	W COURT ST	FLINT	48503
LJ66167	7/13/2021	Lead				0	Copper				0	2012	W DARTMOUTH	FLINT	48504
LJ66168	7/13/2021	Lead				0	Copper				0	2012	W DARTMOUTH	FLINT	48504
LJ81001	9/27/2021	Lead	9	12	11		Copper	90	90	90		1807	W HOBSON	FLINT	48504
LJ78169	9/14/2021	Lead				2	Copper				0	113	W JAMIESON	FLINT	48505
LJ78170	9/14/2021	Lead				6	Copper				0	113	W JAMIESON	FLINT	48505
LJ70114	8/3/2021	Lead				0	Copper				0	514	W JAMIESON	FLINT	48505
LJ70115	8/3/2021	Lead				0	Copper				60	514	W JAMIESON	FLINT	48505
LJ86739	11/1/2021	Lead	0	0	0		Copper	0	0	0		4002	W KEARSLEY ST	FLINT	48532
LJ67000	7/15/2021	Lead				1	Copper				0	145	W LAKEVIEW AVE	FLINT	48503
LJ66999	7/15/2021	Lead				2	Copper				60	145	W LAKEVIEW AVE	FLINT	48503
LJ67004	7/15/2021	Lead				0	Copper				0	520	W THIRD ST	FLINT	48503
LJ67003	7/15/2021	Lead				2	Copper				0	520	W THIRD ST	FLINT	48503
LJ75056	8/26/2021	Lead	1	0	0		Copper	0	0	0		1501	WABASH AVE	FLINT	48504
LJ67630	7/20/2021	Lead				0	Copper				0	2007	WEAVER ST	FLINT	48506
LJ67629	7/20/2021	Lead				1	Copper				0	2007	WEAVER ST	FLINT	48506
LJ73538	8/19/2021	Lead				0	Copper				0	509	WELCH BLVD	FLINT	48503
LJ73539	8/19/2021	Lead				0	Copper				0	509	WELCH BLVD	FLINT	48503
LJ65559	7/8/2021	Lead				0	Copper				0	1920	WELCH BLVD	FLINT	48504
LJ65560	7/8/2021	Lead				0	Copper				0	1920	WELCH BLVD	FLINT	48504
LJ84930	10/18/2021	Lead	1	2	2		Copper	120	90	100		1827	WILLOW BROOK CIRCLE	FLINT	48507

Notes:

ppb = parts per billion

**Flint Residential and Business Testing Report - results collected July 1, 2021 through December 13, 2021**

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				

Lead values exceeding 15 ppb and Copper results exceeding 1,300 are highlighted in red.

Sample results of "Not Detected" have been replaced with a numerical value of zero for ease of sorting.

Samples without a zip code did not have one provided on the accompanying paperwork.

\*\*\* indicate Invalid Zip Code