



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

February 16, 2023

Mr. Dana Hostetler
Romanoff Electric Co., LLC
506 River Road
Maumee, OH 43537

FINAL DECISION OF THE ELECTRICAL ADMINISTRATIVE BOARD

On January 25, 2023, the Construction Code Commission reviewed the Application for Construction Code Appeal submitted by Romanoff Electric Co., LLC for Custer I Elementary School, 5003 West Albain Road, Monroe, MI; Monroe County. Romanoff Electric Co., LLC requested exception to Articles 392.10(B)(1) and 392.46 of the 2017 Michigan Electrical Code. The application and all supplemental materials were reviewed by the Commission. The Commission, then, referred the appeal to the Electrical Administrative Board. This final decision is issued pursuant to Section 15 of 1972 PA 230.

FINDINGS AND CONCLUSIONS: Notification was made to Mr. Dana Hostetler on February 9, 2023, that this matter would be addressed by the Electrical Administrative Board at the meeting on February 9, 2023. The Board acknowledged receipt and reviewed the material on this matter at the meeting on February 9, 2023. Messers. Jerry Oley, Director of Operations for Monroe Public Schools, Justin Heller, Engineer, Rob Gaven, Attorney, and Mister Wright, Romanoff Electric Co., LLC attended the meeting and provided testimony to the Board. Following discussion, the Board moved to approve Mr. Hostetler's (a) variance request for single conductor cable installation due to the unique design of the structure and for the reasons outlined in Mr. Robert Gavin's November 25, 2022 letter specifically at Page 56 of the Board's packet showing all items have been satisfied, and (b) variance request for stove piping installation due to the unique design of the structure and for the reasons outlined in Mr. Robert Gavin's November 25, 2022 letter specifically at Pages 58-59 of the Board's packet showing all items have been satisfied pursuant to MCL 125.1515.

THEREFORE, it is the final decision of the Electrical Administrative Board to approve Mr. Hostetler's variance requests pursuant to MCL 125.1515 for relief from the requirements of Articles 392.10(B)(1) and 392.46 of the 2017 Michigan Electrical Code for Custer I Elementary as specified above. A person aggrieved by this decision may petition the Construction Code Commission to review the decision, as provided in MCL 125.1516.

cc: BCC Electrical Section