



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

MARLON BROWN  
DIRECTOR

April 22, 2024

Daniel Kohler  
Duane Waters Health Center  
Duane Waters Health Center Building  
Unit C  
3857 Cooper St.  
Jackson MI 49201

### **DECISION OF THE ELEVATOR SAFETY BOARD**

On September 19, 2023, the Elevator Safety Board reviewed the variance request for Daniel Kohler on behalf of Duane Waters Health Center – Department of Corrections located at 3857 Cooper St. Jackson MI 49201 for relief from the requirements of the American Society of Mechanical Engineers (ASME) A17.1.1-2010, Sections 2.2.2.3 through 2.2.2.6. This decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

**FINDINGS AND CONCLUSIONS:** Notification was made to Daniel Kohler on September 15, 2023, that this matter would be addressed by the Elevator Safety Board at the meeting on September 19, 2023. The Board acknowledged receipt and reviewed the material on the matter at the meeting on September 19, 2023. Daniel Kohler, Hobbs & Black Architects, appeared before and presented to the board. Following discussion, the Board moved to approve Daniel Kohler's variance request to the Bureau of Construction Codes for Duane Waters Health Center with conditions that a float switch be added and the car to be able to move away from a lower level in case of a flood.

**THEREFORE,** it is the final decision of the Elevator Safety Board to approve the variance request for recommission for Duane Waters Health Center. This final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board act, 1967 PA 227. A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306.

cc: BCC - Elevator Section



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

MARLON BROWN  
DIRECTOR

April 22, 2024

Brent Bauer  
Project Manager  
MSU Student Services Unit C  
556 E. Circle Dr #237  
East Lansing MI 48824

### **DECISION OF THE ELEVATOR SAFETY BOARD**

On September 19, 2023, the Elevator Safety Board reviewed the variance request for Michigan State University, Student Services Building – Car 2 located at 556 E. Circle Drive, #237, East Lansing, MI 48824 for relief from the requirements of the American Society of Mechanical Engineers (ASME) A17.1-2010, Section 2.2.2.5. This decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

**FINDINGS AND CONCLUSIONS:** Notification was made to Brent Bauer on September 15, 2023, that this matter would be addressed by the Elevator Safety Board at the meeting on September 19, 2023. The Board acknowledged receipt and reviewed the material on the matter at the meeting on September 19, 2023. Brent Bauer, Elevator Service, appeared before and presented to the board. Following discussion, the Board moved to approve the variance request for Michigan State University, Student Services Building – Car 2 with the recommendation that a float switch be added, the car to be able to move away from a lower level in case of flood, and then, be removed. from service until the situation is corrected.

**THEREFORE,** it is the final decision of the Elevator Safety Board to approve the variance request for relief for Michigan State university Student Services . This final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board act, 1967 PA 227. A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306.

cc: BCC - Elevator Section



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

MARLON BROWN  
DIRECTOR

April 22, 2024

Mr. Brent Bauer  
Project Manager  
MSU Student Services Unit C  
556 E. Circle Dr #237  
East Lansing MI 48824

### **DECISION OF THE ELEVATOR SAFETY BOARD**

On September 19, 2023, the Elevator Safety Board reviewed the variance request for Michigan State University, Student Services Building – Car 2 located at 556 E. Circle Drive, #237, East Lansing, MI 48824 for relief from the requirements of the American Society of Mechanical Engineers (ASME) A17.1-2010, Section 2.2.2.5. This decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

**FINDINGS AND CONCLUSIONS:** Notification was made to Brent Bauer on September 15, 2023, that this matter would be addressed by the Elevator Safety Board at the meeting on September 19, 2023. The Board acknowledged receipt and reviewed the material on the matter at the meeting on September 19, 2023. Brent Bauer, Elevator Service, appeared before and presented to the board. Following discussion, the Board moved to approve the variance request for Michigan State University, Student Services Building – Car 2 with the recommendation that a float switch be added, the car to be able to move away from a lower level in case of flood, and then, be removed. from service until the situation is corrected.

**THEREFORE,** it is the final decision of the Elevator Safety Board to approve the variance request for relief for Michigan State university Student Services . This final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board act, 1967 PA 227. A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306.

cc: BCC - Elevator Section



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

MARLON BROWN  
DIRECTOR

April 22, 2024

Johnny Stockstill  
TK Elevator  
35432 Industrial Rd  
Livonia MI 48750

### **DECISION OF THE ELEVATOR SAFETY BOARD**

On September 19, 2023, the Elevator Safety Board reviewed the variance request Johnny Stockstill's variance request for TK Elevator located at 35432 Industrial Rd, Livonia MI 48750 for relief from the requirements of the Michigan Elevator Rules, R408.7041. This decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

**FINDINGS AND CONCLUSIONS:** Notification was made to Johnny Stockstill on September 15, 2023, that this matter would be addressed by the Elevator Safety Board at the meeting on September 19, 2023. The Board acknowledged receipt and reviewed the material on the matter at the meeting on September 19, 2023. Johnny Stockstill and Neil Palazzolo, TK Elevator, appeared before and presented to the Board. Following discussion, the Board moved to deny the variance request for TK Elevator as submitted and maintain Rule 41 of the State Code removing machinery from the travel of the elevator.

THEREFORE, it is the final decision of the Elevator Safety Board to deny the variance request for relief for TK Elevator. This final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board act, 1967 PA 227. A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306.

cc: BCC - Elevator Section