



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA.
DIRECTOR

March 21, 2024

Caroline West
University of Michigan
1540 East Hospital Dr
Ann Arbor, MI 48104

DECISION OF THE ELEVATOR SAFETY BOARD

On March 19, 2024, the Elevator Safety Board was presented with a variance request for CS Mott Childrens Hospital located at 1540 East Hospital Drive, Ann Arbor, Michigan 48104 for relief from the requirements of American Society of Mechanical Engineers (ASME) 2.5.1.4 and ASME 2.27 .3.1 Notification was made on March 15, 2024, to Caroline West that this matter would be addressed by the Board at the meeting on March 19, 2024. The board acknowledged receipt of the request on March 19, 2024, reviewed the application and all supplemental materials provided, and considered the matter at a public meeting on that date. The final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

Following discussion, a motion was made and supported and passed unanimously to recommend denial of the variance request for CS Motts Children's hospital due to several code violations.

THEREFORE, it is the final decision of the Elevator Safety Board to recommend denial to the Bureau of Construction Codes of Caroline West's variance request from the requirements of ASME 2.5.1.4 and ASME 2.27 .3.1 of the American Society of Mechanical Engineers (ASME) A17.1-2010 as specified above.

A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306, MCL 24.201 *et seq.*

cc: BCC - Elevator Section



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA.
DIRECTOR

March 21, 2024

Christopher Gustafson
KONE Elevator
5300 Clay Avenue SW
Grand Rapids, MI 49548

DECISION OF THE ELEVATOR SAFETY BOARD

On March 19, 2024, the Elevator Safety Board was presented with a variance request for East Lansing Parking 037847 located at 121 Charles Street, East Lansing, Michigan 48823 for relief from the requirements of American Society of Mechanical Engineers (ASME) A17.1 2.2.2.5. Notification was made to Christopher Gustafson on March 15, 2024, that this matter would be addressed by the Board at the meeting on March 19, 2024. The Board acknowledged receipt of the request on March 19, 2024, reviewed the application and all supplemental materials provided, and considered the matter at a public meeting on that date. This final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

Following discussion, a motion was made, supported, and passed unanimously to recommend approval for the variance request for relief from the requirements of A17.1 2.2.2.5 with the condition that there will be no alterations made to the pit of the elevator.

THEREFORE, it is the final decision of the Elevator Safety Board to recommend that the Bureau of Construction Codes grant relief for Christopher Gustafson's variance request from the requirements of A17.12.2.2.5 of the American Society of Mechanical Engineers (ASME) A17.1-2010 as specified above. A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306, MCL 24.201 *et seq.*

cc: BCC - Elevator Section



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA.
DIRECTOR

March 20, 2024

Mr. Christopher Gustafson
KONE Elevator
5300 Clay Avenue SW
Grand Rapids, MI 49548

DECISION OF THE ELEVATOR SAFETY BOARD

On March 19, 2024, the Elevator Safety Board reviewed the variance request 037848 for East Lansing Charles Street Parking located at 121 Charles Street, East Lansing Michigan 48823 for relief from the requirements of A17.1 2.2.2.5 requiring a sump pump submitted by Christopher Gustafson. Notification was made to Mr. Gustafson that this matter would be addressed by the Elevator Safety Board at the meeting on March 19, 2024. The Board acknowledged receipt of the request on March 19, 2024, reviewed the application and all supplemental materials provided, and considered the matter at a public meeting on that date. This final decision is issued pursuant to Section 8(1)(c) of the Elevator Safety Board Act, 1967 PA 227.

Following discussion, a motion was made, supported, and passed unanimously to recommend approval for the variance request for relief from the requirements of A17.1 2.2.2.5 requiring a sump pump with the condition that there will be no alterations made to the pit of the elevator.

THEREFORE, it is the final decision of the Elevator Safety Board to recommend that the Bureau of Construction Codes grant relief for Mr. Gustafson's variance request from the requirements of A 17.12225 of the American Society of Mechanical Engineers (ASME) A17.1-2010 as specified above. A judicial review of this decision may be requested in accordance with the Administrative Procedures Act, 1969 PA 306, MCL 24.201 *et seq.*

cc: BCC - Elevator Section