

Test Report of Elevators

**Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes / Elevator Section
P.O.Box 30254, Lansing, MI 48909 517-241-9337**

STATE SERIAL NUMBER

BCC-3401 (8/22)

Authority: 1967 PA 227
Completion: Mandatory
Penalty: \$50.00 (MCL408.821(1))

YOU MUST COMPLETE THIS FORM AND RETURN IT TO THE ABOVE ADDRESS WITHIN 30 DAYS OF THE TEST IN ORDER TO RETAIN AUTHORIZATION TO PERFORM THE TESTS AS REQUIRED BY ASME A17.1, SECTION 8.6, R408.7059, R408.7060, AND R408.7007

LOCATION NAME:		CITY	
LOCATION ADDRESS			ZIP CODE
TYPE OF ELEVATOR: P ___ F ___ OTHER ___	MACHINE TYPE: CABLE ___ DIRECT PLUNGER ___ ROPED HYDRAULIC ___ OTHER ___	TYPE OF SAFETY: A ___ B ___ C ___ BROKEN ROPE: ___ RELIEF VALVE: ___	BUFFER TYPE: _____ CAR: ___ COUNTERWEIGHT: ___
LOCATION OF SAFETY DEVICES: COUNTERWEIGHT ___ CROSSHEAD ___ SAFETY PLANK ___ CYLINDER ___	GUIDERAIL THICKNESS: _____	DISTANCE BETWEEN RAIL GRIPPING FACES OF SAFETIES: _____	CAPACITY: _____ SPEED: _____
EMPTY UP:	EMPTY DOWN:	FULL LOAD UP:	FULL LOAD DOWN: CATEGORY TEST TYPE:

ELECTRIC ELEVATOR REQUIREMENTS SECTION (CAT 1 - 8.6.4.19 AND CAT 5 - 8.6.4.20)

OIL BUFFERS	8.6.4.19.1	BROKEN SUSPENSION/RESIDUAL STRENGTH	8.6.4.19.13
SAFETIES	8.6.4.19.2	CAR & CWT SAFETIES	8.6.4.20.1
GOVERNORS	8.6.4.19.3	GOVERNORS	8.6.4.20.2
SLACK-ROPE DEVICES ON DRUM MACHINES	8.6.4.19.4	OIL BUFFERS	8.6.4.20.3
NORMAL AND FINAL STOPPING DEVICES	8.6.4.19.5	BRAKING SYSTEM	8.6.4.20.4
FIREFIGHTERS' EMERGENCY OPERATION	8.6.4.19.6	EMERGENCY AND STANDBY POWER OPERATION	8.6.4.20.5
STANDBY OR EMERGENCY POWER OPERATION	8.6.4.19.7	EMERGENCY TERM. STOPPING/SPEED-LIMITING DEVICES	8.6.4.20.6
POWER OPERATION OF DOOR SYSTEM	8.6.4.19.8	POWER OPENING OF DOORS	8.6.4.20.7
BROKEN ROPE, TAPE, OR CHAIN SWITCH	8.6.4.19.9	LEVELING ZONE/SPEED	8.6.4.20.8
E/E/PES PROTECTIVE DEVICES	8.6.4.19.10	INNER LANDING ZONE	8.6.4.20.9
ASCENDING OS/UNINTENDED MOVEMENT	8.6.4.19.11	EMERGENCY STOPPING DISTANCE	8.6.4.20.10
TRACTION-LOSS DETECTION MEANS	8.6.4.19.12	EMERGENCY BRAKE	8.6.4.20.11
		DRIVE SHEAVES/NON-METALLIC GROOVE & STEEL ROPES	8.6.4.21

HYDRAULIC ELEVATOR REQUIREMENTS SECTION (CAT 1 - 8.6.5.14, CAT 3 - 8.6.5.15, AND CAT 5 - 8.6.5.16)

RELIEF VALVE SETTING AND PRESSURE TEST	8.6.5.14.1	PRESSURE SWITCH	8.6.5.14.5
HYDRAULIC CYLINDERS/PRESSURE PIPING	8.6.5.14.2	POWER OPERATION OF DOOR SYSTEM	8.6.5.14.6
NORMAL TERMINAL STOPPING DEVICES	8.6.5.14.3(a)	SLACK-ROPE DEVICE	8.6.5.14.7
GOVERNORS	8.6.5.14.3(b)	UNEXPOSED PORTIONS OF PISTONS	8.6.5.15.1
SAFETIES	8.6.5.14.3(c)	PRESSURE VESSELS	8.6.5.15.2
OIL BUFFERS	8.6.5.14.3(d)	3-YEAR PRVT (R408.7060)	8.6.5.15.3
FIREFIGHTERS' EMERGENCY OPERATION	8.6.5.14.3(e)	GOVERNORS, SAFETIES, AND OIL BUFFERS	8.6.5.16.1
STANDBY OR EMERGENCY POWER OPERATION	8.6.5.14.3(f)	COATED ROPES	8.6.5.16.2
POWER OPERATIONS OF DOOR SYSTEM	8.6.5.14.3(g)	WIRE ROPE FASTENINGS	8.6.5.16.3
EMERGENCY TERMINAL AND STOPPING DEVICES	8.6.5.14.3(h)	PLUNGER GRIPPER	8.6.5.16.4
LOW OIL PROTECTION	8.6.5.14.3(i)	OVERSPEED VALVE	8.6.5.16.5
FLEXIBLE HOSE AND FITTING ASSEMBLIES	8.6.5.14.4	FREIGHT ELEVATOR CLASS C2 LOADING	8.6.5.16.6
WORKING PRESSURE:		BY-PASS PRESSURE:	

ALL FIELDS MUST BE MARKED P-PASS, F-FAIL, NA-IF DEVICE IS NOT PROVIDED OR TEST IS NOT DUE

DID THE UNIT PASS ALL TESTING REQUIREMENTS PRIOR TO BEING RETURNED TO SERVICE? () YES, () NO

COMMENTS

TESTING COMPANY	SIGNATURE	LIC#	DATE
-----------------	-----------	------	------