Proposed Revisions to Reliability Metrics

MI Power Grid Financial Incentive/Disincentive Workgroup

November 30, 2023

Presentation Agenda

- Review stakeholder feedback
- Discuss key objectives of revisions
- Summary of revisions
- Review proposed reliability performance metrics
- Q&A

Summary of Stakeholder Feedback

- Address reliability performance
 - Different perspectives on downside only vs. symmetric incentives
- Complement Service Quality Rules
- Implement incentives/disincentives through stakeholder process
 - Prioritizing reliability with pace of implementation and scope of Reliability + framework
- Address equity in reliability metrics

Key Objectives with Proposed Revisions

- Prioritize reducing outage duration and improving storm response
- Maintain focus on customer-level outcomes
- Incorporate stakeholder feedback in revisions
- Balance incentives/penalties to improve reliability and prioritize investment
- Reduce complexity where possible
- Clarify how reliability metrics address equity

Summary of Major Proposed Revisions to Reliability Metrics

| | | | Target Performance | Potential Incentive/Disincentive | |
|-------------------|----------|-------------------|---------------------|----------------------------------|--|
| Metric | Baseline | | | Wechanism | |
| | | Penalty Threshold | Incentive Threshold | Long-Term Goal | |
| | | | | | |
| SAIDI | | | | | |
| (Excluding MEDs) | | | | | |
| | | | | | |
| SAIDI | | | | | |
| (All weather) | | | | | |
| Storm Restoration | | | | | |
| (48-hour storm | | | | | |
| response) | | | | | |
| Worst performing | | | | | |
| circuite | | | | | |
| circuits | | | | | |
| | | | | | |

1) Modify outage duration metrics

- SAIDI (excluding MEDs) and SAIDI (all weather) replace CAIDI metrics; include 48-hour storm response
- 2) Reduce complexity
 - Prioritize SAIDI over SAIFI
 - CEMI removed from these metrics but penalties (bill credits) remain in Service Quality Rules

Summary of Major Proposed Revisions to Reliability Metrics

| | | | Target Performance | Potential Incentive/Disincentive | |
|-------------------|----------|-------------------|---------------------|----------------------------------|------------|
| Metric | Baseline | | | | Wiethanism |
| | | Penalty Threshold | Incentive Threshold | Long-Term Goal | |
| | | | | | |
| SAIDI | | | | | |
| (Excluding MEDs) | | | | | |
| | | | | | |
| SAIDI | | | | | |
| (All weather) | | | | | |
| (5-yr average) | | | | | |
| Storm Restoration | | | | | |
| (48-hour storm | | | | | |
| response) | | | | | |
| Worst performing | | | | | |
| circuits | | | | | |
| | | | | | |

3) Total incentive potential based on maximum customer impact of \$10/year

- Caps incentives customers pay to improve grid and penalties paid by shareholders
- DTE \$23 million/yr. and CE \$19 million/yr.
- 4) Incentive allocation addresses today's priorities
 - 60% for SAIDI metrics (30% each), 20% storm restoration, and 20% for worst performing circuit
 - Performance incentives/penalties assessed independently of Service Quality Rules
- 5) Penalty threshold = 5% cumulative reduction over 5 years; Incentive threshold = 10% cumulative reduction over 5 years
 - 1 st. dev. deadband proposed for SAIDI metrics; linear glidepath for interim years
 - 1 st. dev. range for penalty/incentive for SAIDI metrics

SAIDI Metrics Need to Address Recent Trends

1) Different SAIDI (excl MEDs) trends for DTE and CE Influence Baselines

- DTE increasing from 2021-2023
- CE decreasing from 2021-2023
- ComEd baseline set at minimum 2 of past 3 years





CE SAIDI (excluding MEDs) 2012 - 2023

SAIDI Metrics Need to Address Recent Trends

- 2) High SAIDI (all weather) in 2023 YTD
 - DTE reported exceptionally high SAIDI
 - CE also appears to be trending high
 - Revision includes deadband to address high variability and increase in baseline





SAIDI (excl MEDs) Metric Incentivizes Median Performance

| | | | Target Performance | Potential Incentive/Disincentive | |
|--|--|--|---|--|---|
| Metric | Baseline | Penalty Threshold | Incentive Threshold | Long-Term Goal | Wiethanism |
| SAIDI (Excluding MEDs) | Average of lowest 2 years from 2021-2023 DTE(2023) ¹ :141 CE (2023): 180 | SAIDI > 5% reduction from baseline over 5 years (linear glidepath) | 1 st. dev. deadband + SAIDI < 10% reduction from baseline over 5 years (linear glidepath) | 129 (2022 5-yr historical average of Industry median in 5 years) | Symmetric incentive/disincentive Max incentive/penalty scales linearly over 1 SD range 30% of incentive/disincentive pool (DTE ~ \$6.9 million, CE ~ \$5.7 million) |
| SAIDI (All weather) (5-yr average) | | | | | |
| Storm Restoration (48-hour storm response) | | | | | |
| Worst performing circuits | | | | | |





SAIDI (all weather) Metric Proposes to Alter Increasing Trend

| | | | Target Performance | Potential Incentive/Disincentive | |
|--|---|--|---|--|---|
| Metric | Baseline | Penalty Threshold | Incentive Threshold | Long-Term Goal | Wiechanisin |
| SAIDI (Excluding MEDs) | Average of lowest 2 years from 2021-2023 DTE(2023) ¹ :141 CE (2023): 180 | SAIDI > 5% reduction from baseline over 5 years (linear glidepath) | 1 st. dev. deadband + SAIDI < 10% reduction from baseline over 5 years (linear glidepath) | 129 (2022 5-yr historical average of Industry median in 5 years) | Symmetric incentive/disincentive Max incentive/penalty scales linearly over 1 SD range 30% of incentive/disincentive pool (DTE ~ \$6.9 million, CE ~ \$5.7 million) |
| SAIDI (All weather) (5-yr average) | 5-yr historical average DTE (2022): 563 DTE(2023 YTD) ^{2:} 770 CE (2022): 597 CE(2023 est.) ³ : 773 | SAIDI > 5% reduction from baseline over 5 years (linear glidepath) | 1 st. dev. deadband + SAIDI < 10% reduction from baseline over 5 years (linear glidepath) | 250 (2nd/3rd quartile) 5yr-average value = 375 | Symmetric incentive/disincentive Max incentive/penalty scales linearly over 1 SD range 30% of incentive/disincentive pool (DTE ~ \$6.9 million, CE ~ \$5.7 million) |
| Storm Restoration (48-hour storm response) | | | | | |
| Worst performing circuits | | | | | |

Notes: 1 – Based on DTE 2023 goal of 150 mins. Actual YTD currently trending higher. 2 – Based on DTE YTD results for SAIDI (all weather) – 1521 mins. 3 – Based on CE estimated YTD results for SAIDI (all weather) – 1287 mins.





Storm Restoration and Circuit-Level Metrics Address Priority Improvement Areas

| | | | Target Performance | Potential Incentive/Disincentive | |
|--|--|--|--|---------------------------------------|---|
| Metric | Baseline | Penalty Threshold | Incentive Threshold | Long-Term Goal | Wiechanism |
| SAIDI (Excluding MEDs) | | | | | |
| SAIDI (All weather) (5-yr average) | | | | | |
| Storm Restoration (48-hour storm response) | 80% by 2024 DTE and CE report ≈76% YTD in 2023 Recent DTE trend: 5% improvement/yr | 1% improvement/yr. from baseline over 5 years | Exceed recent improvement trend (5%/yr) from baseline to 90% | Early compliance with 90% standard | Symmetric incentive/disincentive Account for 20% of incentive/disincentive pool (DTE ~ \$4.6 million, CE ~ \$3.8 million) Incentive scaled from threshold to 90% Penalty scaled from threshold to 80% |
| Worst performing circuits | Reviewing historical top 10 rankings | Circuits ranked by SAIDI (exc MEDs) No circuits remain in top 10 for more than 2 of past 5 years | N/A | N/A | Penalty only but not bill credit Seeking feedback on system- or circuit-level metric Account for 20% of disincentive pool (DTE ~ \$4.6 million, CE ~ \$3.8 million) |



Worst Performing Circuits

Definition

Penalty triggered if a circuit is in Top 10 worst performing list for 3 years out of 5

Key Considerations

- Circuits ranked by SAIDI (excluding MEDs)
- Address circuits with persistent reliability problems
- Seeking stakeholder feedback on system- vs. circuitlevel focus
- Will review historical data to identify geographic patterns
- Penalty triggered if circuit meets criteria

DTE 2022 Report

2A. Reliability Performance - 5 Worst Performing SAIDI Circuits - System Basis

| | Circuit Name and Number | Substation | Location | Circuit Miles | Customers Served | SAIDI All Wthr Sys Basis | SAIDI ex MEDs Sys Basis | SAIDI All Wthr Cct Basis | SAIDI ex MEDs Cct Basis | Last Tree Trimming |
|---|----------------------------|------------|---------------------|------------------|---------------------|--------------------------------|-------------------------------|--------------------------------|-------------------------------|-----------------------|
| 1 | CONRD8130 | Conrad | Howell Twp | 153.3 | 2,688 | 4.58 | 0.35 | 3814.59 | 288.62 | 2021 |
| 2 | SLOAN8524 | Sloan | Sterling Heights | 23.4 | 2,560 | 3.98 | 0.11 | 3487.61 | 93.70 | 2015 |
| 3 | PROUD9475 | Proud | Milford Twp | 59.9 | 3,259 | 3.79 | 0.31 | 2608.59 | 210.82 | 2014 |
| 4 | AKRON9000 | Akron | Novi | 38.3 | 3,442 | 3.41 | 0.11 | 2220.86 | 69.41 | 2014 |
| 5 | LOMRD8516 | Lombard | Warren | 16.9 | 2,124 | 3.30 | 0.29 | 3480.14 | 307.37 | 2014 |

| Key Parameters | DTE | CE |
|--------------------|------------------|------------------|
| Baseline | N/A | N/A |
| Penalty Allocation | 20% (\$4.6 M) | 20% (\$3.8 M) |

CE 2022 Report

| | 10 Worst SAIDI Performing Circuits for 2022 | | | | | | | | | |
|---------------------------------|---|-----------|------------------------------|----------------------------|----------------|-------------------------------|-------------------|-------------------------------------|---|---|
| Circuit SAIDI Excluding MEDs | Circuit SAIFI Excluding MEDs | Feeder ID | Substation/Circuit | Service Center Location | Length (Miles) | Number of Customers Served | Last Circuit Trim | Number of Customer Interruptions | Outage Causes | Corrective Action Plan to Improve Performance |
| 1987 | 7.99 | 42301 | GERRISH/ LEGION | West Branch | 105 | 2153 | 2017 | 17199 | Equipment Failure and Trees | 2022 - Forestry Zone Clearing 2022 - 2023 - HVD Line Projects 2022 - Substation Projects 2022 - 2024 - LVD Line Projects |
| 1786 | 4.25 | 151602 | HUBBARD LAKE/ MILLER ROAD | Tawas | 68 | 633 | 2017 | 2693 | Weather, No Specific Cause Found, and Trees Outside ROW | 2024 - LVD Line Project |

Summary Table of Revised Reliability Metrics

| | | | Target Performance | Potential Incentive/Disincentive | |
|---|---|--|---|--|---|
| Metric | Baseline | Penalty Threshold | Incentive Threshold | Long-Term Goal | Mechanism |
| SAIDI (Excluding MEDs) | Average of lowest 2 years from 2021-2023 DTE(2023) ¹ :141 CE (2023): 180 | SAIDI > 5% reduction from baseline over 5 years (linear glidepath) | 1 st. dev. deadband + SAIDI < 10% reduction from baseline over 5 years (linear glidepath) | 129 (2022 5-yr historical average of Industry median in 5 years) | Symmetric incentive/disincentive Max incentive/penalty scales linearly over 1 SD range 30% of incentive/disincentive pool (DTE ~ \$6.9 million, CE ~ \$5.7 million) |
| SAIDI (All weather) (5-yr average) | 5-yr historical average DTE (2022): 563 DTE(2023 YTD) ^{2:} 770 CE (2022): 597 CE(2023 est.) ³ : 773 | SAIDI > 5% reduction from baseline over 5 years (linear glidepath) | 1 st. dev. deadband + SAIDI < 10% reduction from baseline over 5 years (linear glidepath) | 250 (2nd/3rd quartile) 5yr-average value = 375 | Symmetric incentive/disincentive Max incentive/penalty scales linearly over 1 SD range 30% of incentive/disincentive pool (DTE ~ \$6.9 million, CE ~ \$5.7 million) |
| Storm Restoration (48-hour storm response) | 80% by 2024 DTE and CE report 76% YTD in 2023 Recent trend: 5% improvement/yr | 1% improvement/yr. from baseline over 5 years | Exceed recent improvement trend (5%/yr) from baseline to 90% | Early compliance with 90% standard | Symmetric incentive/disincentive Account for 20% of incentive/disincentive pool (DTE ~ \$4.6 million, CE ~ \$3.8 million) Incentive scaled from threshold to 90% Penalty scaled from threshold to 80% |
| Worst performing circuits | Reviewing historical top 10 rankings | Circuits ranked by SAIDI (exc MEDs) No circuits remain in top 10 for more than 2 of past 5 years | N/A | N/A | Penalty only but not bill credit Seeking feedback on system- or circuit-level metric Account for 20% of disincentive pool (DTE ~ \$4.6 million, CE ~ \$3.8 million) |

Notes:

1 – Based on DTE 2023 goal of 150 mins. Actual YTD currently trending higher. 2 – Based on DTE YTD results for SAIDI (all weather) – 1521 mins.

3 – Based on CE estimated YTD results for SAIDI (all weather) – 1287 mins.

Equity Considerations

- Partially addressed w/ Service Quality Rules and Bill Credits
 - Includes CEMI, CELID, and Outage duration metrics
- Improving outage/storm response metrics reduces outage burden on IQ/DI Communities
- Circuit-level metric intended to address equity
- Utility metric reporting on circuit, census tract, and ZIP Code basis under Case No. U-21122 can be combined with work to identify environmental justice communities under SB 271 to further evaluate equity impacts
- Next Reliability + metrics will also address equity

Procedural/Ratemaking Considerations

- Incentive/Disincentive metrics implemented through contested case proceeding
- Conduct a review every two years
- "Offramp" mechanism should be included
 Scope of offramp mitigated by initial review cycle
- Incentives/disincentives tracked in regulatory asset
- Next Reliability + metrics can build on initial steps

Topics for Discussion

- Feedback on revised metrics
- Incentive/disincentive potential
 - Allocation by metric
 - Symmetric incentives for SAIDI and storm response metrics
- Focus area for worst performing circuit metric (system- vs. circuit-level)
- Other areas of interest to stakeholders

Backup Slides

System Average Interruption Duration Index (SAIDI excluding MEDs)

Definition

Total amount of time average customer experiences a sustained interruption in a year excluding Major Event Days

Key Considerations

- Baseline uses avg. of lowest 2 yrs. from 2021-2023 to reflect recent improvements
- Long-term goal at median performance in IEEE benchmarking study
- Incentive/penalty scales linearly over 1 st. dev. range

| Key Parameters | DTE | CE |
|----------------------------------|------------------|------------------|
| Baseline (est. 2023) | 141 | 180 |
| 5% Improvement Target | 134 | 171 |
| 10% Improvement Target | 127 | 162 |
| Long-Term Goal | 129 | 129 |
| 1 Standard Deviation (2012-2023) | 22 | 23 |
| Max Incentive/Penalty Allocation | 30% (\$6.9 M) | 30% (\$5.7 M) |

DTE SAIDI (excl MEDs) Incentive/Penalty Mechanism

| Year | Penalty | No Penalty/Incentive | Incentive |
|------|------------|----------------------|------------|
| 1 | >162 - 140 | 140 - 116 | 116 – 93 > |
| 2 | >161 - 138 | 138 – 113 | 113 – 91 > |
| 3 | >159 - 137 | 137 – 110 | 110 - 88 > |
| 4 | >158 - 135 | 135 – 107 | 107 – 85 > |
| 5 | >156 - 134 | 134 – 105 | 105 – 82 > |

CE SAIDI (excl MEDs) Incentive/Penalty Mechanism

| Year | Penalty | No Penalty/Incentive | Incentive |
|------|------------|----------------------|-------------|
| 1 | >202 - 178 | 178 – 153 | 153 – 130 > |
| 2 | >200 - 176 | 176 – 149 | 149 – 126 > |
| 3 | >198 – 175 | 175 – 146 | 146 – 123 > |
| 4 | >196 - 173 | 173 – 142 | 142 – 119 > |
| 5 | >194 - 171 | 171 – 139 | 139 – 115 > |

System Average Interruption Duration Index (SAIDI all weather)

Definition

Total amount of time average customer experiences a sustained interruption in a year under all weather conditions

Key Considerations

- Metric uses 5-yr average of SAIDI (all weather)
- Baseline uses 5-yr historical average to reflect recent improvements
- Long-term goal at median performance in IEEE benchmarking study
- Incentive/penalty scales linearly over 1 st. dev. range
- Includes a 1 st. dev. deadband to address variability

| Key Parameters | DTE | CE |
|---|------------------|------------------|
| Baseline 5-yr avg. (est. 2023) | 770 | 773 |
| 5% Cumulative Improvement | 39 mins | 39 mins |
| 10% Cumulative Improvement | 77 mins | 77 mins |
| Long-Term Goal | 250 | 250 |
| 1 Standard Deviation 5-yr avg. (2016-2023) | 95 | 106 |
| Max Incentive/Penalty Allocation | 30% (\$6.9 M) | 30% (\$5.7 M) |

DTE SAIDI (all weather) Incentive/Penalty Mechanism

| Year | Penalty | No Penalty/Incentive | Incentive |
|------|------------|----------------------|-------------|
| 1 | >857 – 762 | 762 – 660 | 660 – 565 > |
| 2 | >850 - 755 | 755 – 644 | 644 – 549 > |
| 3 | >842 - 747 | 747 – 629 | 629 – 534 > |
| 4 | >834 - 739 | 739 – 613 | 613 – 518 > |
| 5 | >827 - 732 | 732 – 598 | 598 – 503 > |

CE SAIDI (all weather) Incentive/Penalty Mechanism

| Year | Penalty | No Penalty/Incentive | Incentive |
|------|------------|----------------------|-------------|
| 1 | >872 – 765 | 765 – 651 | 651 – 545 > |
| 2 | >864 - 758 | 758 – 636 | 636 – 530 > |
| 3 | >856 – 750 | 750 – 620 | 620 – 514 > |
| 4 | >849 - 742 | 742 – 605 | 605 – 499 > |
| 5 | >841 - 735 | 735 – 590 | 590 – 483 > |

48 Hour Storm Response

| <u>Definition</u> | Key Parameters | DTE/CE | |
|--|----------------------------------|---|--|
| Percentage of customers restored within 48 hours of a | 2024 Baseline | 80% | |
| catastrophic event | Penalty Threshold | 1%/yr | |
| Key Considerations | Incentive Threshold | 5%/yr | |
| 2023 YTD for DTE and CE is 76% Penalty threshold reflects DTE proposal Incentive threshold accelerates compliance to 90% Penalty linearly scaled from 80% Incentive linearly scaled to 90% | Long-Term Goal | 90+% | |
| | Max Incentive/Penalty Allocation | 20% (DTE - \$4.6 M, CE - \$3.8 M) | |

DTE and CE 48 Hour Storm Response Incentive/Penalty Mechanism

| Year | Penalty | Incentive | |
|------|---------|-----------|-------|
| 1 | < 81% | 81% - 85% | > 85% |
| 2 | < 82% | 82% - 90% | > 90% |
| 3 | < 83% | 83% - 90% | > 90% |
| 4 | < 84% | 84% - 90% | > 90% |
| 5 | <85% | 85% - 90% | > 90% |

Worst Performing Circuits

Definition

Penalty triggered if a circuit is in Top 10 worst performing list for 3 years out of 5

Key Considerations

- Circuits ranked by SAIDI (excluding MEDs)
- Address circuits with persistent reliability problems
- Seeking stakeholder feedback on system- vs. circuitlevel focus
- Will review historical data to identify geographic patterns
- Penalty triggered if circuit meets criteria

DTE 2022 Report

2A. Reliability Performance - 5 Worst Performing SAIDI Circuits - System Basis

| | Circuit Name and Number | Substation | Location | Circuit Miles | Customers Served | SAIDI All Wthr Sys Basis | SAIDI ex MEDs Sys Basis | SAIDI All Wthr Cct Basis | SAIDI ex MEDs Cct Basis | Last Tree Trimming |
|---|----------------------------|------------|---------------------|------------------|---------------------|--------------------------------|-------------------------------|--------------------------------|-------------------------------|-----------------------|
| 1 | CONRD8130 | Conrad | Howell Twp | 153.3 | 2,688 | 4.58 | 0.35 | 3814.59 | 288.62 | 2021 |
| 2 | SLOAN8524 | Sloan | Sterling Heights | 23.4 | 2,560 | 3.98 | 0.11 | 3487.61 | 93.70 | 2015 |
| 3 | PROUD9475 | Proud | Milford Twp | 59.9 | 3,259 | 3.79 | 0.31 | 2608.59 | 210.82 | 2014 |
| 4 | AKRON9000 | Akron | Novi | 38.3 | 3,442 | 3.41 | 0.11 | 2220.86 | 69.41 | 2014 |
| 5 | LOMRD8516 | Lombard | Warren | 16.9 | 2,124 | 3.30 | 0.29 | 3480.14 | 307.37 | 2014 |

| Key Parameters | DTE | CE |
|--------------------|------------------|------------------|
| Baseline | N/A | N/A |
| Penalty Allocation | 20% (\$4.6 M) | 20% (\$3.8 M) |

CE 2022 Report

| | 10 Worst SAIDI Performing Circuits for 2022 | | | | | | | | | |
|---------------------------------|---|-----------|------------------------------|----------------------------|----------------|-------------------------------|-------------------|-------------------------------------|---|---|
| Circuit SAIDI Excluding MEDs | Circuit SAIFI Excluding MEDs | Feeder ID | Substation/Circuit | Service Center Location | Length (Miles) | Number of Customers Served | Last Circuit Trim | Number of Customer Interruptions | Outage Causes | Corrective Action Plan to Improve Performance |
| 1987 | 7.99 | 42301 | GERRISH/ LEGION | West Branch | 105 | 2153 | 2017 | 17199 | Equipment Failure and Trees | 2022 - Forestry Zone Clearing 2022 - 2023 - HVU Line Projects 2022 - Substation Projects 2022 - 2024 - LVD Line Projects |
| 1786 | 4.25 | 151602 | HUBBARD LAKE/ MILLER ROAD | Tawas | 68 | 633 | 2017 | 2693 | Weather, No Specific Cause Found, and Trees Outside ROW | 2024 - LVD Line Project |