

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 506014	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 4/16/2024
NAME OF PROVIDER OR SUPPLIER MICHIGAN VETERANS HOME OF CHESTERFIELD TOWNSHIP			STREET ADDRESS, CITY, STATE, ZIP CODE 47901 SUGARBUSH RD CHESTERFIELD TOWNSHI, MI 48047		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E0000 SS=	Initial Comments On April 16, 2024, an Emergency Preparedness Survey was conducted by the Michigan Department of Licensing and Regulatory Affairs, Bureau of Survey and Certification. At the survey, Michigan Veteran's Home of Chesterfield Township was found in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR 483.73, Emergency Preparedness.	E0000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

04/24/2024

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 506014	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 4/16/2024
NAME OF PROVIDER OR SUPPLIER MICHIGAN VETERANS HOME OF CHESTERFIELD TOWNSHIP			STREET ADDRESS, CITY, STATE, ZIP CODE 47901 SUGARBUSH RD CHESTERFIELD TOWNSHI, MI 48047		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K0000 SS=	<p>INITIAL COMMENTS</p> <p>On April 16, 2024, a Life Safety Recertification Survey was conducted by the Michigan Department of Licensing and Regulatory Affairs, Bureau of Survey and Certification. At the survey, Michigan Veteran's Home of Chesterfield Township was found in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR 483.90(a), Life Safety from Fire and the applicable provisions of the 2012 Edition of the National Fire Protection Agency (NFPA) 101, Life Safety Code and the 2012 Edition of NFPA 99, Health Care Facilities Code.</p> <p>The facility is a 1- story building of Type II (111) construction consisting of 4 identical connecting neighborhoods with service areas separated by 2 hour fire walls between a common assembly classified occupancies, with no basement, built in 2020. The building is fully sprinklered throughout and has supervised smoke detection in the corridors, resident rooms, and spaces open to the corridors.</p> <p>The facility has 123 certified beds. At the time of survey the census was 120.</p> <p>The requirements at 42 CFR, subpart 483.90 (a) is MET.</p>	K0000			