



AECOM

Drawn: DP

Date: 9/17/2024

Approved: ED

Date: 9/17/2024

Project #: 60560354

●

No Detections of the 25 Analyzed PFAS

●

One or more of the 25 Analyzed PFAS Detected

●

One or more of the 7 PFAS with Michigan Part 201 Drinking Water Criteria Detected Above Criteria

Surface Water Body

Michigan Part 201 Residential & Nonresidential Drinking Water Criteria (DWC), ng/L

PFHxA = 400,000

PFOA = 8

PFNA = 6

PFBS = 420

PFHxS = 51

PFOS = 16

HFPO-DA = 370

N

0

200

400

Feet

MPART - 2<sup>nd</sup> STREET LINCOLN

PFAS HEAT MAP

ALCONA COUNTY, MI

Document Path: L:\DCS\GIS\ArcMap\_GeoDB\_Projects\ENV\GIS\_Data\GIS\MPART\MXDs\Lincoln\_2ndStreet\_Heatmap.mxd