

**AECOM**

Drawn: DP Date: 9/13/2022

Approved: ED Date: 9/13/2022


Project #: 60560354



**Legend**

- Residential Well Sample**
- No Detections of the 18 Analyzed PFAS
  - One or more of the 18 Analyzed PFAS Detected
  - One or more of the 7 PFAS with Michigan Part 201 Drinking Water Criteria Detected Above Criteria

Michigan Part 201 Residential & Nonresidential  
 Drinking Water Criteria (DWC), ng/L  
 PFHxA = 400,000  
 PFOA = 8  
 PFNA = 6  
 PFBS = 420  
 PFHxS = 51  
 PFOS = 16  
 HFPO-DA = 370



**MIDDLEVILLE WWTP  
 PFAS HEAT MAP**

**DRAFT**

**BARRY COUNTY, MI**