



**West Test Site
Highest GW
Exceedances**
 PFOA 139 ppt
 PFNA 7.7 ppt
 PFHxS 2,590 ppt
 PFOS 1,490 ppt

**Emergency Response Area
Highest GW Exceedances**
 PFOS 65.2 ppt
 PFHxS 74.2 ppt

**South Test Site
Highest GW
Exceedances**
 PFBS 451 ppt
 PFHxS 2,080 ppt

**BATTLE CREEK EXECUTIVE AIRPORT
AT KELLOGG FIELD**

AFFF Use Locations

Reported AFFF Use Locations

- Test Site
- Crash Site
- Other Site
- Emergency Response Area
- Approximate ANG Area

0 1,000 2,000 ft

Figure 1-1. AFFF Use Areas Investigated at BTL.

