




AECOM

Drawn: DP Date: 5/19/2026

Approved: DB Date: 5/19/2026

Project #: 60778704



Legend

★ Source Areas associated with Verona Well Field

Drinking Water Well Sample

● No Detections of the Analyzed PFAS Substances

▲ One or more of the Analyzed PFAS Substances Detected

■ One or more of the 7 PFAS Substances with Michigan DWC Detected at or Above Criteria


— Surface Water Body

Sampling Status

◡ Canvassed

⊞ Connected to Municipal Water

Michigan Drinking Water Criteria (DWC), ppt
 PFHxA = 400,000 PFHxS = 51
 PFOA = 8 PFOS = 16
 PFNA = 6 HFPO-DA = 370
 PFBS = 420



**FIGURE 1
 PFAS CRITERIA HEAT MAP**

**MPART - VERONA WELL FIELD
 CALHOUN COUNTY, MI**