



Drawn: DP

Date: 5/1/2025

Approved: DB

Date: 5/1/2025

Project #: 60733947

**Legend**

●

No Detections of the Analyzed PFAS Substances

●

One or more of the Analyzed PFAS Substances Detected

●

One or more of the 7 PFAS Substances with Michigan DWC Detected at or Above Criteria

—

Surface Water Body

Michigan Drinking Water Criteria (DWC), ppt

PFHxA = 400,000

PFOA = 8

PFNA = 6

PFBS = 420

PFHxS = 51

PFOS = 16

HFPO-DA = 370

N

0

400

800

Feet

FIGURE 2

PFAS CRITERIA HEAT MAP

BLAIR TOWNSHIP

AREA OF INTEREST

GRAND TRAVERSE COUNTY, MI

Document Path: C:\Users\lendriss-periardi\OneDrive - AECOM\920\_929\_GIS\_Graphics - EGLE\_Dorin\_Projects\Blair\20250501\Work\LEER\_Blair\_Twp.aprx, Blair\_Township\_Heatmap