



PFAS Analyte	Generic Clean-up Criteria (ng/L)
Perfluorooctanoic acid (PFOA)	8
Perfluorooctane sulfonate (PFOS)	16
Perfluorononanoic acid (PFNA)	6
Perfluorohexane sulfonate (PFHxS)	51
Perfluorobutanesulfonic acid (PFBS)	420
hexafluoropropylene oxide dimer acid (HFPO-DA)	370
Perfluorohexanoic acid (PFHxA)	400,000

EGLE

AECOM

Prepared: 1/3/2022



Legend

- Residential Well Sampling Location
- △ Groundwater Sampling Location
- PFAS Compounds (ppt)**
- Non-Detect for Part 201 PFAS Compounds
- Detection below Part 201 PFAS Criteria, but no Exceedance
- One or more Part 201 PFAS Criteria Exceeded
- △ Monitoring well not sampled in January 2020

- ▨ Discharge Area
- ▭ Former Wastewater Treatment Lagoon

N

0 800 1,600 3,200 Feet

DRAFT

FIGURE 2

CONCENTRATIONS OF PFAS COMPOUNDS (ppt) COMPARED TO PART 201 CRITERIA

CEDAR SPRINGS WWTP INVESTIGATION

KENT COUNTY, MI

Aerial: ESRI World Imagery 2018