



Rose & Westra
A Division of GZA

GEOTECHNICAL
ENVIRONMENTAL
ECOLOGICAL
WATER
CONSTRUCTION
MANAGEMENT

The Widdicomb Building
601 Fifth Street NW
Suite 102
Grand Rapids, MI 49504
T: 616.956.6123
F: 616.288.3327
www.rosewestra.com
www.gza.com



TANNERY INTERCEPTOR SYSTEM CONCEPTUAL DESIGN

Rockford, Kent County, Michigan

March 20, 2020
File No. 16.0062335.60

PREPARED FOR:
Wolverine World Wide, Inc.
Rockford, Michigan

Rose & Westra, a Division of GZA GeoEnvironmental, Inc.
601 Fifth Street NW | Suite 102 | Grand Rapids, MI 49504
616.956.6123

31 Offices Nationwide
www.gza.com

Copyright© 2020 GZA GeoEnvironmental, Inc.



TABLE OF CONTENTS

1.0	INTRODUCTION	1
2.0	BACKGROUND	1
3.0	OBJECTIVE	1
4.0	GROUNDWATER CAPTURE	1
5.0	GROUNDWATER TREATMENT.....	2
6.0	IMPLEMENTATION	3
7.0	ANTICIPATED SCHEDULE	3

APPENDED FIGURES

FIGURE 1	GROUNDWATER CONTOURS AND FLOW DIRECTIONS
FIGURE 2	PFOS CONCENTRATION MAP
FIGURE 3	INTERIM RESPONSE PRELIMINARY SITE PLAN
FIGURE 4	TENTATIVE TREATMENT SYSTEM SCHEMATIC

ATTACHMENT 1 – TREATMENT SYSTEM BASIS OF DESIGN



1.0 INTRODUCTION

On behalf of Wolverine Worldwide, Inc. (Wolverine), Rose & Westra, a Division of GZA GeoEnvironmental, Inc. (R&W/GZA), prepared this Technical Memorandum to describe the goal, technical approach, and conceptual design for the interim remedy (IR), which includes groundwater interception, treatment, and discharge at Wolverine's former tannery site located at 123 North Main Street NE, Rockford, Michigan (Site).

2.0 BACKGROUND

The ongoing remedial investigation (RI) indicates groundwater north and south of Rum Creek generally flows to and likely discharges to the Rogue River. Figures 1 and 2 show groundwater contours (the groundwater flow direction is perpendicular to the contour lines) and the highest Perfluorooctanesulfonic acid (PFOS) concentrations measured in 2017 and 2018. The PFOS concentrations in groundwater exceed the generic groundwater-surface water interface cleanup criterion established under Part 201 of Michigan's Natural Resources and Environmental Protection Act.

The RI provided significant information utilized in the treatment system design, including on-site PFOS distribution, approximate groundwater flux to the Rogue River (estimated from slug tests performed in 2014 and pump tests performed in 2018), and concentrations of other groundwater constituents which can reasonably be predicted to affect perfluoroalkyl substances (PFAS) treatment or discharge.

3.0 OBJECTIVE

The objective of the IR is to reduce the mass of PFOS discharging with groundwater from the Site to the Rogue River. Groundwater will be stagnated east of the Rogue River, captured, treated, and discharged. The IR is not designed to remove all PFAS from groundwater at the Site, but to reduce PFOS migration to the Rogue River while further investigations and longer-term solutions are studied.

4.0 GROUNDWATER CAPTURE

Because the apparent bottom of the shallow groundwater formation north of Rum Creek is near the surface, most shallow groundwater north of Rum Creek will be captured using a French drain/interceptor trench. The trench will be set on the bottom of the shallow groundwater formation. One or more capture/purge wells may be used to collect groundwater from near Rum Creek where the bottom of the shallow groundwater formation is deeper. Groundwater from the trench and capture wells (if any) will be pumped to the treatment building.

The bottom of the shallow aquifer is deeper south than north of Rum Creek; therefore, a series of capture wells will likely be used in this area. The spacing and locations for these purge wells are based on hydraulic conductivity estimates from the slug and pump tests described previously and a particle tracking groundwater model. Several paired shallow and deep capture wells will be used in the southern portion of the Site where multiple interconnected groundwater formations are present. Figure 3 presents a tentative layout for the capture system. As indicated on this Figure, all locations are tentative at this time.

The testing and modeling performed to date suggest individual capture wells will produce less than 1 gallon per minute (gpm) on a continuous basis. R&W/GZA could not identify a variable speed pump having appropriate discharge characteristics for such small flow rates. Therefore, all pumps will be operated on an on-off basis. During startup and balancing for the first several months of operation, pumps in the French drain and capture



wells will be activated by a pressure transducer (level sensor) in the equalization tank. Pressure transducers in the French drain manhole and in all capture wells will stop individual pumps at an adjustable, pre-determined (low) water level. Therefore, each capture location will be controlled by both the equalization tank and their own individual water levels. When the equalization tank reaches its high-water elevation, all pumps will shut off until the equalization tank returns to its low-water level and this cycle will repeat continuously.

Captured groundwater will be pumped via a force main to the treatment building. The portion of the force main passing under Rum Creek will be installed using horizontal boring.

Pressure transducers will also be installed in a series of monitoring wells between the capture wells/French drain and Rogue River as well as one or more points within Rum Creek and/or the Rogue River. These will record water levels to assess the local groundwater flow direction between the surface water bodies and capture system. While not used to directly control the capture system, these measurements will be used to adjust the low-water set point in the capture wells and manhole to optimize/balance the capture system.

5.0 GROUNDWATER TREATMENT

While multiple emerging technologies are being researched and tested for PFAS treatment, R&W/GZA selected granular activated carbon (GAC) sorption for the primary treatment technology because its effectiveness has been thoroughly demonstrated and systems using GAC can be designed, constructed, and implemented promptly. In addition to numerous literature studies, the Point-of-Entry Treatment filters installed at selected homes in the House Street and Wolven-Jewell study areas demonstrate the effectiveness of the proposed GAC treatment.

Initially, treated groundwater will be discharged to the City of Rockford sanitary sewer leading to the North Kent Sewer Authority (NKSA) treatment plant. NKSA has conditionally approved the proposed discharge and treatment scheme. Based on the substantial groundwater test results, only PFAS treatment is required to comply with the NKSA discharge limits.

Based on estimated iron concentrations from groundwater sampling performed to date, iron removal prior to the GAC treatment will be cost effective. Therefore, the groundwater treatment system will include:

- Iron removal - aeration, chemical feed, and settling
- Equalization
- Sediment filtration
- Ultra-Violet sanitizer (to reduce potential bacteriological fouling on the GAC)
- Two-stage GAC
- Sediment filtration
- Effluent metering and sampling

Figure 4 presents the treatment schematic. Because the flow to the treatment system will be increased over time, the design accommodates two different size GAC vessels. The system is designed to accommodate flow from 3 to 50 gpm and includes an effluent clear well to provide water for re-bedding and backwashing the GAC columns. The Treatment System Basis of Design is Attachment 1.

The system will also have connections for full-scale, two-stage, resin (ion exchange) sorption as an alternative or supplement to the GAC. The design accommodates resin sorption before, after, or in place of the GAC.



Sludge from iron removal will be stored prior to off-site disposal in the liquid/semi-solid state.

6.0 IMPLEMENTATION

The IR is subject to local, state, and federal permit requirements. These include, but are not limited to:

- Local zoning, site plan approval and building codes
- Surface water/utility crossing
- Capture well, pipe and conduit installation within the former railroad right-of-way owned by Michigan Department of Transportation.
- Effluent discharge

Wolverine already has conditional discharge approval. All other approvals will be obtained prior to construction.

The conditional discharge approval from NKSA requires the system to be started incrementally, i.e., the flow will be increased stepwise. Therefore, the capture wells south of Rum Creek will be installed in phases (currently two phases are proposed).

7.0 ANTICIPATED SCHEDULE

The design is complete to the 50-percent stage which is sufficient for site plan approval, permitting, and cost estimating. Wolverine will apply for all approvals in Spring 2020.

Construction will likely commence once approvals have been received. We anticipate approximately four months until substantial completion and startup will commence immediately thereafter.



FIGURES



Legend

- Ground Water Sample Location
- Estimated Hydraulic Head Contour
- Inferred Direction of Groundwater Flow

NOTES

1. CALCULATED VALUES OF OVERBURDEN GROUNDWATER HYDRAULIC HEAD ARE BASED ON DEPTH TO GROUNDWATER MEASUREMENTS MADE BY R&W/GZA ON AUGUST 29, 2018. CALCULATED VALUES OF OVERBURDEN GROUNDWATER HYDRAULIC HEAD BASED ON MEASUREMENTS MADE ON OTHER DATES INCLUDING MARCH 14, 2018 AND AUGUST 3, 2018 WERE INCLUDED FOR LOCATIONS THAT WERE NOT INCLUDED IN THE AUGUST 29, 2018 MEASUREMENT ROUND AND ARE DENOTED WITH ***.

2. ESTIMATED HYDRAULIC HEAD CONTOURS ARE BASED ON DEPTH TO WATER LEVEL MEASUREMENTS MADE IN WELLS SCREENED WITHIN THE UPPER APPROXIMATELY 10 FEET OF THE SATURATED ZONE. CALCULATED VALUES OF HYDRAULIC HEAD BASED ON DEPTH TO WATER LEVEL MEASUREMENTS MADE IN WELLS SCREENED WITHIN DEEPER INTERVALS ARE ALSO SHOWN BUT WERE NOT USED IN THE ESTIMATION OF THE HYDRAULIC HEAD CONTOURS DEPICTED HEREON. FOR LOCATIONS WITH MULTIPLE WELLS THE DEPTH TO WATER LEVEL MEASUREMENT FROM THE WELL WITH THE SHALLOWEST WELL SCREEN WAS USED IN THE ESTIMATION OF THE HYDRAULIC HEAD CONTOURS.

3. CALCULATED VALUES OF OVERBURDEN GROUNDWATER HYDRAULIC HEAD FOR WELLS SCREENED AT DEPTHS WITHIN THE SATURATED ZONE GREATER THAN APPROXIMATELY 10 FEET ARE INCLUDED ON THE FIGURE FOR COMPARISON TO THE SHALLOW SCREENED WELLS.

4. ESTIMATED HYDRAULIC HEAD CONTOURS AND INFERRED DIRECTIONS OF GROUNDWATER FLOW ASSUME HOMOGENEOUS ISOTROPIC POROUS MEDIA CONDITIONS. LOCALIZED VARIATIONS IN HYDRAULIC HEAD AND THE DIRECTION OF GROUNDWATER FLOW WILL OCCUR DUE TO SPATIAL VARIATIONS IN AQUIFER PROPERTIES.

5. BASEMAP CONTAINS GEOREFERENCED AERIAL IMAGERY PROVIDED BY GOOGLE EARTH DATED TO 2017.


0 25 50 100
SCALE IN FEET

UNLESS SPECIFICALLY STATED BY WRITTEN AGREEMENT, THIS DRAWING IS THE SOLE PROPERTY OF GZA GEOENVIRONMENTAL, INC. (GZA). THE INFORMATION SHOWN ON THE DRAWING IS SOLELY FOR THE USE BY GZA'S CLIENT OR THE CLIENT'S DESIGNATED REPRESENTATIVE FOR THE SPECIFIC PROJECT AND LOCATION IDENTIFIED ON THE DRAWING. THE DRAWING SHALL NOT BE TRANSFERRED, REUSED, COPIED, OR ALTERED IN ANY MANNER FOR USE AT ANY OTHER LOCATION OR FOR ANY OTHER PURPOSE WITHOUT THE PRIOR WRITTEN CONSENT OF GZA. ANY TRANSFER, REUSE, OR MODIFICATION TO THE DRAWING BY THE CLIENT OR OTHERS, WITHOUT THE PRIOR WRITTEN EXPRESS CONSENT OF GZA, WILL BE AT THE USER'S SOLE RISK AND WITHOUT ANY RISK OR LIABILITY TO GZA.

WOLVERINE WORLDWIDE / WARNER, NORCROSS AND JUDD
FORMER TANNERY SITE
123 MAIN STREET, ROCKFORD, MI
2018 DATA SUMMARY REPORT

**GROUNDWATER POTENTIOMETRIC CONTOUR MAP
SHALLOW OVERBURDEN**

PREPARED BY:	GZA GeoEnvironmental, Inc. Engineers and Scientists www.gza.com	PREPARED FOR:	WOLVERINE WORLD WIDE / WARNER, NORCROSS & JUDD			
PROJ MGR:	LN	REVIEWED BY:	LN	CHECKED BY:	JW	FIGURE
DESIGNED BY:	JW	DRAWN BY:	MD	SCALE:	1 in = 50 ft	1
DATE:	October 26, 2018	PROJECT NO:	16.0062335.02	REVISION NO:		



ALL PIPES ROUTED UNDER RUM CREEK ARE AS FOLLOWS:
- 3" HDPE INSIDE OF 4" HDPE CARRIER PIPE (ACTIVE)
- 3" HDPE INSIDE OF 4" HDPE CARRIER PIPE (SPARE)
- 3" POWER CONDUIT (ACTIVE)
- 2" FIBER OPTIC CONDUIT (ACTIVE)
- 2" CONDUIT (SPARE)

ALL PIPES/CONDUITS BEING ROUTED BENEATH RUM CREEK MUST BE MINIMUM OF 3ft BELOW CREEK BOTTOM - (PER PERMIT)

4ft DIA PRECAST MANHOLE FOR TERMINATION OF ENDS OF CARRIER PIPE (MANHOLE TYP. AT BOTH SIDES OF CREEK)

NOTE:
1) BASE MAP DERIVED FROM NEDERVELD SITE SURVEY DATED NOVEMBER 22, 2013


NOTE:
LOCATIONS OF GROUNDWATER TREATMENT BLDG, DEEP & SHALLOW EXTRACTION WELLS & THEIR ASSOCIATED MANHOLE LOCATIONS ARE ALL TENTATIVE.

SITE PLAN W/ PROPOSED GROUNDWATER INTERIM REMEDY

DRAFT COPY

NO.	REVISIONS	BY	DATE

WOLVERINE WORLD WIDE/WNJ
FORMER TANNERY SITE, ROCKFORD, MICHIGAN
GROUNDWATER INTERIM REMEDY



ROSE & WESTRA
A DIVISION OF GZA
Grand Rapids, Michigan

GEOTECHNICAL-ENVIRONMENTAL-ECOLOGICAL-WATER-CONSTRUCTION MANAGEMENT

PROJECT NO.
16.0062335.60
SHEET NO.



ATTACHMENT 1

TREATMENT SYSTEM BASIS OF DESIGN

Wolverine Tannery IR
Wastewater Treatment

Last Revised: 1/24/2020 - MAW

Influent Flow-	gpm	gpd
Phase I - NKSA discharge	7	10080
Phase II - NPDES discharge (includes Phase I)	28	40320
Phase III (Phase I & II + Unknown future)	50	72000
Extraction Wells	gpm	gpd
Phase I (5-6) MH-1 to MH-6 + North Trench Drain	7	10080
Phase II (~ 18 additional extraction wells)	21	30240
Subtotal	28	40320

Influent Concentrations

PFAS - GW	28740 ppt
Fe - GW	1.27 mg/l
Ammonia - GW	1.18 mg/l
Chloride	133 mg/l

Effluent Required for NKSA discharge

PFAS	ND
------	----

Aeration Tank

Design Objective - oxidize iron for precipitation and settling.

Since the rate of the reaction is pH dependent, pH adjustment equipment will be installed to raise the pH, if required.

At pH 6 - requires > 100 hours.

At pH of 7.0 - 90% Fe+2 oxidation requires 1 hour at 21C - requires 10 hours at 5C

At pH of 8 - 90% Fe+2 oxidation in 30 seconds.

However, the aeration tank will be designed to provide 30 minutes of detention at a pH of 7.5 based on no addition of hydroxide.

Average pH of Groundwater	7.5
Detention Time (minimum)	30 minutes

Tank volume based on Phase III - 50 gpm	1500 gallon
Type	Concrete
Size (cu ft) required	201
width	3 ft
length	14 ft
depth	6 ft (swd)
Cubic foot designed	252

Oxygen Required:

TOC	4 mg/l	assume 3lb Oxygen/lb TOC
Fe	1.27 mg/l	assume 1lb/lb
Increase DO	6 mg/l	
Oxygen Required	11.6 lb/day	
	0.4833333 lb oxygen/hour	
say 4% transfer	0.04	
say .21 percent oxygen in air	0.21	
Air required	57.5 lb air/hour	
Air density	0.0765 lb/cu ft	
	752 cu ft/hr	
	13 CFM	

Notes: Use NaOCl to inhibit nitrification if needed

Air Supply

Type	Rotary Vane
Number	2 installed Standby
Equal to	PB Gast
Diffusers	removable for cleaning hand drilled orifices - Fabricate with 1" SS pipe

Settling Tank

Overflow Rate (OR)	0.5 gpm/sf
Surface Area Required at 50 gpm influent flow	100 SF
Area provided	
length	18

width	6
Area provided	108 SF

Wet Well/Equalization

Purpose - on-off control of PD pumps discharging to treatment

Size - on-off cycle, dwell in tankage when all off, re-bed backwash

8078 gallon

Available for re-bed backwash

6000 gallon

Pumps

P-1 - 1 standby (on shelf) for NKSA

7 gpm

P-2 - NPDES Phase II

28 gpm

Control

Set flow rate and control pump speed to maintain flow rate.

Solids Generation

Iron hydroxide solids

1.27 mg/l

Fe-OH Solids

0.7626096 lb/day

Fe-OH Solids

0.7626096 lb/day

Chemical/conditioning

2.5 Multiplier

Total Solids 50 gpm

1.906524 lb/day

Monthly

57.19572 lbs/month

underflow (2-5%) use 3

0.03

volume

228.6 gallons/month

Tank size - 3' wide, 6' deep, 18' long =

2424 gallons

Months of storage

10.601575

Ultimate disposal

Pump and Haul

Pre-Carbon Sediment Filters

Number

2

One operating, one standby

Polyester Felt Bag

20-25 micron

Mesh basket

40 micron

UV Sanitizer

UV Viqua Pro 50

Design flow

50 gpm

GAC Vessels

	Phase I NKSA	Phase II NPDES
Concentration ppt	28740	28740
Lead size CF	24	38
Peak flow (gpm)	10	28
Avg Flow (gpm)	7	28
# columns in lead	1	1
Column height (in)	72	72
Column dia (in)	30	48
Column Area (SF)	4.9	12.6
HLR Average	1.4	2.2
HLR Peak	2.0	2.2
EBCT min	18	10
tb (time to breakthrough, days)	88	35

Post-Carbon Sediment Filters

Number

1

Polyester Felt Bag

20-25 micron

Mesh basket

40 micron

Sampling/Metering

ISCO Refrigerated Model 5800 - Flow Proportional Sampling



GZA GeoEnvironmental, Inc.