



AECOM

Drawn: DP Date: 5/19/2022

Approved: DB Date: 5/19/2022

Project #: 60588767



- Legend**
- Residential Well Sample
 - Livestock Well Sample
 - PFAS Results**
 - Below Detection Limit (DL) for all analyzed PFAS
 - >DL and ≤Part 201 Drinking Water Criteria (DWC)
 - >Part 201 DWC
 - ▭ Biosolids Application
 - ➡ Approximate GW Flow Direction

Michigan Part 201 Residential & Nonresidential Drinking Water Criteria (DWC), ng/L

PFHxA = 400,000	PFHxS = 51
PFOA = 8	PFOS = 16
PFNA = 6	GenX = 370
PFBS = 420	

14 PFAS were analyzed for samples collected in 2019.
18 PFAS were analyzed for samples collected in 2021 and 2022.



RESIDENTIAL WELL SAMPLING RESULTS

LIVINGSTON COUNTY