



Ruben John, Sr. Project Manager  
F&V Operations.  
2059 Charms Road Wixom, MI 48393  
248-960-0870  
r.john@fv-operations.com

April 16, 2021

Mr. Ed Barriager  
TRIBAR.  
48668 Alpha Dr.  
Wixom, Michigan 48393

cc: T. Sikma, City of Wixom

**RE: NOTICE OF SIGNIFICANT NONCOMPLIANCE-VIOLATION WITH YOUR  
WASTEWATER DISCHARGE PERMIT – UNPERMITTED DISCHARGE**

Dear Mr. Barriager:

Tribar Plant 5 is in violation of the terms of its Industrial Discharge Permit. The November 2020 results for PFAS/PFOS were higher than water quality standards, PFOS 2700 ng/L & PFOA <180 ng/L and have continued to persist with out remediation.

Please prepare and submit a written report to explain why this occurred and a plan for the satisfactory correction and prevention of similar situations.

It is important to note that violations of the City's Industrial Pretreatment Program are also violations of Federal and State law and those future violations may result in more stringent enforcement measures.

Should you have any questions regarding this violation, do not hesitate to contact us at (248) 960-0870.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ruben John", is written over a faint, larger version of the signature.

Ruben John  
Plant/Project Manager  
F&V Operations-Wixom Operations